

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

116 Nassau Street

Received: 6/30/02

7:40:00 PM

ATC Group #: 8355

Analysis Date: 6/30/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.3µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
003 8355 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
004 8355 -2	1795.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
005 8355 -3	1790.00	0.0450	0	CHRYSTOLE	0	1	0.0048	22.24	0.0048
006 8355 -4	1785.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
007 8355 -5	1783.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____

8355 24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

W&P FILE #: 1079. 01.02

CLIENT: DEP

LABORATORY: ATC ENVI R

CONTACT: *Mike P. [Signature]*

PROJECT: NASSAU ST. 132nd - 115th St.

ANALYSIS METHOD: PCM TEM TEM

LOCATION: 116 NASSAU ST.

circle one 7400 (AHERA) EPA LEVEL II

TECHNICIAN: *ELLEN CARO*

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (µg./cc.)
				START	STOP					
001	FIELD BLANK	1		5		0931				
002	FIELD BLANK	1		5		0932				
003	132 NASSAU SOUTH	3		5	5	0935	15:35	360	1802	
004	112 NASSAU	3		5	5	0937	15:36	359	1795	
005	112 NASSAU	3		5	5	0939	15:37	358	1790	
006	118 NASSAU NORTH	3		5	5	0941	15:38	357	1785	
007	118 NASSAU SOUTH	3		5	5	0942	15:39	356	1785	
008	CAPPED BLANK	1								

COMMENTS:

SAMPLE BY: <i>ELLEN CARO</i>	DATE: 6/30/02
SIGNATURE: <i>[Signature]</i>	
RELEASED BY: <i>[Signature]</i>	DATE: 6/30/02
SIGNATURE: <i>[Signature]</i>	
RECEIVED BY: <i>[Signature]</i>	DATE: 6/30
SIGNATURE: <i>[Signature]</i>	DATE: 6/30

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS METHOD



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8355

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
116 Nassau Street

Date: Sunday, June 30, 2002

Time: 11:08:51 PM

Comments:

Number of Pages: 3
(including cover page)

64