

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 6/30/02 7:40:00 PM
ATC Group #: 8354
Analysis Date: 6/30/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
111 Nassau Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity	Asbestos Concentration		Notes
					0.5µ-5µ	5µ	(S/cc)	(S/mm ²)	(S/cc)	
01 8354 -1	1584.00	0.0562	0	None Detected	0	0	0.0043	<17.79	<0.0043	
02 8354 -2	1584.00	0.0562	0	None Detected	0	0	0.0043	<17.79	<0.0043	
03 8354 -3	1584.00	0.0562	0	None Detected	0	0	0.0043	<17.79	<0.0043	
04 8354 -4	1584.00	0.0562	0	None Detected	0	0	0.0043	<17.79	<0.0043	
05 8354 -5	1584.00	0.0562	0	None Detected	0	0	0.0043	<17.79	<0.0043	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

62

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____

P.O.

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: Dep

W&P FILE #: 1075 el 02

LABORATORY: KTC

CONTACT:

PROJECT: FACADE / ROOF CLEANUP

ANALYSIS METHOD: PCM TEM TEM
circle one AHERA EPA LEVEL II

LOCATION: 111 JASSAN ST

TECHNICIAN: B. B. B.

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	TIME OFF	TOTAL TIME	VOLUME (Hers)	CONCENTR. (Hb/cc)
01	Upper roof North by West	3		4	1	9:40	10:00	396	1584	
02	North by West - N.Y.	3		4	1	9:41	10:01	396	1584	
03	East	3		4	1	9:43	10:02	396	1584	
04	North by West - N.Y.	3		4	1	9:45	10:03	396	1584	
05	North by West - N.Y.	3		4	1	9:47	10:04	396	1584	
06	East	3		4	1	9:49	10:06	396	1584	
07	East	3		4	1	9:51	10:08	396	1584	

COMMENTS:

SAMPLE BY: B. B. B.	DATE: 06/30
SIGNATURE: [Signature]	
RELEASED BY: [Signature]	DATE: 06/30
SIGNATURE: [Signature]	
RECEIVED BY: [Signature]	DATE: 06/30
SIGNATURE: [Signature]	19:10

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 8354

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
111 Nassau Street

Date: Sunday, June 30, 2002

Time: 11:09:25 PM

Number of Pages: 3
(including cover page)

Comments:

61