

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/3/02 8:00:00 AM
 ATC Group #: 8385
 Analysis Date: 7/3/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File # 1079.01.02
 88 Nassau Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
01 8385 -1	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
02 8385 -2	1440.00	0.0562	0	CHRYSTILE	0	0.0048	17.79	0.0048
03 8385 -3	1440.00	0.0562	0	CHRYSTILE	0	0.0048	17.79	0.0048
04 8385 -4	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
05 8385 -5	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.
IT MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O. _____

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
--	-----------------------	-----------------------	----------------------	----------------------	---------------------------

W&P FILE #: 1079.61.02

CONTACT:

CLIENT: NYKDEP

PROJECT:

LOCATION: ~~88~~ NASIAU 5X

LABORATORY: ATC

ANALYSIS METHOD: PCM

ANALYSIS METHOD: PCM TEM TEM
7400 AMERA EPA LEVEL II

TECHNICIAN: L. SOTO

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
				START	STOP					
01	ON 122 FULTON ROOF LEFT SIDE	3	01	4	4	11:00	17:00	360	1440	
02	ON 122 FULTON ROOF RIGHT SIDE	3	02	4	4	11:01	17:01	360	1440	
03	ON 122 FULTON ROOF CENTER	3	03	4	4	11:02	17:02	360	1440	
04	ON 122 FULTON ROOF NEAR BACK WALL	3	04	4	4	11:03	17:03	360	1440	
05	ON 122 FULTON ROOF NEAR AC	3	05	4	4	11:04	17:04	360	1440	
06	FIELD BLOCK	1								
07	FIELD BLOCK	1								
08	CORNER BLOCK	1								

COMMENTS:

SAMPLE BY: Louis Soto	DATE: 7-2-01
SIGNATURE: [Signature]	
RELEASED BY: Louis Soto	DATE: 7-2-01
SIGNATURE: [Signature]	
RECEIVED BY: [Signature]	DATE: 7/3/01
SIGNATURE: [Signature]	8 AM

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8385

Date: Wednesday, July 03, 2002

Client Project: NYC-DEP W & P File # 1079.01.02
88 Nassau Street

Time: 2:41:57 PM

Comments:

Number of Pages:

3
(including cover page)