

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File # 1079.01.02

86 Nassau Street

Received: 7/3/02

8:00:00 AM

ATC Group #: 8386

Analysis Date: 7/3/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8386 -1	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
04 8386 -2	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
05 8386 -3	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
06 8386 -4	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049
07 8386 -5	1750.00	0.0450	0	None Detected	0	0	0.0049	<22.24	<0.0049

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10679

225 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-9530

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE ____ OF ____
P.O. _____

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NYC DEP
PROJECT: 86 MASSA ST
LOCATION: ROAD
2386

W&P FILE #: 1079-01-02
LABORATORY: NYC
ANALYSIS METHOD: PCM TEM
circle one 7400 (HEPA EPA LEVEL II)
TECHNICIAN: F. O'Sullivan

CONTACT: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb/cc.)
				START	STOP					
01	Blank	1								
02	11	1								
03	DECON	3				1030	1620	350	1750	
04	EAST SIDE	3				1032	1622	350	1750	
05	WEST SIDE	3				1034	1624	350	1750	
06	SOUTH SIDE	3				1036	1626	350	1750	
07	NORTH SIDE	3				1038	1628	350	1750	
08	Blank	1								

COMMENTS:

SAMPLE BY: F. O'Sullivan DATE: 09-02-01
SIGNATURE: _____
RELEASED BY: F. O'Sullivan DATE: 09-02-01
SIGNATURE: _____
RECEIVED BY: [Signature] DATE: 7/3/02
SIGNATURE: [Signature] 8 AM

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8386

Date: Wednesday, July 03, 2002

Client Project: NYC-DEP W & P File # 1079.01.02
86 Nassau Street

Time: 2:42:25 PM

Comments:

Number of Pages: 3

(including cover page)