

Asbestos Inspection Report

Premise No. 87 NASSAU STREET					Inspection Date: AS NOTED	
Floor ROOF & FACADE	Zip 10038	Borough 1	Block 79	Lot 1	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type COMMERCIAL		Basis of Inspection WTC Survey		Photos Taken (Yes/ No)
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from: AS NOTED		
THURSDAY SEPTEMBER 12 2002 - FRIDAY SEPTEMBER 13 2002						
THE HANGING SCAFFOLDING IS ERECTED IN PREPARATION FOR THE CLEAN UP OF THE SOUTH FACADE OF THE PREMISE.						
SATURDAY SEPTEMBER 14 2002 - MONDAY SEPTEMBER 16 2002						
NO WORK WAS PERFORMED						
TUESDAY SEPTEMBER 17 2002 (800AM - 800PM)						
THE CLEAN UP OF THE PENTHOUSE ROOF OF THE PREMISE BEGAN TODAY. A REMOTE DECONTAMINATION UNIT WAS ERECTED ON THE SECOND FLOOR OF THE PREMISE. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP WAS PERFORMED BY DIPO ELEMO (CERTIFICATE # AH01-14694 EXP 03/03). AIR SAMPLES WERE RUN ON THE MAIN ROOF OF THE PREMISE.						
WEDNESDAY SEPTEMBER 18 2002 (800 AM - 800PM)						
PENTHOUSE ROOF CLEAN UP WAS COMPLETED TODAY. THE CLEAN UP OF THE MAIN ROOF AND THE CLEAN UP OF THE SOUTH FACADE BEGAN TODAY. AIR SAMPLING FOR THE MAIN ROOF CLEAN UP WAS PERFORMED BY DIPO ELEMO. AIR SAMPLING FOR THE SOUTH FACADE CLEAN UP WAS PERFORMED BY YURI BEDIN (CERTIFICATE # AH 96-14947 EXP 02/03)						
THURSDAY SEPTEMBER 19 2002 (800AM - 800PM)						
CLEAN UP OF THE MAIN ROOF IS ONGOING. CLEAN UP OF THE SOUTH FACADE IS COMPLETED. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP WAS PERFORMED BY DIPO ELEMO.						

Asbestos Inspection Report

Premise No. 87 NASSAU STREET	Inspection Date: AS NOTED
Inspector Dennis Antzoulatos	Page <u>2</u> of <u>2</u>

FRIDAY SEPTEMBER 20 2002 (800 AM - 800 PM)

THE CLEAN UP OF THE MAIN ROOF WAS COMPLETED TODAY. THE ROOF AREA IS TOO WET FOR A VISUAL INSPECTION. AIR SAMPLING FOR THE DAY'S CLEAN UP ACTIVITIES WAS PERFORMED BY DIPO ELEMO. I CONDUCTED A VISUAL INSPECTION OF THE SOUTH FACADE AND THE FIRE ESCAPES. VISIBLE WTC DEBRIS WAS OBSERVED ON THE FIRE ESCAPES AND IN THE MIDDLE PORTION OF THE SOUTH FACADE. A RE CLEANING OF THESE AREAS WAS REQUESTED.

SATURDAY SEPTEMBER 21 2002 (800AM-700PM)

RE CLEANING OF THE SOUTH FACADE WAS COMPLETED. THE CLEAN UP OF THE SET BACK AREA BEGAN TODAY. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP WAS PERFORMED BY DIPO ELEMO OF WARREN & PANZER ENGINEERS. AIR SAMPLES (5) WERE RUN ON THE SEMI CIRCLE ROOF (3 SAMPLES) AND ON THE FIRE ESCAPE LANDING ON THE 3RD FLOOR (2 SAMPLES).

SUNDAY SEPTEMBER 22 2002

NO WORK WAS PERFORMED.

MONDAY SEPTEMBER 23 2002 (800 AM - 800 PM)

THE CLEAN UP OF THE SET BACK AREA WAS COMPLETED. AIR SAMPLING FOR THE DAYS ACTIVITIES WAS PERFORMED BY DIPO ELEMO. A VISUAL INSPECTION OF THE CLEANED WORK AREAS (SET BACK, SOUTH FACADE & FIRE ESCAPES AND THE MAIN AND PENTHOUSE ROOF) WAS CONDUCTED. NO VISIBLE WTC DEBRIS WAS OBSERVED. THE CLEAN UP PROJECT AT THE PREMISE IS NOW COMPLETE.