

10/23/2002 16:20 FAX

000

**ATHENICA**
 ENVIRONMENTAL SERVICES INC.
 Tel. (718) 784-7490
 Fax. (718) 784-4065

 CLIENT: Warner & Panzer Engineers, P.C.
 LABORATORY ID #: T02-10-124
 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.
 AVERAGE G.O. AREA (mm²): 0.013838

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 PROJECT: NYC DEP, 85 Nassau Street
 DATE OF REPORT: 10/20/02
 DATE OF ANALYSIS: 10/20/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT#	LAB. ID #	LOCATION	VOLUME (B)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (street/cm ³)	TOTAL ASBESTOS AIR CONC. (street/cm ³)	TOTAL ASBESTOS FILTER CONC. (air/mm ²)	AIR CONC. FOR STRUCT. 0.5<S<5µm	AIR CONC. FOR STRUCT. S>5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-124-3307	Entrance to roof	1350	5	0.0692	0.0041	<0.0041	<14.45	NA	NA	NA	NA
02	T02-10-124-3308	West side of roof 1	1350	5	0.0692	0.0041	<0.0041	<14.45	NA	NA	NA	NA
03	T02-10-124-3309	West side of roof 2	1350	5	0.0692	0.0041	<0.0041	<14.45	NA	NA	NA	NA
04	T02-10-124-3310	East side of roof 1	1350	5	0.0692	0.0041	<0.0041	<14.45	NA	NA	NA	NA
05	T02-10-124-3311	East side of roof 2	1350	5	0.0692	0.0041	<0.0041	<14.45	NA	NA	NA	NA

E. Sioukai

 ANALYST
 E. Sioukai

Sp. Dongaris

 LABORATORY DIRECTOR
 Spiro Dongaris

LABORATORY CERTIFICATION NUMBERS: NYE AP 101059, E1 AP 10055

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0890**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE OF

Fax (212) 922-0890

24 hr⁺/a12 hr⁺/a

3 hr t/a

+/a	Immediate +/a
1	1
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10
11	11
12	12
13	13
14	14
15	15
16	16
17	17
18	18
19	19
20	20
21	21
22	22
23	23
24	24
25	25
26	26
27	27
28	28
29	29
30	30
31	31
32	32
33	33
34	34
35	35
36	36
37	37
38	38
39	39
40	40
41	41
42	42
43	43
44	44
45	45
46	46
47	47
48	48
49	49
50	50
51	51
52	52
53	53
54	54
55	55
56	56
57	57
58	58
59	59
60	60
61	61
62	62
63	63
64	64
65	65
66	66
67	67
68	68
69	69
70	70
71	71
72	72
73	73
74	74
75	75
76	76
77	77
78	78
79	79
80	80
81	81
82	82
83	83
84	84
85	85
86	86
87	87
88	88
89	89
90	90
91	91
92	92
93	93
94	94
95	95
96	96
97	97
98	98
99	99
100	100

P.O.

W&P FILE #: 1049-01-02

CLIENT: MYCDEF

LABORATORY: A964241CA

ANALYSIS METHOD: PCM TEM

PROJECT: KODT
LOCATION: 85 MASSA 37

PROJECT: Roof

CONTACT:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTRA (lb./cc.)
01	ENTRANCE TO ROOF	3		3 3	0830 1600	450	1350	
02	WEST SIDE OF ROOF	3		3 3	0832 1602	450	1350	
03	WEST " " " "	3		3 3	0834 1604	450	1350	
04	EAST SIDE OF ROOF	3		3 3	0836 1606	450	1350	
05	EAST " " " "	3		3 3	0838 1608	450	1350	
06	BLANK	—						
07	"	—						

COMMENTS:

SAMPLE BY: 4684-1 O'Sullivan, E. DATE: 10-19-92

SIGNATURE: 

RELEASED BY: FE911 OSGUNDA DATE 10-79-82

SIGNATURE: [Signature]

RECEIVED BY: W. J. C. A. DATE 10/2/82

RECEIVED BY: A. C. GILBERT DATE: 7/20/52

SIGNATURE: [Signature]

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION