

10/23/2002 15:29 FAX

038


ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7499

Fax. (718) 784-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-10-140

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 85 Nassau Street

DATE OF REPORT: 10/21/02

DATE OF ANALYSIS: 10/21/02

 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O. % ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (strict/cm ³)	TOTAL ASBESTOS AIR CONC. (strict/cm ³)	TOTAL ASBESTOS FILTER CONC. (strict/cm ³)	AIR CONC. FOR STRUCT. 0.55S-5µm	AIR CONC. FOR STRUCT. ≥5µm	ASBEST. TYPE CURVS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-140-3404	East side of roof 1	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
02	T02-10-140-3405	East side of roof 2	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
03	T02-10-140-3406	Center of roof	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
04	T02-10-140-3407	West side of roof 1	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA
05	T02-10-140-3408	West side of roof 2	1800	4	0.0554	0.0039	<0.0039	<18.07	NA	NA	NA	NA

 ANALYST
B. Dimitrakas

 LABORATORY DIRECTOR
Spiro Dongaris

LABORATORY ID: T02-10-140-3404-3408

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling results will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVE, AP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

SEE REVERSE SIDE FOR ANALYSIS INFORMATION