

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 7/14/02 7:00:00 PM
ATC Group #: 8494
Analysis Date: 7/15/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
80 Nassau

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8494 -1	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
04 8494 -2	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
05 8494 -3	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
06 8494 -4	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042
07 8494 -5	1620.00	0.0562	0	None Detected	0	0	0.0042	<17.79	<0.0042

20

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Monday, July 15, 2002

Time: 10:21:33 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8494

Client Project: NYC DEP. W&P# 1079.01.02
80 Nassau

Number of Pages: 3 -
(including cover page)

19