

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/1/02 3:00:00 PM
 ATC Group #: 8370
 Analysis Date: 7/1/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
 80 Nassau

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
01 8370 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
02 8370 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
03 8370 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
04 8370 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
05 8370 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

14

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE _____ OF _____

8370

24 hr⁺/a	12 hr⁺/a	6 hr⁺/a	3 hr⁺/a	Immediate⁺/a
----------------------------	----------------------------	---------------------------	---------------------------	--------------------------------

○
R

CLIENT: NYC DEP
PROJECT: Roof Cleaning.
LOCATION: 80 Nassau

W&P FILE #: 1079: 61: 02

LABORATORY: ATC

ANALYSIS METHOD:	PCM	TEM	TEM

circle one
7400
AHERA
EPA LEVEL II

TECHNICIAN: CELESTINE HYMMLA

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOW RATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (mg./cc.)
01	Inside work area (near pump)			3 3	1030 1830	480	1440	
02	Inside work area (east)			3 3	1032 1832	480	1440	
03	Inside work area north			3 3	1034 1834	480	1440	
04	Inside work area west			3 3	1036 1836	480	1440	
05	B-1 decan			3 3	1038 1838	480	1440	
06	B-F							
07	B-F							
08	B-F-S							

COMMENTS:

SAMPLE BY:	Celestine N Mwangi	DATE:	07/09/08
SIGNATURE:	Celestine N Mwangi		
RELEASED BY:	Celestine N Mwangi	DATE:	07/09/08
SIGNATURE:	Celestine N Mwangi		
RECEIVED BY:	R. P. SACHAU	DATE:	7. 1. 02
SIGNATURE:	[Signature]		20:00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8370

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File #: 1079.01.02
80 Nassau

Date: Monday, July 01, 2002

Time: 11:53:49 PM

Comments:

Number of Pages: 3
(including cover page)

13