

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File # 1079.01.02

80 Nassua Street

Received: 7/4/02

5:00:00 PM

ATC Group #: 8396

Analysis Date: 7/4/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8396 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
02 8396 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
03 8396 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
04 8396 -4	1440.00	0.0562	0	CHRYSTOLE	0	1	0.0048	17.79	0.0048
05 8396 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
-----------------------	-----------------------	----------------------	----------------------	---------------------------

CLIENT: nyc Dep

PROJECT: SET BANK

LOCATION: 80 MASSACHUSETTS STREET

W&P FILE #: 1679:65:62

LABORATORY: ATC

ANALYSIS METHOD: PCM
circle one 7400

TECHNICIAN: Coley E. N. N. N.

CONTACT:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
01	DY DECON	3		3	0830 1630	480	1440	
02	EAST	3		3	0832 1632	480	1440	
03	WEST	3		3	0834 1634	480	1440	
04	SOUTH	3		3	0836 1636	480	1440	
05	NORTH	3		3	0838 1638	480	1440	
06	BF	1						
07	BF	1						
08	Copper Blank	1						

COMMENTS:

SAMPLE BY:	Celestine Monroe	DATE:	07/03/02
SIGNATURE:	Celestine	DATE:	07/03/02
RELEASED BY:	Celestine Monroe	DATE:	
SIGNATURE:	Celestine		
RECEIVED BY:	Al Green	DATE:	7/3/02
SIGNATURE:	Al Green		5:00pm

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8396

Date: Thursday, July 04, 2002

Client Project: NYC-DEP W & P File # 1079.01.02
80 Nassau Street

Time: 9:34:54 AM

Comments:

Number of Pages: 3
(including cover page)