

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
41/ 43 Murray Street

Received: 7/13/02

8:30:00 PM

ATC Group #: 8486

Analysis Date: 7/14/88

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
001A 8486 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
002A 8486 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
003A 8486 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
004A 8486 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048
005A 8486 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

Page 1 of 1

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

8486

P.O.

CLIENT: NYC DEP

W&P FILE #: 1079-0102

LABORATORY: NYC

CONTACT: Mike Moran

PROJECT: Windows Washed / Facade

ANALYSIS METHOD: PCM

TEM

LOCATION: 41 / 43 Murray St

TEM

EPA LEVEL II

SCA JOB#:

TECHNICIAN: N. Wells

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
001A	Adj to light post	3		6	6	07:35	11:35	240	1440	
002A	underneath sign #43	3		6	6	07:36	11:36	240	1440	
003A	Entrance to Bldg #43	3		6	6	07:37	11:37	240	1440	
004A	8' Adj to entrance #41	3		6	6	07:38	11:38	240	1440	
005A	comb' of sidewalk	3		6	6	07:39	11:39	240	1440	
006	field	1								
007	field	1								
008	Sealed	1								

COMMENTS: instructed to clean + monitor as over 500, only windows should be washed for facade by deep sitters.

SAMPLE BY: N. Wells	DATE: 7/13
SIGNATURE: N. Wells	
RELEASED BY:	DATE:
SIGNATURE:	
RECEIVED BY: A. TC	DATE: 07/13/02
SIGNATURE: H. Graft	19:15

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8486

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02
41/ 43 Murray Street

Date: Thursday, July 14, 1988

Time: 9:43:31 AM

Comments:

Number of Pages: 3
(including cover page)