

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

51 Murray Street

Received: 6/27/02

3:00:00 PM

ATC Group #: 8306

Analysis Date: 6/28/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 8306 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
02 8306 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
03 8306 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
04 8306 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
05 8306 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0977
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

PAGE 1 OF 1

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a
12 hr⁺/a
6 hr⁺/a
3 hr⁺/a
Immediate⁺/a

ॐ

W8P E# 1079..Ø1-Ø2:

CONTACT:

CLIENT: NYC DEP

LABORATORY: ATC

PROJECT: SI MURRAY ST

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	AHERA	EPA LEVEL II

circle one
7400
AHERA
EPA LEVEL II

TECHNICIAN: R. FERNANDEZ

902

[illegible]

COMMENTS:

SAMPLE BY: B. FERNANDEZ DATE: 6-27-02

SIGNATURE: _____

RELEASED BY: _____ DATE: _____

SIGNATURE: _____

RECEIVED BY: ATC DATE: 6/27/02

SIGNATURE: SP 15.00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION