

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File # 1079.01.02
49 / 51 Nassau Street

Received: 7/3/02

6:00:00 PM

ATC Group #: 8391

Analysis Date: 7/3/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5u-5 µm	5µ		(S/mm ²)	(S/cc)	
9 8391 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
10 8391 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
11 8391 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
12 8391 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046	
13 8391 -5	1500.00	0.0562	0	AMOSITE	0	1	0.0046	17.79	0.0046	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/run². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: N.Y.C. DEP

PROJECT: 49/51 MASSA ST

LOCATION: Roof

W&P FILE #: 1079-01-02

LABORATORY: A.T.C.

ANALYSIS METHOD: PCM 7400
circle one

TECHNICIAN: Dipo ELEMO

CONTACT: MIKE NOLAN

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (mg/cc.)
				START	STOP					
DE70302-9	By DEcon	TEM		10	10	1300	1530	150	1500	
DE70302-10	Inside door (N 49)	TEM		10	10	1302	1532	150	1500	
DE70302-11	WNA left (N 49)	TEM		10	10	1304	1534	150	1500	
DE70302-12	WNA Right (N 49)	TEM		10	10	1306	1536	150	1500	
DE70302-13	WNA Middle (N 49)	TEM		10	10	1308	1538	150	1500	
DE70302-14	field Blank	HA		NA	NA	0	0	0	0	
DE70302-15	" "	HA		NA	NA	0	0	0	0	
DE70302-16	Scaled Blank	HA		NA	NA	0	0	0	0	

COMMENTS:

8391

SAMPLE BY: Dipo ELEMO	DATE: 7/3/02
SIGNATURE: <i>[Signature]</i>	
RELEASED BY: <i>[Signature]</i>	DATE: 7.3.02
SIGNATURE: <i>[Signature]</i>	
RECEIVED BY: <i>[Signature]</i>	DATE: 7/3/02
SIGNATURE: <i>[Signature]</i>	6:00pm

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Wednesday, July 03, 2002

Time: 11:33:28 PM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8391

Client Project: NYC-DEP W & P File # 1079.01.02
49 / 51 Nassau Street

Number of Pages: 3
(including cover page)