

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/13/02

8:30:00 PM

ATC Group #: 8484

Analysis Date: 7/14/88

Project: NYC DEP, W&P# 1079.01.02

53 /51 Murray

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (f/cc)	Asbestos Concentration (f/mm ³)	(f/cc)	Notes
01 8484 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
02 8484 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
03 8484 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
04 8484 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044
05 8484 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0017
Fax (212) 922-0030

8484

WARREN & PANZER ENGINEERS, P. C.

PAGE 1 OF 1

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

W&P FILE #: 1079-dt-d2

CLIENT: NYC DEP

CONTACT:

PROJECT: 53/51 MURRAY

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II

LOCATION: TA

TECHNICIAN: R. TERADA, DCI

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (µg./cc.)
d1	① SIDE BUILD	3		10.0 10.0	0702	0912	130	1300	
d2	NO CRACKS SIGN (SIDEWALK)	3		10.0 10.0	0703	0913			
d3	MIDDLE (SIDEWALK)	3		10.0 10.0	0704	0914			
d4	② SIDE BUILD BRCADE	3		10.0 10.0	0705	0915			
d5	SIDEWALK ②	3		10.0 10.0	0707	0917	130	1300	
d6	FB	1							
d7	FB	1							

COMMENTS:

SAMPLE BY: R. TERADA, DCI
DATE: 7-13-02

SIGNATURE: 

RELEASED BY: 

SIGNATURE: 

RECEIVED BY: NYC
DATE: 07/13/02

SIGNATURE: H. Gier
DATE: 1/9/15

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8484

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02

Date: Thursday, July 14, 1988

53 /51 Murray

Time: 9:00:43 AM

Comments:

Number of Pages:

3
(including cover page)