

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

110 Liberty Street, New York, NY

Received: 7/22/02

8:00:00 AM


ATC Group #: 8571

Analysis Date: 7/22/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µm	5µ		(S/mm ³)	(S/cc)	
DE01 8571 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE02 8571 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE03 8571 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE04 8571 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE05 8571 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependant on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEVSAKHOV

ATC Group #: 8571

Fax #: (212) 922-0630

Client Project: NYC DEP. W&P# 1079.01.02
110 Liberty Street, New York, NY

Date: Monday, July 22, 2002

Time: 3:08:13 PM

Comments:

Number of Pages: 3
(including cover page)