

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 6/23/02

6:00:00 PM

ATC Group #: 8246

Analysis Date: 6/23/02

Project: NYC-DEP W & P File #: 1079.01.02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mn ²)	(S/cc)	
97 8246'-1	1261.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
98 8246'-2	1261.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
99 8246'-3	1261.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
100 8246'-4	1261.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	
101 8246'-5	1261.00	0.0674	0	None Detected	0	0	0.0045	<14.83	<0.0045	

MARK PEYSAKHOV

Analyzed by:

A handwritten signature in black ink, appearing to read 'Mark Peysakhov'.

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mn². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0877
Fax (212) 922-0830

WARREN & PANZER ENGINEERS, P.C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE OF
P.O.

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1079.01.02

CLIENT: LEP

CONTACT:

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM
circle one AHERA EPA LEVEL II

TECHNICIAN: LEV FAINSTEIN

PROJECT: 114 Liberty
LOCATION: Bay

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
097	10A Inside ramp	3		9.7	11-30 13-40	130	1261	
098	" "	3		"	11-31 13-41	"	"	
099	Over Ocean Units (CLM)	3		"	11-32 13-42	"	"	
100	" Staircase	3		"	11-34 13-44	"	"	
101	" Elevator Lobby	3		"	11-36 13-46	"	"	
102		1						
103		1						
104		1						

COMMENTS:

SAMPLE BY: <u>L Fainstein</u>	DATE: <u>6/23/02</u>
SIGNATURE: <u>[Signature]</u>	
RELEASED BY: <u>Fainstein</u>	DATE: <u>6/23/02</u>
SIGNATURE: <u>[Signature]</u>	
RECEIVED BY: <u>[Signature]</u>	DATE: <u>6/23</u>
SIGNATURE: <u>[Signature]</u>	DATE: <u>6/23/02</u>

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Sunday, June 23, 2002

Time: 10:47:08 PM

Comments:

From: MARK PEYSAKHOV

ATC Group #: 8246

Client Project: NYC-DEP W & P File #: 1079.01.02

Number of Pages: 3
(including cover page)