

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

114 Liberty

Received: 6/22/02

6:30:00 PM

ATC Group #: 8230

Analysis Date: 6/23/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
089 8230 -1	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
090 8230 -2	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
091 8230 -3	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	
092 8230 -4	1410.00	0.0562	0	CHRYSTILE	1	0	0.0049	17.79	0.0049	
093 8230 -5	1410.00	0.0562	0	None Detected	0	0	0.0049	<17.79	<0.0049	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #13879



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Sunday, June 23, 2002

Time: 9:53:35 AM

Comments:

From: ROMAN PEYSAKHOV

ATC Group #: 8230

Client Project: NYC-DEP W & P File #: 1079.01.02
114 Liberty

Number of Pages: 3
(including cover page)