

09/18/2002 06:30 FAX 7187844085

008

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7330
Fax. (718) 784-4085**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

CLIENT: Wachen & Puzer Engineers, P.C.

LABORATORY ID #: T02-09-058

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013771

PROJECT: NYC DEP, 9-11 Maiden Lane

DATE OF REPORT: 09/17/02

DATE OF ANALYSIS: 09/17/02

EFFECTIVE FILTER AREA (mm²): 185

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft ³)	G.O. % ANAL. VZEB	AREA ANALYT. (mm ²)	ANALYT. SENSITIV. (micrograms)	TOTAL ASBESTOS AIR CONC. (micrograms)	TOTAL ASBESTOS FILTER CONC. (micrograms)	AIR CONC. FOR STRUCT. 0.5-5.0um	AIR CONC. FOR STRUCT. 5.5-9um	ASBEST. TYPE CHRYE.	ANALYT. SPECIFY
01	T02-09-058-2355	In remote decou	1680	4	0.0551	0.0042	<0.0042	<18.15	NA	NA	NA	NA
02	T02-09-058-2356	At roof entrance	1680	3	0.0413	0.0042	0.0042	199.65	0.0252	0.0210	Chrys.	NA
03	T02-09-058-2357	East side roof	1680	4	0.0551	0.0042	0.0210	90.75	0.0084	0.0126	Chrys.	NA
04	T02-09-058-2358	West side roof	1680	4	0.0551	0.0042	0.0210	90.75	0.0126	0.0084	Chrys.	Auth.
05	T02-09-058-2359	Middle of roof	1680	4	0.0551	0.0042	<0.0042	<18.15	NA	NA	NA	NA

E. SioukhiANALYST
E. Sioukhi

LABORATORY DIRECTOR
Spiro Donganis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, EIALP 10935

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling capsules will be stored for sixty (60) days. AES Inc. should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

SEE REVERSE SIDE FOR ANALYSIS INFORMATION