

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

10 Maiden Lane

Received: 7/20/02

9:30:00 PM

ATC Group #: 8559

Analysis Date: 7/21/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
01 8559 -1	1620.00	0.0562	0	None Detected	0	0	0.0042 <17.79 <0.0042	
02 8559 -2	1620.00	0.0562	0	None Detected	0	0	0.0042 <17.79 <0.0042	
03 8559 -3	1620.00	0.0562	0	None Detected	0	0	0.0042 <17.79 <0.0042	
04 8559 -4	1620.00	0.0562	0	None Detected	0	0	0.0042 <17.79 <0.0042	
05 8559 -5	1620.00	0.0562	0	None Detected	0	0	0.0042 <17.79 <0.0042	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/loc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/min. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0636

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O.

PAGE ____ OF ____

CLIENT: NYC DED

PROJECT: ROOF

LOCATION: 10 MATTHEW LANE

W&P FILE #: 1079-01-02

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM TEM

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: F. O'Sullivan

CONTACT:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (fib./cc.)
01	Blank	1								
02	"	1								
03	EAST SIDE OF ROOF	3		3	3	1100	2000	540	1620	
04	WEST " " "	3		3	3	1102	2002	540	1620	
05	SOUTH " " "	3		3	3	1104	2004	540	1620	
06	NORTH " " "	3		3	3	1106	2006	540	1620	
07	CENTER " " "	3		3	3	1108	2008	540	1620	
08	BLANK	1								

COMMENTS:

SAMPLE BY: F. O'Sullivan DATED 07-10-02

SIGNATURE: [Signature]

RELEASED BY: F. O'Sullivan DATE: 07-10-02

SIGNATURE: [Signature]

RECEIVED BY: ATC DATE: 07/10/02

SIGNATURE: [Signature]

DATE: 11:30

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8559

Date: Sunday, July 21, 2002

Client Project: NYC DEP. W&P# 1079.01.02
10 Maiden Lane

Time: 10:33:02 AM

Number of Pages: 3

(including cover page)

Comments: