

10/10/2002 08:47 FAX

6/007/015

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (212) 784-7400

Fax. (718) 784-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-10-044

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP. 15 Maiden Lane

DATE OF REPORT: 10/08/02

DATE OF ANALYSIS: 10/08/02

EFFECTIVE FILTER AREA (mm²): 385**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY****LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (B)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (ct/area)	TOTAL ASBESTOS AIR CONC. (pfue./cm ³)	TOTAL ASBESTOS FILTER CONC. (pf./mm ²)	AIR CONC. FOR STRUCT. 0.553-5.5pm	AIR CONC. FOR STRUCT. >5.50pm	ASBEST. TYPE CHRYSL.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-044-2898	IWA right side of WA (east)	1740	4	0.0554	0.0040	<0.0040	<18.07	NA	NA	NA	NA
02	T02-10-044-2899	IWA middle side of WA (east)	1740	4	0.0554	0.0040	<0.0040	<18.07	NA	NA	NA	NA
03	T02-10-044-2900	IWA left side of WA (east)	1740	4	0.0554	0.0040	<0.0040	<18.07	NA	NA	NA	NA
04	T02-10-044-2901	IWA right side of WA (west)	1740	4	0.0554	0.0040	<0.0040	<18.07	NA	NA	NA	NA
05	T02-10-044-2902	IWA left side of WA (west)	1740	4	0.0554	0.0040	<0.0040	<18.07	NA	NA	NA	NA

ANALYST
E. Dimitrakos

LABORATORY DIRECTOR
Spiro Dosgaris
LABORATORY CERTIFICATION NUMBERS: NYLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- All sampling activities will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- This report relates only to items tested. This report must not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

