

10/15/2002 17:34 FAX

007

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7498  
Fax. (718) 784-4885**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

CLIENT: Warren & Parter Engineers, P.C.  
LABORATORY ID #: T02-10-088  
ANALYT. METHODOLOGY: AHERA  
FILTER TYPE: M.C.E.  
AVERAGE G.O. AREA (mm<sup>2</sup>): 0.013838

PROJECT: NYC DEP, 15 Maiden Lane  
DATE OF REPORT: 10/14/02  
DATE OF ANALYSIS: 10/14/02  
EFFECTIVE FILTER AREA (mm<sup>2</sup>): 385

**LABORATORY RESULTS**

| CLIENT # | LAB. ID #       | LOCATION         | VOLUME (m <sup>3</sup> ) | G.O. % ANALYZED | AREA ANALYZED (mm <sup>2</sup> ) | ANALYT. SENSITV. (fibre/cm <sup>3</sup> ) | TOTAL ASBESTOS AIR CONC. (fibre/cm <sup>3</sup> ) | TOTAL ASBESTOS FILTER CONC. (fibre/cm <sup>3</sup> ) | AIR CONC. FOR STRICT. 0.35µm | AIR CONC. FOR STRICT. 0.5µm | ASBEST. TYPE CHRYA. | ASBEST. TYPE SPECIFY |
|----------|-----------------|------------------|--------------------------|-----------------|----------------------------------|-------------------------------------------|---------------------------------------------------|------------------------------------------------------|------------------------------|-----------------------------|---------------------|----------------------|
| 01       | T02-10-088-3126 | East facade 1    | 1800                     | 4               | 0.0554                           | <0.0039                                   | <0.0039                                           | <18.07                                               | NA                           | NA                          | NA                  | NA                   |
| 02       | T02-10-088-3127 | East facade 2    | 1800                     | 4               | 0.0554                           | <0.0039                                   | <0.0039                                           | <18.07                                               | NA                           | NA                          | NA                  | NA                   |
| 03       | T02-10-088-3128 | East facade 3    | 1800                     | 4               | 0.0554                           | <0.0039                                   | <0.0039                                           | <18.07                                               | NA                           | NA                          | NA                  | NA                   |
| 04       | T02-10-088-3129 | Below roof       | 1800                     | 4               | 0.0554                           | <0.0039                                   | <0.0039                                           | <18.07                                               | NA                           | NA                          | NA                  | NA                   |
| 05       | T02-10-088-3130 | Entrance to roof | 1800                     | 4               | 0.0554                           | <0.0039                                   | 0.0039                                            | 18.07                                                | <0.0039                      | 0.0039                      | Chrys.              | NA                   |

ANALYST

E. Dimitrakas

LABORATORY DIRECTOR

Spirio Dominguez

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling sessions will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to tests listed. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

10/15/2002 17:34 FAX

006

228 East 48th Street  
New York, NY 10017  
(212) 922-0827  
Fax (212) 922-0830

# WARREN & PANZER ENGINEERS, P.C.

## AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr<sup>+</sup>/a 12 hr<sup>+</sup>/a 6 hr<sup>+</sup>/a 3 hr<sup>+</sup>/a Immediate <sup>+</sup>/a

PAGE \_\_\_\_\_ OF \_\_\_\_\_

P.O. \_\_\_\_\_

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

PROJECT: FACADE

LABORATORY: ATP/ENICIA

CONTACT: \_\_\_\_\_

LOCATION: 15 MURDEN LANE

ANALYSIS METHOD: PCM PER TEM  
circle one 7400 AMEREA EPA LEVEL II

TECHNICIAN: FERRY OCEANUS

| SAMPLE NUMBER | SAMPLE DESCRIPTION/LOCATION | SAMPLE TYPE | PUMP # | FLOWRATE START STOP | ON   | TIME OFF | TOTAL TIME | VOLUME (liters) | CONCENTRA (mb/cc) |
|---------------|-----------------------------|-------------|--------|---------------------|------|----------|------------|-----------------|-------------------|
| 01            | East FACADE 1               | 3           | 5      | 5                   | 0800 | 1400     | 360        | 1800            |                   |
| 02            | " " 2                       | 3           | 5      | 5                   | 0802 | 1402     | 360        | 1800            |                   |
| 03            | " " 3                       | 3           | 5      | 5                   | 0804 | 1404     | 360        | 1800            |                   |
| 04            | Below roof                  | 3           | 5      | 5                   | 0806 | 1406     | 360        | 1800            |                   |
| 05            | Entrance to roof            | 3           | 5      | 5                   | 0808 | 1408     | 360        | 1800            |                   |
| 06            | Blank                       |             |        |                     |      |          |            |                 |                   |
| 07            | " "                         |             |        |                     |      |          |            |                 |                   |
| 08            | " "                         |             |        |                     |      |          |            |                 |                   |

COMMENTS:

TOTAL 010.088

SAMPLE BY: FERRY OCEANUS DATE: 10-13-02

SIGNATURE: [Signature]

RELEASED BY: FERRY OCEANUS DATE: 10-15-02

SIGNATURE: [Signature]

RECEIVED BY: [Signature] DATE: 10/15/02

SIGNATURE: [Signature]

| SAMPLE TYPE CODES            |                               |
|------------------------------|-------------------------------|
| 1 - Blank                    | 5 - Final Clearance (inside)  |
| 2 - Pre-Abatement            | 6 - Final Clearance (outside) |
| 3 - During Abatement         | 7 - Personal                  |
| 4 - During Glove Bag Removal | 8 - Background                |