

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

22 Maiden Lane

Received: 7/20/02

6:00:00 PM

ATC Group #: 8556

Analysis Date: 6/21/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
1 8556 -1	1709.00	0.0562	0	None Detected	0	0.0040	<17.79	<0.0040
2 8556 -2	1709.00	0.0562	0	CHRYSTOLE	0	0.0040	17.79	0.0040
3 8556 -3	1709.00	0.0562	0	None Detected	0	0.0040	<17.79	<0.0040
4 8556 -4	1709.00	0.0562	0	None Detected	0	0.0040	<17.79	<0.0040
5 8556 -5	1709.00	0.0562	0	None Detected	0	0.0040	<17.79	<0.0040

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

29

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0539

WARREN & PANZER ENGINEERS, P. C.

8556

PAGE ____ OF ____

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NYC DEP

W&P FILE #: 1079-01.02

PROJECT: Roof/Facade power wash

LABORATORY: ATC

LOCATION: 22 Kaidan Lane

ANALYSIS METHOD: PCM ITEM

CONTACT: Hike Naleen

TECHNICIAN: Greg Boren

circle one 7400 TEM
ASTM EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
1	Street level corner of Kaidan and Nassau	3		5.1	10:40	16:15	335	1709	
2	Street level east of work area	3		5.1	10:41	16:16	335	1709	
3	Street level by 24 Kaidan Ln	3		5.1	10:42	16:17	335	1709	
4	Street level by 22 Kaidan Ln	3		5.1	10:43	16:18	335	1709	
5	Street level West of work area	3		5.1	10:44	16:19	335	1709	
6	Field Blank	1							
7	" "	1							
8	" "	1							

COMMENTS:

SAMPLE BY: <u>Greg Boren</u>	DATE: <u>7/20/02</u>
SIGNATURE: _____	
RELEASED BY: <u>Greg Boren</u>	DATE: <u>7/20/02</u>
SIGNATURE: <u>Boren</u>	Time: <u>18:00</u>
RECEIVED BY: <u>ATC</u>	DATE: <u>07/20/02</u>
SIGNATURE: <u>H. Gher</u>	Time: <u>18:00</u>

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8556

Date: Monday, July 22, 2002

Client Project: NYC DEP. W&P# 1079.01.02
22 Maiden Lane

Time: 9:30:39 AM

Comments:

Number of Pages: 2
(including cover page)

28