

Asbestos Inspection Report

Premise No. 83 MAIDEN LANE					Inspection Date: AS NOTED	
Floor ROOF	Zip 10038	Borough 1	Block 68	Lot T	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type COMMERCIAL		Basis of Inspection WTC Survey		Photos Taken Yes ☒ No ☐
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from:		
WEDNESDAY SEPTEMBER 4 2002						
CONTRACTOR BRINGS MATERIALS TO THE WORK SITE.						
THURSDAY SEPTEMBER 5 2002						
THE CLEAN UP PROJECT ON THE ROOF OF THE PREMISE BEGINS. A REMOTE DECONTAMINATION UNIT IS CONSTRUCTED IN THE HALLWAY AREA LEADING TO THE ROOF. AIR SAMPLING IS PERFORMED BY JERSON GARCIA (CERTIFICATE # AH 01-11633 EXP 03/03) OF WARREN & PANZER.						
FRIDAY SEPTEMBER 6 2002						
THE CLEAN UP ON THE ROOF IS COMPLETED. AIR SAMPLING FOR THIS PORTION OF THE CLEAN-UP IS PERFORMED BY FESY OSEMWEGIE (CERTIFICATE # AH 01-01030 EXP 01/03). CLEAN UP OF THE 11TH FLOOR SET-BACK AND THE CLEAN UP OF TWO WINDOW LEDGES ON THE 5TH FLOOR (FACING GOLD STREET) WILL BE DONE TOMORROW. MINOR RE-CLEANING ON THE ROOF WILL ALSO BE COMPLETED ON SATURDAY.						
SATURDAY SEPTEMBER 7 2002						
THE CLEAN UP OF THE 11TH FLOOR SET-BACK IS COMPLETED. WORKERS DOUBLE-SUIT AND USE STEP OFF PADS IN LIGN OF A REMOTE DECON. THE 5TH FLOOR WINDOW LEDGES ARE CLEANED FROM INSIDE THE BUILDING. THE 11TH FLOOR AND THE 5TH FLOOR ARE CURRENTLY UNOCCUPIED AREAS. I CONDUCT A VISUAL INSPECTION OF THESE TWO WORK AREAS AND OBSERVE NO VISIBLE WTC DEBRIS AT THE CONCLUSION OF THE CLEANING ACTIVITIES. THE CLEAN UP PROJECT AT THE PREMISE IS NOW COMPLETE.						

pl