

Asbestos Inspection Report

Premise No. 90 MAIDEN LANE					Inspection Date: 07-07-02	
Floor FACADE	Zip	Borough 1	Block 42	Lot 36	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type COMMERCIAL		Basis of Inspection WTC Survey		Photos Taken ☒ Yes ☐ No
Contractor's Name TRIO ASBESTOS REMOVAL CORP				Sample Number N/A		
Address City 14-20 129TH STREET, COLLEGE POINT				Sample Number N/A		
State Zip NY 11356		Phone (718) 961-4100		Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York		Address City				
State Zip NY 10017		Phone (212) 922-0077		State Zip Phone		
Contact Person				Time of Inspection from: 8 ⁰⁰ AM - 6 ⁰⁰ PM		
SUNDAY JULY 7, 2002						
8:00AM CLEAN UP ACTIVITIES BEGIN ON THE THREE STORIES LOCATED ABOVE THE SIDEWALK BRIDGE. WORKERS BEGIN CONSTRUCTION OF A PLASTIC DYKE TO COLLECT ANY RUN-OFF WATER. A MOBILE DECON TRUCK WILL BE USED.						
9:45 AM VACUUMING ACTIVITIES BEGIN. DIPO ELEMO (CERTIFICATE # AH 01-14674 EXP 03/03) OF WARREN & PANZER BEGINS AIR SAMPLING. FIVE AIR SAMPLES (1 @ DECON AND 4 ON THE STREET) ARE RUN						
12:30 PM WORKERS HAVE NOT FINISHED THE FACADE CLEAN UP AS ORIGINALLY PLANNED. AT THIS TIME ONLY TWO OF THE THREE LEVELS ABOVE THE SIDEWALK BRIDGE HAVE BEEN COMPLETED. THE FIVE ORIGINAL AIR SAMPLES ARE PULLED. FIVE ADDITIONAL SAMPLES WILL BE RUN FOR THE REMAINDER OF THE CLEAN-UP. THE LOCATION OF THE SECOND SET OF AIR SAMPLES WILL BE IDENTICAL TO THE FIRST SET OF SAMPLES.						
1:55AM BACK-UP GENERATOR WAS TAKEN OFF CONTRACTOR'S TRUCK AND PUT INTO SERVICE AFTER THE PRIMARY GENERATOR BEGAN MALFUNCTIONING (ASBESTOS HANDLER SUPERVISOR SPASA SIMIC PERFORMED THIS FUNCTION).						
2:30PM DIPO ELEMO CONDUCTS A VISUAL INSPECTION OF THE CLEANED FACADE SURFACES LOCATED ABOVE THE SIDEWALK BRIDGE AND OBSERVES NO VISIBLE WTC DEBRIS. WORKERS BEGIN REMOVING WASTE BAGS GENERATED BY THIS PORTION OF THE CLEAN-UP.						
3:00PM BAG-OUT ACTIVITIES ARE COMPLETED. WORKERS BREAK FOR LUNCH.						

elp.

Asbestos Inspection Report

Premise No. 90 MAIDEN LANE	Inspection Date: 07-07-02
Inspector Dennis Antzoulatos	Page <u>2</u> of <u>2</u>
SUNDAY JULY 7, 2002 (CONTINUED) 3:30PM WORKERS CONSTRUCT PLASTIC DYKE FOR THE COLLECTION OF ANY RUN-OFF WATER FROM THE FACADE CLEANUP BELOW THE SIDEWALK BRIDGE. 5:30PM DIDD ELEMO OF WARDEN & PANZER CONDUCTS A VISUAL INSPECTION OF THE CLEANED FACADE SURFACES BELOW THE SIDEWALK BRIDGE AND OBSERVES NO VISIBLE WTC DEBRIS. 6:00PM WORKERS HAVE DISMANTLED THE DYKE, REMOVED ALL WASTE BAGS AND LEAVE THE WORKSITE. THE CLEAN UP PROJECT AT THIS PREMISE IS NOW COMPLETE.	