

WWW.PRESERVINC.COM

PRESERV

GLEN A. ZANE

96 14TH ST.
BROOKLYN, NY 11215
718-768-3600
718-768-3601 FAX

551 VALLEY RD., PMB 160
MONTCLAIR, N.J. 07043
973-509-7747
973-744-1629 FAX

WTC-LBC

Scope of Work Items

Item (11) Page 2: Add the following sentence to the end of the item:

After installation of the isolation barriers, floors shall be covered with a layer of 6-mil polyethylene sheeting.

Item (13) Page 2: Add phrases to sentences two and three so that they read:

Interior and perimeter walls shall be removed, as well as insulation behind those walls, to access the interstitial spaces for cleaning. Only one side of each wall shall be removed, from floor to ceiling, to access the space.

Item (19) Page 4: Add the following sentences to the end of the item:

The polyethylene sheeting covering the floors shall be cleaned and folded inward onto itself. All floor surfaces shall then be fine cleaned using HEPA vacuuming and wet-wiping procedures.

WTC-LBA

Sampling and Analytical Procedures for Lead, PAHs, Dioxin, Fibrous Glass, and Silica

(22)

Item 2, Page ³2: Add the clarification for sampling the duplex apartment at both prior to and after cleaning activities.

- ✓ Prior to the cleaning activities, three wipe samples shall be collected for each of these parameters in each apartment, except the duplex apartment where three wipe samples shall be collected on each floor of the apartment.

After cleaning activities, three wipe samples shall be collected for each of these parameters in each apartment, except the duplex apartment where three wipe samples shall be collected on each floor of the apartment.