

3/27/02

CONTACTED AMBIENT
SPOKE TO LIZ REQUESTED
ANALYTICAL REPORTS -
FURTHER - AMBIENT
RECOMMENDATION FOR
ROOF DEBRIS WAS
INAPPROPRIATE - DEBRIS
WAS ACM. ONLY RESPONDED
WITH OKAY - LEFT NAME
& # FOR FILE WITH MR.
LEITNER

Indoor environmental quality surveys
Water treatment consulting
Asbestos & lead field services
Regulatory compliance programs
Air, water & soil analytical laboratories

55 WEST 39TH STREET
12TH FLOOR
NEW YORK, NEW YORK 10018
TEL: (212) 944-4615
FAX: (212) 944-4618
WEB: WWW.AMBIENTGROUP.COM

R. Radhakrishnan, P.E.
Director, Asbestos Control Program
New York City Department of Environmental Protection
59-17 Junction Boulevard
Corona, NY 11368

Gentlemen:

Settled dust samples were collected from various locations on floors 6, 11, 20, 26, and 29 and analyzed for the absence/presence of asbestos. No asbestos was detected in any of the samples. Bulk samples were also collected of debris from the roof of the building, the air filter on the 29th floor HVAC unit, and from the central staircase on the 17th floor, and analyzed for the absence/presence of asbestos. Trace (<1%) amounts of asbestos were detected in the sample from the 17th floor, and no asbestos was detected in the fan unit filter material. Analysis of the debris on the roof revealed that greater than 1% of asbestos was present. Based upon our recommendations, the building subsequently washed down the affected areas thereby eliminating the debris from those locations.

Air samples were collected from various locations on floors 1, 6, 11, 17 and 28 and analyzed for dust characterization. The samples were composed primarily of gravel road dust, carbon particles, cement dust, fungal spores and skin fragments. In addition, no asbestos was detected in any of the air samples.

Finally, Ambient Group, Inc. continues to perform air quality testing at this building, on a monthly basis and all results have thus far been found to be within any applicable guidelines. If you have any questions regarding this information, do not hesitate to contact our office.

Sincerely,
Signed for Ambient Group, Inc. by:


John J. Leitner
Vice President

GLEN COVE, NY
516 609-0009

MIAMI, FL
305 860-0101

CHICAGO, IL
312 527-5526


ORANGE, CA
714 282-2525




55 WEST 39TH STREET
12TH FLOOR
NEW YORK, NEW YORK 10018

ambient group inc.

A National Environmental & Water Treatment Consulting Company




R. Radhakrishnan, P.E.
Director, Asbestos Control Program
New York City Department of Environmental
Protection
59-17 Junction Boulevard
Corona, NY 11368