

Can be filed.

Can be filed.

Fax Cover Sheet

**MTA Bridges & Tunnels
Randall's Island
P. O. Box 35
New York, New York 10035-0035
(212) 360-4160
Fax No. (212) 360-4170**

To: Carl Lutchmedial From: Steven Kozak
Date: 11/6/02 Fax No.: 718-595-3749
Total number of pages including cover page: 6

Message: Air monitoring data you requested. I had
the consultant put the data in a summary table.
Call me if you have questions.
Steve Kozak

If you have any problems receiving this transmission, please call, the above telephone number.

This message is intended only for the use of the individual or entity to which it is addressed and may contain information that is privileged, confidential and exempt from disclosure.

If the reader of this message is not the intended recipient or an employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone so we can arrange for the return of the original message to us.

Thank You.

File
9 Battery Place
at

LOCATION	SAMPLE ID	DATE	FIBERS CONC. (Fibers/cc)
Vent Building Manhattan 2nd Floor Fan Room	BA-001	8/18/2002	<0.002
Vent Building Manhattan 2nd Floor Fan Room	BA-002	8/18/2002	<0.002
Vent Building Manhattan 2nd Floor Fan Room	BA-003	8/18/2002	<0.002
Vent Building Manhattan 2nd Floor Fan Room	BA-004	8/18/2002	<0.002
Vent Building Manhattan 2nd Floor Fan Room	BA-005	8/18/2002	<0.002
Vent Building Manhattan 2nd Floor Fan Room	BA-006	8/18/2002	N/A
Vent Building Manhattan 2nd Floor Fan Room	BA-007	8/18/2002	N/A
Manhattan Vent Building- Post Abatement	GS51	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS52	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS53	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS54	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS55	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS56	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS57	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS58	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS59	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS60	8/25/2002	<0.001
Manhattan Vent Building- Post Abatement	GS61	8/25/2002	N/A
Manhattan Vent Building- Post Abatement	GS62	8/25/2002	N/A
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-01	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-02	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-03	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-04	8/30/2002	<0.001

LOCATION	SAMPLE ID	DATE	FIBERS CONC. (Fibers/cc)
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-05	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-06	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-07	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-08	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-09	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	PF-10	8/30/2002	<0.001
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	FB-11	8/30/2002	N/A
Manhattan Vent Building- Blower Fans #51 & 44 Post Abatement	FB-12	8/30/2002	N/A
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-01-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-02-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-03-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-04-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-05-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-06-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-07-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-08-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-09-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #53 - Post Abatement	PF-10-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #53 - Post Abatement	FB-11-P	9/4/2002	N/A
Manhattan Vent Building- Blower Fans #53 - Post Abatement	FB-12-P	9/4/2002	N/A
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-01-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-02-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-03-P	9/4/2002	0.002

LOCATION	SAMPLE ID	DATE	FIBERS CONC. (Fibers/cc)
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-04-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-05-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-06-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-07-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-08-P	9/4/2002	<0.001
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-09-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #42 - Post Abatement	PF-10-P	9/4/2002	0.002
Manhattan Vent Building- Blower Fans #42 - Post Abatement	FB-11-P	9/4/2002	N/A
Manhattan Vent Building- Blower Fans #42 - Post Abatement	FB-12-P	9/4/2002	N/A
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-01-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-02-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-03-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-04-P	9/5/2002	0.002
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-05-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-06-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-07-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-08-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-09-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	PF-10-P	9/5/2002	<0.001
Manhattan Vent Building- Blower Fans #43 - Post Abatement	FB-11-P	9/5/2002	N/A
Manhattan Vent Building- Blower Fans #43 - Post Abatement	FB-12-P	9/5/2002	N/A
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-01-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-02-P	9/6/2002	<0.001

LOCATION	SAMPLE ID	DATE	FIBERS CONC. (Fibers/cc)
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-03-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-04-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-05-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-06-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-07-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-08-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-09-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	PF-10-P	9/6/2002	<0.001
Manhattan Vent Building- Blower Fans #41 - Post Abatement	FB-11-P	9/6/2002	N/A
Manhattan Vent Building- Blower Fans #41 - Post Abatement	FB-12-P	9/6/2002	N/A
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-001	9/9/2002	N/A
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-002	9/9/2002	N/A
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-003	9/9/2002	<0.001
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-004	9/9/2002	0.002
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-005	9/9/2002	<0.001
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-006	9/9/2002	<0.001
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-007	9/9/2002	0.002
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-008	9/9/2002	<0.001
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-009	9/9/2002	<0.001

LOCATION	SAMPLE ID	DATE	FIBERS CONC. (Fibers/cc)
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-010	9/9/2002	<0.001
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-011	9/9/2002	<0.001
Manhattan Vent Building- Post Abatement (AMENDED REPORT 9/10/02 CYF)	ZD-012	9/9/2002	<0.001