NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.

# Stuyvesant High School
# 345 Chambers Street
# New York, NY

## 3RD THROUGH 10TH FLOORS

**Final Air Test Results (Asbestos and Lead)**
**Post General Cleaning Lead Wipe Sample Results**
**Unit Ventilator Lead Wipe Sample Results**
**HVAC Duct Lead Wipe Sample Results**
**Lead Personal (OSHA Air Monitoring Results)**
**Lead Area Air Monitoring Sample Results**

**Project #: M477-15217**
**LLW#: 29881**

***BOOK 2 OF 2***

130A JERICHO TPKE., FLORAL PARK, NY 11001 ▪ PHONE (516) 358-2955 ▪ FAX (516) 358-1780

NYC-WTC_000106890

NYC 9/11 Public Portal Document

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.

# HVAC DUCT LEAD WIPE SAMPLE RESULTS 3RD THROUGH 10TH FLOORS

**PROJECT #: M477-15217**
**LLW#: 29881**

130A JERICHO TPKE., FLORAL PARK, NY 11001 • PHONE (516) 358-2955 • FAX (516) 358-1780

NYC-WTC_000106892

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

20613 3 of 3

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: SCA Stuyvesant
CONTACT: Hanif Sayed
SAMPLER (SIGNATURE): DATE: 7/24/02 TIME: 16
SAMPLER NAME (PRINT): Ettarle
SAMPLE(S) SEALED: YES / NO
CORRECT CONTAINER(S): YES / NO
PROJECT LOCATION: 345 Chambers St
PROJECT #: m477-15217-29881
MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT |
|---|---|---|---|---|---|---|---|---|
| | 10-01 | 10th Fl. O/S rm 1010 HVAC 1 west supply | 1 | | X | | | < 9.0 |
| | 10-02 | 10th Fl O/S rm 1010 HVAC 1 East Supply | 1 | | X | | | 37.4 |
| | 10-03 | 10th Fl o/s rm 1007 HVAC 1 east Supply | 1 | | X | | | < 9.0 |
| | 10-04 | 10th Fl O/S rm 1010 HVAC 1 return Plenum | 2 | | | | X | < 4.5 |
| | 10-05 | 10th Fl O/S rm 1010 HVAC 1 return Plenum | 2 | | | | X | 5.5 |
| | 10-06 | 10th Fl O/S rm 1017 HVAC return duct | 1 | | X | | | 34.7 |
| | FB-1 ~~10-04~~ | Field Blank | | | | | | < 9.0 |
| | FB-2 | Field Blank | | | | | | < 9.0 |

10th Fl. Rm. HVAC Supply/return

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /
COMMENTS / INSTRUCTIONS

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| | 7/24/02 5:20pm | S. FRANCIS | 07/24 6pm | | |
| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |
| | | | | | |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC-WTC_000106893

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-25-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 07-24-02 |
| **DATE RECEIVED:** | 07-24-02 |
| **DATE ANALYZED:** | 07-24-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| 10-01 | 20613 | 10 Floor O/S Rm 1010 HVAC 1 West Supply | <9.0 | 9.0 |
| 10-02 | 20613 | 10 Floor O/ S Rm 1010 HVAC 1 East Supply | 37.4 | 9.0 |
| 10-03 | 20613 | 10 Floor O/S Rm 1007 HVAC 1 East Supply | <9.0 | 9.0 |
| 10-04 | 20613 | 10 Floor O/S Rm 1010 HVAC 1Return Plenum | <4.5 | 4.5 |
| 10-05 | 20613 | 10 Floor O/S Rm 1010 HVAC 1Return Plenum | 5.5 | 4.5 |
| 10-06 | 20613 | 10 Floor O/S Rm 1018 HVAC Return Duct | 34.7 | 9.0 |
| FB-1 | 20613 | Field Blank | <9.0 µg | 9.0 µg |
| FB-2 | 20613 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

20676

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: SCA

CONTACT: Hamid Sanoj

SAMPLER (SIGNATURE): [signature] DATE: 7/26/02 TIME: 1430

SAMPLER NAME (PRINT): AL. Cacamo

SAMPLE(S) SEALED: YES / NO

CORRECT CONTAINER(S): YES / NO

PROJECT LOCATION: Stuyvesant H.S.

PROJECT #: M477-85217/29881

MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | DW-01 | 10th floor, Supply air duct by room # 1006 | 1 | | X | | | 21.3 |
| | DW-02 | 10th floor, Return air plenum by room # 1001 | 1 | | | | X | 29.0 |
| | DW-03 | 10th floor, Supply air duct by room # 1009 | 1 | | X | | | 19.8 |
| | DW-04 | 10th floor, Return air duct by room # 1017 | 1 | | X | | | 14.2 |
| | DW-05 | 10th floor Supply air duct by room # 1024 | 1 | | X | | | 10.0 |
| | DW-06 | 10th floor Return plenum by room # 1039 | 1 | | | | X | 26.5 |
| | DW-07 | F/B | 4 | | | | | |
| | DW-08 | F/B | 4 | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☒ BY / /

COMMENTS / INSTRUCTIONS: 6 Hr TAT

RELINQUISHED BY (SIGNATURE): [signature] DATE: 7/26/02 TIME: 2:30 pm PRINTED NAME: L. CACAMO

RELINQUISHED BY (SIGNATURE): DATE: TIME: PRINTED NAME:

RECEIVED BY (SIGNATURE): DATE: TIME: PRINTED NAME:

RECEIVED BY LAB (SIGNATURE): [signature] DATE: 7/26/2 TIME: 2:30 pm PRINTED NAME:

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-26-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 07-26-02 |
| **DATE RECEIVED:** | 07-26-02 |
| **DATE ANALYZED:** | 07-26-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| DW-01 | 20676 | 10th Floor Supply Air Duct by Rm 1006 | 21.3 | 9.0 |
| DW-02 | 20676 | 10th Floor Return Air Planum by Rm 1001 | <9.0 | 9.0 |
| DW-03 | 20676 | 10th Floor Supply Air Duct by Rm 1009 | 19.8 | 9.0 |
| DW-04 | 20676 | 10th Floor Return Air Duct by Rm 1017 | 14.2 | 9.0 |
| DW-05 | 20676 | 10th Floor Supply Air Dutc by Rm 1024 | 10.0 | 9.0 |
| DW-06 | 20676 | 10th Floor Return Planum by Rm 1039 | 26.5 | 9.0 |
| DW-07 | 20676 | Field Blank | <9.0 µg | 9.0 µg |
| DW-08 | 20676 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

20697

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

| CLIENT NAME/ADDRESS | CONTACT: | SAMPLER (SIGNATURE) | DATE | TIME | SAMPLE(S) SEALED |
|---|---|---|---|---|---|
| NYC SCA | Hamid Savoj | | 7/26/02 | 2120 | (YES) / NO |
| PROJECT LOCATION: Stuyvesant H.S. 345 Chambers | PROJECT # M477-15217-28881 | SAMPLER NAME (PRINT) | | | CORRECT CONTAINER(S) (YES) NO |

MATRIX (CIRCLE ONE): (WIPE) PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA ($FT^2$) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT |
|---|---|---|---|---|---|---|---|---|
| | DW-01A | 10th Floor - Supply Air Duct by Room 1006 | 1 | | ✓ | | | 15.7 |
| | FBL-1 | Field Blank | — | | | | | < 9.0 |
| | FBL-2 | Field Blank | — | | | | | < 9.0 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☒ BY 7/27/02

COMMENTS / INSTRUCTIONS: 6 HR TAT

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| | 7/26/02 2130 | Kirk McKenzie | | | |
| ISC | 7/26/02 | Igor Blank | | | |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC-WTC_000106897

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-29-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 07-26-02 |
| **DATE RECEIVED:** | 07-26-02 |
| **DATE ANALYZED:** | 07-26-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| DW-01A | 20697 | 10th Floor Supply Rm Duct by Rm 1006 | 15.7 | 9.0 |
| FBL-1 | 20697 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 20697 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC-WTC_000106898

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE.. FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

#20740

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: SCA Stuyvesant
CONTACT: Hamid Sarej
SAMPLER (SIGNATURE):
DATE: 7/29/02 TIME: 11a
SAMPLER NAME (PRINT): Petranek
SAMPLE(S) SEALED: YES / NO
CORRECT CONTAINER(S): YES / NO
PROJECT LOCATION: 345 Chambers
PROJECT #: M477-15217-29981
MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | LW01 | 9th fl. east Supply Duct Corridor o/s rm 911 | 1 | | X | | | <9.0 |
| | LW02 | 9th fl. west Supply Duct corridor o/s west Stair | | | X | | | <9.0 |
| | LW03 | 9th floor - return corridor o/s 911 & 912 | | | X | | | <9.0 |
| | LW04 | 9th fl. east supply Duct Corridor o/s rm 907 | | | X | | | <9.0 |
| | FB1 | Field Blank | | | | | | |
| | FB-2 | Field Blank | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

all wipes from Vertical Thruout

TURNAROUND REQUIRED: NORMAL ☐ STAT ☒ BY 6pm
COMMENTS / INSTRUCTIONS: Fax 212-406-2535 516 358 1786

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| | 7/29/02 12:30 | Petranek | | 7/29/02 13:40 | |
| | 7/29/02 1:30PM | Sylvester Fromals | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-29-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers Street, NY

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-29-02
**DATE RECEIVED:** 07-29-02
**DATE ANALYZED:** 07-29-02

**SAMPLE MEDIA:** Dust Wipe Sample
**ANALYSIS REQUIRED:** Method EPA 3050/7420

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 20740 | 9th Floor East Supply and Corr. O/S Rm 911 | <9.0 | 9.0 |
| LW-02 | 20740 | 9th Floor West Supply and Corr. O/S West Stair | <9.0 | 9.0 |
| LW-03 | 20740 | 9th Floor Return Corridor O/S 911&921 | <9.0 | 9.0 |
| LW-04 | 20740 | 9th Floor East Supply Dyct Corridor O/S in 907 | <9.0 | 9.0 |
| FBL-1 | 20740 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 20740 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$.
Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC-WTC_000106900

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

20770

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: Stanley

CONTACT: Howard Sav

SAMPLER (SIGNATURE): [signature] DATE: 7/30/02 TIME: 12:30

SAMPLER NAME (PRINT): Petrak

SAMPLE(S) SEALED: YES / NO

CORRECT CONTAINER(S): YES / NO

PROJECT LOCATION: 345 Chambers

PROJECT #: 1472-1507/2988

MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | LW-07 | 8TH FLOOR CORRIDOR EAST SUPPLY AIR #807 | 1.0 | | X | | | <9.0 |
| | LW-08 | 8TH FLOOR CORRIDOR RETURN AIR #C821 | 1.0 | | X | | | 26.7 |
| | LW-09 | 8TH FLOOR CORRIDOR SUPPLY (WEST) @ C832 | 1.0 | | X | | | 23.5 |
| | LW-10 | 8TH FLOOR CORRIDOR WEST SUPPLY @ 840 | 1.0 | | X | | | 145.7 |
| | LW-11 | F. BLANK - 1 | — | | | | | — |
| | LW-12 | F. BLANK - 2 | — | | | | | — |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS: GHEM AT

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| [signature] | 7/30 1:15 PM | Petrak | | | |
| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |
| | | | [signature] | 7/30 2:30 | |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-30-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers Street, NY

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-30-02
**DATE RECEIVED:** 07-30-02
**DATE ANALYZED:** 07-30-02

**SAMPLE MEDIA:** Dust Wipe Sample
**ANALYSIS REQUIRED:** Method EPA 3050/7420

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-07 | 20770 | 8th Floor Corridor East Supply Adj. 807 | <9.0 | 9.0 |
| LW-08 | 20770 | 8th Floor Corridor Return Adj. to C821 | 26.7 | 9.0 |
| LW-09 | 20770 | 8th Floor Corridor Supply (West) @ C832 | 23.5 | 9.0 |
| LW-10 | 20770 | 8th Floor Corridor West Supply @ 840 | 145.7 | 9.0 |
| LW-11 | 20770 | Field Blank | <9.0 µg | 9.0 µg |
| LW-12 | 20770 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1.
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC-WTC_000106902

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

20791

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: NYC SCA
CONTACT: HAMID SAWOJ
SAMPLER (SIGNATURE): [signature] DATE: 7/30/02 TIME:
SAMPLE(S) SEALED: (YES) / NO
SAMPLER NAME (PRINT): KIRK MC KENZIE
CORRECT CONTAINER(S): (YES) / NO
PROJECT LOCATION: STUYVESANT HS 345 CHAMBERS ST. NY
PROJECT #: M477-15217-29881
MATRIX (CIRCLE ONE): (WIPE) PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | LW-01 | 8th FLOOR CORRIDOR WEST SUPPLY @ 840 | 1 composit | | ✓ | | | 10.0 |
| | LW-02 | 8th FLOOR CORRIDOR (WEST) @ C832 - Supply | 1 composit | | ✓ | | | 85.3 |
| | LW-03 | 8th FLOOR CORRIDOR Adj. to C821 - Return | 1 composit | | ✓ | | | < 9.0 |
| | LW-04 | 8th FLOOR CORRIDOR SUPPLY Adj: 807 | 1 composit | | ✓ | | | 9.8 |
| | FBL-1 | FIELD BLANK | | | | | | < 9.0 |
| | FBL-2 | FIELD BLANK | | | | | | < 9.0 |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /
COMMENTS / INSTRUCTIONS: 6 HR TAT

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| [signature] | 7.30.02 0920 | KIRK MC KENZIE | R. Droudina | 7.31.02 01.30 | R. Droudina |
| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |

FAX TO: 212 406-9521 WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-31-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers Street, NY

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-30-02
**DATE RECEIVED:** 07-31-02
**DATE ANALYZED:** 07-31-02

**SAMPLE MEDIA:** Dust Wipe Sample
**ANALYSIS REQUIRED:** Method EPA 3050/7420

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 20791 | 8th Floor Corridor West Supply @ 840 | 10.0 | 9.0 |
| LW-02 | 20791 | 8th Floor Corridor (West) @ C832 Supply | 85.3 | 9.0 |
| LW-03 | 20791 | 8th Floor Corridor ajd. to C821 - Return | <9.0 | 9.0 |
| LW-04 | 20791 | 8th Floor Corridor Supply Adj. 807 | 9.8 | 9.0 |
| FBL-1 | 20791 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 20791 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples. Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

2077/

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

| | | | | |
|---|---|---|---|---|
| CLIENT NAME/ADDRESS SCA Stuyvesa | CONTACT: Ian Sas | SAMPLER (SIGNATURE) | DATE 7/30/02 TIME | SAMPLE(S) SEALED YES / NO |
| | | SAMPLER NAME (PRINT) Keegan | | CORRECT CONTAINER(S) YES / NO |
| PROJECT LOCATION: 345 Chambers | PROJECT # M477-15217 2998 | MATRIX (CIRCLE ONE) WIPE | PAINT SOIL OTHER _____ | |

| SAMPLE INFORMATION: | | | | SURFACE MATERIAL | | | | |
|---|---|---|---|---|---|---|---|---|
| LABORATORY # | SAMPLE # | LOCATION | AREA ($FT^2$) | WOOD | METAL | BRICK | OTHER | LAB RESULT µg/$FT^2$ |
| | LW-01 | 7TH FL CORRIDOR WEST SUPPLY O/S C728 | 1.0 | | X | | | 677.6 |
| | LW-02 | 7TH FL CORRIDOR RETURN. ADJ TO C721 | 1.0 | | X | | | 49.3 |
| | LW-03 | 7TH FL CORRIDOR EAST SUPPLY ADJ #715 | 1.0 | | X | | | 16.3 |
| | LW-04 | 7TH FL CORRIDOR EAST SUPPLY ADJ #705 | 1.0 | | X | | | <9.0 |
| | LW-05 | F. BLANK - 1 | — | | — | | | — |
| | LW-06 | F. BLANK - 2 | — | | — | | | — |
| | | | | | | | | |
| | | | | | | | | |

Fax results 212-406-0535
516 358 2955

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS GREAT

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED BY (SIGNATURE) | DATE 7/30/02 TIME 2:10P | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE TIME | PRINTED NAME |
| RELINQUISHED BY (SIGNATURE) | DATE TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE 7/30/02 TIME | PRINTED NAME |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-30-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers Street, NY

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-30-02
**DATE RECEIVED:** 07-30-02
**DATE ANALYZED:** 07-30-02

**SAMPLE MEDIA:** Dust Wipe Sample
**ANALYSIS REQUIRED:** Method EPA 3050/7420

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 20771 | 7th Floor Corridor West Supply O/S C728 | 677.6 | 9.0 |
| LW-02 | 20771 | 7th Floor Corridor Return Adj. to C721 | 49.3 | 9.0 |
| LW-03 | 20771 | 7th Floor Corridor East Supply Ajd. 715 | 16.3 | 9.0 |
| LW-04 | 20771 | 7th Floor Corridor East Supply Adj. 705 | <9.0 | 9.0 |
| LW-05 | 20771 | Field Blank | <9.0 µg | 9.0 µg |
| LW-06 | 20771 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

C0792

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

| | | | |
|---|---|---|---|
| CLIENT NAME/ADDRESS: NYC SCA | CONTACT: HAMID SAWOJ | SAMPLER (SIGNATURE) | DATE 7/30/02 TIME |
| PROJECT LOCATION: STUYVESANT HS 345 CHAMBERS ST. NY | PROJECT # M477-15217-29881 | SAMPLER NAME (PRINT): KIRK MC KENZIE | SAMPLE(S) SEALED (YES) / NO; CORRECT CONTAINER(S) (YES) / NO |
| | | MATRIX (CIRCLE ONE): (WIPE) PAINT SOIL OTHER _____ | |

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT, µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | LW-01 | 7th FLOOR CORRIDOR - WEST SUPPLY O/S C728 | 1 composit | | ✓ | | | <9.0 |
| | LW-02 | 7th FLOOR CORRIDOR - RETURN Adj. to C721 | 1 | | ✓ | | | <9.0 |
| | LW-03 | 7th FLOOR CORRIDOR - EAST SUPPLY Adj. 715 | 1 Composit | | ✓ | | | <9.0 |
| | LW-04 | 7th FLOOR CORRIDOR EAST SUPPLY Adj. 705 | 1 Compsit | | ✓ | | | 21.6 |
| | FBL-01 | FIELD BLANK. | | | | | | <9.0 |
| | FBL-02 | FIELD BLANK | | | | | | <9.0 |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS: 6 HR TAT

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED BY (SIGNATURE) | DATE 7.30.02 TIME 0130 | PRINTED NAME KIRK MC KENZIE | RECEIVED BY (SIGNATURE) R. Droudina | DATE 7.31.02 TIME 01.30 | PRINTED NAME R. Droudina |
| RELINQUISHED BY (SIGNATURE) | DATE TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE TIME | PRINTED NAME |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-31-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers Street, NY

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-30-02
**DATE RECEIVED:** 07-31-02
**DATE ANALYZED:** 07-31-02

**SAMPLE MEDIA:** Dust Wipe Sample
**ANALYSIS REQUIRED:** Method EPA 3050/7420

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 20792 | 7th Floor Corridor West Supply O/S C728 | <9.0 | 9.0 |
| LW-02 | 20792 | 7ht Floor Corridor Return Adj. C721 | <9.0 | 9.0 |
| LW-03 | 20792 | 7th Floor Corridor Easrt Supply Adj. 715 | <9.0 | 9.0 |
| LW-04 | 20792 | 7th Floor Corridor East Supply Adj. 705 | 21.6 | 9.0 |
| FBL-1 | 20792 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 20792 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC-WTC_000106909

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RM

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

0302/0356

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

| | | | |
|---|---|---|---|
| CLIENT NAME/ADDRESS: SCA Stuyvesant | CONTACT: Hamid Sanei | SAMPLER (SIGNATURE): | DATE: 7/31/02 TIME: 11:45 |
| | | SAMPLER NAME (PRINT): Bethan C | SAMPLE(S) SEALED: YES / NO |
| PROJECT LOCATION: 345 Chambers | PROJECT #: m477-15217/29881 | MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER _____ | CORRECT CONTAINER(S): YES / NO |

| SAMPLE INFORMATION: | | | AREA (FT²) | SURFACE MATERIAL | | | | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| LABORATORY # | SAMPLE # | LOCATION | | WOOD | METAL | BRICK | OTHER | |
| | 1 | 7th floor corridor c/s 705 East Supply | 1 | | X | | | <10.0 |
| | 2 | 8th floor corridor c/s rm 832 west Supply | 1 | | X | | | <10.0 |
| | FB-1 | | | | | | | — |
| | FB-2 | | | | | | | — |
| | | | | | | | | 0302/0356 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

ENCLAVA/MANHATTAN RECEIVED 02 JUL 31 PM 12:35

Fax TO 516 358 2955
212-406-2535

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY 6 hrs

COMMENTS / INSTRUCTIONS: Call (516) 523-0654 Fax TO (516) 358 1780

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED BY (SIGNATURE) | DATE 7/31/02 TIME 12:00 | PRINTED NAME Bethan | RECEIVED BY (SIGNATURE) | DATE 7/31/02 TIME 12:35 pm | PRINTED NAME |
| RELINQUISHED BY (SIGNATURE) | DATE 7/31/02 TIME 1235 | PRINTED NAME C McELwain | RECEIVED BY LAB (SIGNATURE) | DATE TIME | PRINTED NAME |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

07/31/2002 16:11 212-290-2538 EMSL ANALYTICAL INC PAGE 02/02

NYC-WTC_000106911

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1760 Phone: 516-358-2955
Project: M477-15217 / 29881 / SCA / Stuyvesant / 345 Chambers

Customer ID: TAYL50
Customer PO:
Received: 07/31/02 12:35 PM
EMSL Order: 030210356
EMSL Project ID:

## Lead in Wipes by Flame AAS (SW 846, 7420)

| Client Sample Description | | Lab ID | Analyzed | Area Sampled | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 1 | 7th Floor Corridor O/S 705 East Supply | 0001 | 7/31/2002 | 144 $in^2$ | <10.0 $\mu g/ft^2$ | |
| 2 | 8th Floor Corridor O/S Rm C832 West Supply | 0002 | 7/31/2002 | 144 $in^2$ | <10.0 $\mu g/ft^2$ | |
| FB-1 | Blank | 0003 | 7/31/2002 | n/a | <10.0 µg/wipe | |
| FB-2 | Blank | 0004 | 7/31/2002 | n/a | <10.0 µg/wipe | |

Laboratory Manager
or other approved signatory

Reporting limit is 10 ug/wipe
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581



NYC-WTC_000106912

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

20944

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: Stuyvesant SHS
CONTACT: Hamid Sanj
SAMPLER (SIGNATURE): [signature] DATE 8/5/02 TIME 9:10
SAMPLER NAME (PRINT): [illegible]
SAMPLE(S) SEALED: YES / NO
CORRECT CONTAINER(S): YES / NO
PROJECT LOCATION: 345 Chambers
PROJECT #: M477-15217-29881
MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | 11-01 | 11th flr HVAC #2 Louvre supply | 1 | | X | | | <9.0 |
| | 11-02 | 11th flr HVAC #1 Louvre supply | 1 | | X | | | <9.0 |
| | 05-03 | 5th fl Boys Locker rm HVAC 9 return | 1 | | X | | | <9.0 |
| | 05-04 | 5th fl Boys Locker rm HVAC 9 supply | 1 | | X | | | <9.0 |
| | 05-05 | 5th fl corridor o/s 517 HVAC 1 supply | 1 | | X | | | <9.0 |
| | 05-06 | 5th fl [illegible] cafeteria HVAC 10 supply | 1 | | X | | | <9.0 |
| | F-B-3 | Field Blank | | | | | | <9.0 |
| | FB-4 | Field Blank | | | | | | <9.0 |

Fax 516-358-1760 / 212 406-2535

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /
COMMENTS / INSTRUCTIONS: 6hr T.A.T.

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| [signature] | 8/5/02 | [illegible] | | | |
| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |
| | | | R. Drondina | 8.5.02 | R. Drondina |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 08-07-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 08-05-02 |
| **DATE RECEIVED:** | 08-05-02 |
| **DATE ANALYZED:** | 08-05-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| 11-01 | 20944 | 11th Floor HVAC #2 Louvre Supply | <9.0 | 9.0 |
| 11-02 | 20944 | 11th Floor HVAC #1 Louvre Supply | <9.0 | 9.0 |
| 05-03 | 20944 | 5th Floor Boys Locker Room HVAC #9 | <9.0 | 9.0 |
| 05-04 | 20944 | 5th Floor Boys Locker Room HVAC #9 Supply | <9.0 | 9.0 |
| 05-05 | 20944 | 5th Floor Corridor o/s 517 HVAC #1 Supply | <9.0 | 9.0 |
| 05-06 | 20944 | 5th Floor Cafeteria HVAC #10 Supply | <9.0 | 9.0 |
| FB-3 | 20944 | Field Blank | <9.0 µg | 9.0 µg |
| FB-4 | 20944 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

20905

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: NYC SCA
CONTACT: HAMID SAVAJ
SAMPLER (SIGNATURE): [signature] DATE: 8/4/02 TIME:
SAMPLER NAME (PRINT): Kirk McKenzie
SAMPLE(S) SEALED: (YES) / NO
CORRECT CONTAINER(S): (YES) / NO
PROJECT LOCATION: Stuyvesant HS. 345 Chambers ST NY
PROJECT #: M477-15217-2988
MATRIX (CIRCLE ONE): (WIPE) PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | AHLW-02 | 11th Floor M.E.R. HVAC-2 Supply Liner | 1.0 | | | | X | <9.0 |
| | AHLW-03 | 11th Floor M.E.R. HVAC-2 Return Louver | 1.0 | | X | | | <9.0 |
| | AHLW-05 | 11th Floor M.E.R. HVAC-1 Supply Liner | 1.0 | | | | X | <9.0 |
| | AHLW-06 | 11th Floor M.E.R. HVAC-1 Return Louver | 1.5 | | X | | | 7.6 |
| | AHLW-07 | 11th Floor M.E.R. HVAC-1 Return Liner | 1.0 | | X | | (EA) | <9.0 |
| | AHLW-08 | 11th Floor M.E.R. HVAC-2 Return Liner | 1.0 | | | | X | <9.0 |
| | FBL-1 | Field Blank | — | | | | — | <9.0 |
| | FBL-2 | Field Blank | — | | | | — | <9.0 |

FAX TO 212-406-2525 & 516-358-1780

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /
COMMENTS / INSTRUCTIONS: 6 HR TAT

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| [signature] | 8/4/02 1600 | Kirk McKenzie | | | |
| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |
| | | | R. Droudina | 8.4.02 16.15 | R. Droudina |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 08-05-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 08-04-02 |
| **DATE RECEIVED:** | 08-04-02 |
| **DATE ANALYZED:** | 08-04-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| AHLW-02 | 20905 | 11th Floor M.E.R. HVAC-2 Supply Liner | <9.0 | 9.0 |
| AHLW-03 | 20905 | 11th Floor M.E.R. HVAC-2 Return Louver | <9.0 | 9.0 |
| AHLW-05 | 20905 | 11th Floor M.E.R. HVAC-1 Supply Liner | <9.0 | 9.0 |
| AHLW-06 | 20905 | 11th Floor M.E.R. HVAC-1 Return Louver | 7.6 | 6.0 |
| AHLW-07 | 20905 | 11th Floor M.E.R. HVAC-1 Return Linter | <9.0 | 9.0 |
| AHLW-08 | 20905 | 11th Floor M.E.R. HVAC-2 Return Liner | <9.0 | 9.0 |
| FBL-1 | 20905 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 20905 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001

516-358-2955
Fax 516-358-1780

20903

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

| | | | |
|---|---|---|---|
| CLIENT NAME/ADDRESS: NYC SCA | CONTACT: HAMID SADJ | SAMPLER (SIGNATURE): [signature] DATE: 8/4/02 TIME: | SAMPLE(S) SEALED: YES / NO |
| PROJECT LOCATION: Stuyvesant H.S 345 Chambers ST NY | PROJECT #: M477-15217-29881 | SAMPLER NAME (PRINT): Kirk McKenzie | CORRECT CONTAINER(S): YES / NO |
| | | MATRIX (CIRCLE ONE): (WIPE) PAINT SOIL OTHER _____ | |

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | LW-01 | 6th FLR. - HVAC Corridor Supply - West O/S Room 638 (638) | 1.0 | | X | | | < 9.0 |
| | LW-02 | 6th FLR. - HVAC Corridor Supply - Central O/S E621 | 1.0 | | X | | | < 9.0 |
| | LW-03 | 6th FLR. - HVAC Corridor Supply - East O/S Main East Stair | 1.0 | | X | | | < 9.0 |
| | LW-04 | 6th FLR. - HVAC - Corridor Return O/S Library | 1.0 | | X | | | 17.2 |
| | FB-1 | F. BLANK | — | | | | | < 9.0 |
| | FB-2 | F. BLANK | — | | | | | < 9.0 |
| | | | | | | | | |
| | | | | | | | | |

Fax to 212-406-2535 & 571-358-1780

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS: 6 HR TAT

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED BY (SIGNATURE): [signature] | DATE: 8/4/02 TIME: 1600 | PRINTED NAME: Kirk McKenzie | RECEIVED BY (SIGNATURE): | DATE: TIME: | PRINTED NAME: |
| RELINQUISHED BY (SIGNATURE): | DATE: TIME: | PRINTED NAME: | RECEIVED BY LAB (SIGNATURE): R. Droudina | DATE: 8.4.2 TIME: 16.15 | PRINTED NAME: Droudina |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 08-05-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers Street, NY

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 08-04-02
**DATE RECEIVED:** 08-04-02
**DATE ANALYZED:** 08-04-02

**SAMPLE MEDIA:** Dust Wipe Sample
**ANALYSIS REQUIRED:** Method EPA 3050/7420

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 20903 | 6. 8th Floor HVAC (638) Corridor Supply West O/S Rm 638 | <9.0 | 9.0 |
| LW-02 | 20903 | 6th Floor HVAC Corridor Supply O/C C627 | <9.0 | 9.0 |
| LW-03 | 20903 | 6th Floor HVAC Corridor Supply East O/S East Stair | <9.0 | 9.0 |
| LW-04 | 20903 | 6th Floor HVAC Corridor Return O/O Library | 17.2 | 9.0 |
| FBL-1 | 20903 | Field Blank | <9.0 µg | 9.0 µg |
| FBL-2 | 20903 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$.
Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

030210738

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: NYC SCA
CONTACT: HALID SAVAS
SAMPLER (SIGNATURE): [signature] DATE: 8/6/02 TIME: 1210
SAMPLER NAME (PRINT): CARLOS JOTA
SAMPLE(S) SEALED: YES / NO
CORRECT CONTAINER(S): YES / NO
PROJECT LOCATION: CHAMBERS ST STUYVESANT H.S. NYDY
PROJECT #: M477-1521/2981
MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER ug/FT2

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT |
|---|---|---|---|---|---|---|---|---|
| | LW-01 | 4TH FL - CORRIDOR (1-2000) RETURN BTWN #413 + #421 | 24"x6" 1.0FT² | | X | | | <10.0 |
| | LW-02 | 4TH FL - CORRIDOR SUPPLY - O/S WEST STAIR | 36"x4" 1.0FT² | | X | | | 14.0 |
| | LW-03 | 4TH FL - CORRIDOR SUPPLY - O/S RM #436 | 36"x4" 1.0FT² | | X | | | <10.0 |
| | LW-04 | 4TH FL - CORRIDOR SUPPLY - O/S RM #403/405 | 36"x4" 1.0FT² | | X | | | <10.0 |
| | FB-05 | F/BLANK | — | | | | | - |
| | FB-06 | F/BLANK | — | | | | | - |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /
COMMENTS / INSTRUCTIONS: 6 HR TAT

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| [signature] | 8-6-02 / 1752 | JOTA | [signature] | 8/6/02 / 1752 | |
| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |
| | | | | | |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

PAGE 002/002
EMS ANALYTICAL INC 212-290-2538 08:58 08/07/2002
02 AUG -6 PM 5:58 RECEIVED
NYC-WTC_000106920

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217/29881/ NYC SCA/ CHAMBERS ST. STUYVESANT H.S. NY, NY

Customer ID: TAYL50
Customer PO:
Received: 08/06/02 5:58 PM
EMSL Order: 030210738
EMSL Project ID:

## Lead in Wipes by Flame AAS (SW 846, 7420)

| Client Sample Description | | Lab ID | Analyzed | Area Sampled | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| LW-01 | 4TH FL-CORRIDOR RETURN BTWN. #413 & #421 | 0001 | | 144 in² | <10.0 µg/ft² | |
| LW-02 | 4TH FL-CORRIDOR SUPPLY-O/S WEST STAIR | 0002 | | 144 in² | 14.0 µg/ft² | |
| LW-03 | 4TH FL-CORRIDOR SUPPLY-O/S RM. #436 | 0003 | | 144 in² | <10.0 µg/ft² | |
| LW-04 | 4TH FL-CORRIDOR SUPPLY-O/S RM #403/#405 | 0004 | | 144 in² | <10.0 µg/ft² | |
| FB-05 | Field blank | 0005 | | n/a | <10.0 µg/wipe | |
| FB-06 | Field blank | 0006 | | n/a | <10.0 µg/wipe | |

Laboratory Manager —
or other approved signatory

Reporting limit is 10 ug/wipe
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581



NYC-WTC_000106921

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

21041

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: NYCSCA. Stuyvesant H.S.
CONTACT: Hamid Saadat
SAMPLER (SIGNATURE): [signature] DATE: 8/9/02 TIME: 11:15
SAMPLER NAME (PRINT): Carlos Bolaños
SAMPLE(S) SEALED: YES / NO
CORRECT CONTAINER(S): YES / NO
PROJECT LOCATION: Chambers St, NY, NY
PROJECT #: M447-15217/29866
MATRIX (CIRCLE ONE): WIPE PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT µg/ft² |
|---|---|---|---|---|---|---|---|---|
| | LW-01 | 3rd Fl. Corridor Supply O/S Rm 335/337 | 1.0 | | X | | | <9.0 |
| | LW-02 | 3rd Fl Corridor Supply O/S Rm C323/C325 | 1.0 | | Y | | | <9.0 |
| | LW-03 | 3rd Fl Corridor Return O/S Rm C321 | 1.0 | | Y | | | <9.0 |
| | LW-04 | 3rd Fl Corridor Supply @ Elevator (P) | 1.0 | | Y | | | <9.0 |
| | FB-01 | F/Blank | — | | | | | <9.0 |
| | FB-02 | F/Blank | — | | | | | <9.0 |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /
COMMENTS / INSTRUCTIONS: GREEN

| RELINQUISHED BY (SIGNATURE) | DATE / TIME | PRINTED NAME | RECEIVED BY (SIGNATURE) | DATE / TIME | PRINTED NAME |
|---|---|---|---|---|---|
| [signature] | 8-9-02 | | ATC Lab [signature] | 08/09/02 17:30 | [signature] D. Kocian |
| [signature] | 8-9-02 5:30 | PRINTED NAME: M. Francis | RECEIVED BY LAB (SIGNATURE) | DATE / TIME | PRINTED NAME |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 08-12-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217-29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 08-09-02 |
| **DATE RECEIVED:** | 08-09-02 |
| **DATE ANALYZED:** | 08-09-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 21041 | 3rd Floor Corridor Supply O/S Rm 335/337 | <9.0 | 9.0 |
| LW-02 | 21041 | 3rd Floor Corridor Supply O/S Rm C323/C325 | <9.0 | 9.0 |
| LW-03 | 21041 | 3rd Floor Corridor Return O/S Rm C321 | <9.0 | 9.0 |
| LW-04 | 21041 | 3rd Floor Corridor Supply @ Elevator (P) | <9.0 | 9.0 |
| FB-1 | 21041 | Field Blank | <9.0 µg | 9.0 µg |
| FB-2 | 21041 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.
130 JERICHO TPKE., FLORAL PARK, NY 11001
516-358-2955
Fax 516-358-1780

21057

# LEAD SAMPLING DATA AND CHAIN OF CUSTODY DOCUMENT

CLIENT NAME/ADDRESS: NYC
SCA:

CONTACT: HAMID SAVOJ

SAMPLER (SIGNATURE): Carlos [illegible] DATE: 8-10-02 TIME:

SAMPLE(S) SEALED: (YES) / NO

SAMPLER NAME (PRINT): CARLOS JOFAT

CORRECT CONTAINER(S): (YES) / NO

PROJECT LOCATION: STUYVESANT H.S.

PROJECT #: 11477-15217/29881

MATRIX (CIRCLE ONE): (WIPE) PAINT SOIL OTHER _____

SAMPLE INFORMATION:

| LABORATORY # | SAMPLE # | LOCATION | AREA (FT²) | SURFACE MATERIAL: WOOD | METAL | BRICK | OTHER | LAB RESULT (µg/ft²) |
|---|---|---|---|---|---|---|---|---|
| | LW-01 | 3rd Floor GYM. RETURN AT center. east. | composite 1 | | ✓ | | | <9.0 |
| | LW-02. | 3rd. Floor SUPPLY AT North east corner. | composite 1 | | / | | | <9.0 |
| | FB-1 | FIELD BLANK | — | — | — | — | — | <9.0 |
| | FB-2 | FIELD BLANK | — | — | — | — | — | <9.0 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

TURNAROUND REQUIRED: NORMAL ☐ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS: 6 HR TAT

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED BY (SIGNATURE): Carlos [illegible] | DATE: 8-10-02 TIME: 18.30 | PRINTED NAME: CARLOS JOFAT | RECEIVED BY (SIGNATURE): [illegible] | DATE: 8/10/2 TIME: 13:30 | PRINTED NAME: |
| RELINQUISHED BY (SIGNATURE): | DATE: TIME: | PRINTED NAME: | RECEIVED BY LAB (SIGNATURE): | DATE: TIME: | PRINTED NAME: |

WHITE - OFFICE / YELLOW - LAB / PINK - CLIENT

NYC 9/11 Public Portal Document

**ATC ASSOCIATES, INC**
**104 E 25th Street, 10th Floor**
**New York, NY 10010**
**Tel. 212-353-8280**
**Fax 212-353-8306**

| | |
|---|---|
| **REPORT DATE:** | 08-12-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers Street, NY |
| **PROJECT NUMBER:** | M477-15217-29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE:** | 08-10-02 |
| **DATE RECEIVED:** | 08-10-02 |
| **DATE ANALYZED:** | 08-10-02 |
| **SAMPLE MEDIA:** | Dust Wipe Sample |
| **ANALYSIS REQUIRED:** | Method EPA 3050/7420 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/ft^2$) | DETECTION LIMIT ($\mu g/ft^2$) |
|---|---|---|---|---|
| LW-01 | 21057 | 3rd Floor GYM Return at Center East | <9.0 | 9.0 |
| LW-02 | 21057 | 3rd Floor Supply at North East Corner | <9.0 | 9.0 |
| FB-1 | 21057 | Field Blank | <9.0 µg | 9.0 µg |
| FB-2 | 21057 | Field Blank | <9.0 µg | 9.0 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 18.0 µg**
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.

# LEAD PERSONAL (OSHA) AIR MONITORING RESULTS 3RD THROUGH 10TH FLOORS

**PROJECT #: M477-15217**
**LLW#: 29881**

130A JERICHO TPKE., FLORAL PARK, NY 11001 • PHONE (516) 358-2955 • FAX (516) 358-1780

NYC-WTC_000106928

NYC 9/11 Public Portal Document

20361

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: STUYVESANT H.S. 345 CHAMBERS ST. | DATE SUBMITTED: 7-14-02. |
| DATE SAMPLED: 7-14-02. | CONTACT: ARNOLD SAVOS. | WORK AREA: TEN (10TH) FLOOR. | DATE LOGGED: |
| ROTOMETER NO: TEG L-16 | PROJECT NO.: M477. 15217 / 24881 | PROJECT MANAGER: CHRIS MC ELOUN. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | MG/M3 | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ MARIA ORTEGA. RM# 1001 TENT 1<br>OWA ☐ SS# PII → Northeast | 2 / 2 | 0800 | 1135 | 205 | 2 | 410 | | | 43.7 | |
| L-02 | | IWA ☐ KLEVER CALLE RM# 1001 TENT 2.<br>OWA ☐ SS# PII → South. | 2 / 2 | 0805 | 1136 | 201 | 2 | 402 | | | 43.7 | |
| L-03. | | IWA ☐ PABLO ORGILES RM# ~~000~~ 1007.<br>OWA ☐ SS# PII → South. | 2 / 2 | 0810 | 1138 | 200 | 2 | 400 | | | 43.7 | |
| L-04. | | IWA ☐ RAMIREZ ZAY ROOM# 1009.<br>OWA ☐ SS# PII → South. | 2 / 2. | 0950 | 1139. | 109 | 2 | 218 | | | 46.9 | |
| L-05 | | IWA ☐ MARIA ORTEGA → RM# 1001 Tent# 1<br>OWA ☐ SS# PII → Northeast | 2 / 1.0 | 1200 | 1518 | 198 | 1.5 | 297 | | | 45.1 | |
| L-06 | | IWA ☐ KLEVER CALLE RM# 1001 Tent# 2.<br>OWA ☐ SS# PII → South. | 2 / 2 | 1202 | 1517. | 197 | 2 | 394 | | | 43.8 | |
| L-07 | | IWA ☐ PABLO ORGILES RM# 1007<br>OWA ☐ SS# PII South. | 2 / 1 | 1203 | 1515 | 198 | 1.5 | 297 | | | 45.1 | |
| L-08 | | IWA ☐ RAMIREZ ZAY ROOM# 1009.<br>OWA ☐ SS# PII → South. | 2 / 1 | 1205 | 1519. | 196. | 1.5 | 294. | | | 45.1 | |
| FB 1 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | |
| FB 2. | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos Quinfofat | 7-14-02. | 1705 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) Jacy Slay | 7-14-02 | 18:30 | COMMENTS: (12 HRS TAT.) NIOSH Method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT # — FILTER MANUFACTURER: Envirex.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document


# ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306


**REPORT DATE:** 07-15-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 10th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-14-02
**DATE RECEIVED:** 07-15-02
**DATE ANALYZED:** 07-15-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L01 | 20361 | Maria Ortega SS# PII | <3.7 | 3.7 |
| L02 | 20361 | Klever Calle SS# PII | <3.7 | 3.7 |
| L03 | 20361 | Pablo Orgiles SS# PII | <3.7 | 3.7 |
| L04 | 20361 | Ramirez Zay SS# PII | <6.9 | 6.9 |
| L05 | 20361 | Maria Ortega SS# PII | <5.1 | 5.1 |
| L06 | 20361 | Klever Calle SS# PII | <3.8 | 3.8 |
| L07 | 20361 | Pablo Orgiles SS# PII | <5.1 | 5.1 |
| L08 | 20361 | Ramirez Zay SS# PII | <5.1 | 5.1 |
| FB1 | 20361 | Field Blank | <1.5 µg | 1.5 µg |
| FB2 | 20361 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE ____ OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: N. Pholah | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S. Chambers St NYC | DATE SUBMITTED: 7-15-02 |
| DATE SAMPLED: 7.14.02 | CONTACT: Hamid Saadi | WORK AREA: 10th | DATE LOGGED: |
| ROTOMETER NO.: L-18 | PROJECT NO.: M477-15217/74551 | PROJECT MANAGER: Ch. McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L01 | | IWA ☐ OWA ☐ Raul Loja PII rm 1009 | 2/2 | 16⁴⁸ | 19⁵² | 184 | 2 | 368 | | | | |
| L02 | | IWA ☐ OWA ☐ Felix Calle PII rm 1007 | 2/2 | 16⁵⁵ | 19⁵⁴ | 179 | 2 | 358 | | | | |
| L03 | | IWA ☐ OWA ☐ Jose Vivar PII rm 1001 east | 2/2 | 17⁰¹ | 19⁵⁵ | 194 | 2 | 348 | | | | |
| L04 | | IWA ☐ OWA ☐ Luis Rodriguez - PII rm 1001 south | 2/2 | 17⁰⁴ | 19⁵⁷ | 173 | 2 | 346 | | | | |
| L05 | | IWA ☐ OWA ☐ Mauricio Avila - PII rm 1027 | 2/2 | 17⁰⁷ | 19⁵⁹ | 172 | 2 | 344 | | | | |
| L06 | | IWA ☐ OWA ☐ Henri Avila - PII rm 1025 | 2/2 | 17¹⁰ | 20⁰⁰ | 170 | 2 | 340 | | | | |
| L07 | | IWA ☐ OWA ☐ Raul Loja - PII rm 1009 | 2/2 | 20⁴² | 23⁴⁵ | 183 | 2 | 366 | | | | |
| L08 | | IWA ☐ OWA ☐ Felix Calle PII rm 1033 | 2/2 | 20⁴⁴ | 23⁴⁷ | 183 | 2 | 366 | | | | |
| L09 | | IWA ☐ OWA ☐ Jose Vivar PII rm 1009 | 2/2 | 20⁴⁵ | 23⁴⁹ | 184 | 2 | 368 | | | | |
| L10 | | IWA ☐ OWA ☐ Luis Rodriguez PII rm 1033 | 2/2 | 20⁴⁷ | 23⁵⁰ | 183 | 2 | 366 | | | | |
| L11 | | IWA ☐ OWA ☐ Mauricio Avila PII rm 1017 | 2/2 | 20⁴⁹ | 23⁵² | 183 | 2 | 366 | | | | |
| L12 | | IWA ☐ OWA ☐ Henri Avila PII rm 1025 | 2/2 | 20⁵⁰ | 23⁵³ | 183 | 2 | 366 | | | | |
| BL1 | | IWA ☐ OWA ☐ | | | | | | | | | | |
| BL 2 | | | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): N. Pholah | 7-15-02 | 0100 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12hour turnaround | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — USHA — OTHER NIOSH 7082

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106931

NYC 9/11 Public Portal Document


# ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306


**REPORT DATE:** 07-15-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 10th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-14-02
**DATE RECEIVED:** 07-15-02
**DATE ANALYZED:** 07-15-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L01 | 20368 | Raul Loja SS# PII | <4.1 | 4.1 |
| L02 | 20368 | Felix Calle SS# PII | <4.2 | 4.2 |
| L03 | 20368 | Jose Vivar SS# PII | <4.3 | 4.3 |
| L04 | 20368 | Luis Rodriguez SS# PII | <4.3 | 4.3 |
| L05 | 20368 | Mauricio Arila SS# PII | <4.4 | 4.4 |
| L06 | 20368 | Henry Avila SS# PII | <4.4 | 4.4 |
| L07 | 20368 | Raul Loja SS# PII | <4.1 | 4.1 |
| L08 | 20368 | Felix Calle SS# PII | <4.1 | 4.1 |
| L09 | 20368 | Jose Vivar SS# PII | <4.1 | 4.1 |
| L10 | 20368 | Luis Rodriguez SS# PII | <4.1 | 4.1 |
| L11 | 20368 | Mauricio Arila SS# PII | <4.1 | 4.1 |
| L12 | 20368 | Henry Avila SS# PII | <4.1 | 4.1 |
| BL1 | 20368 | Field Blank | <1.5 µg | 1.5 µg |
| BL2 | 20368 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD 20388

PAGE 1 OF 2

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCH. | STUYVESANT H.S. 345 CHAMBERS ST. NYC. | 7-14-02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-15-02. | HAMID SAVOJ. | 10th Floor. | |
| **ROTOMETER NO.** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG L-18 | H477 - 15217/29881 | CHRIS McELROY. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ JAIME QUISI → SS# PII<br>OWA ☐ ROOM # 1039. South side. | 2/2 | 0715 | 1124 | 249 | 2 | 498 | | | | < 3.0 |
| L-02 | | IWA ☐ ANA ALVAREZ → SS# PII<br>OWA ☐ ROOM # 1017 South side. | 2/2 | 0716 | 1121 | 245 | 2 | 490 | | | | < 3.0 |
| L-03 | | IWA ☐ JESUS VELEZ → SS# PII<br>OWA ☐ ROOM # 1033. South side. | 2/2 | 0717 | 1122 | 245 | 2 | 490 | | | | < 3.0 |
| L-04 | | IWA ☐ SILVIO PEREZ → SS# PII<br>OWA ☐ ROOM # 1025 South side | 2/2 | 0718 | 1120 | 242 | 2 | 484 | | | | < 3.0 |
| L-05 | | IWA ☐ MIGUEL ALI → SS# PII<br>OWA ☐ ROOM # 1024. North side. | 2/2 | 0719 | 1123 | 244. | 2 | 488 | | | | 8.4 |
| L-06 | | IWA ☐ MANUEL VISCAINO → SS# PII<br>OWA ☐ ROOM # 1039 → Northeast side. | 2/2 | 0720 | 1030 | 190 | 2. | 380 | | | | < 3.9 |
| L-07 | | IWA ☐ ALEX BERNAL → SS# PII<br>OWA ☐ ROOM # 1039. → North west side | 2/2 | 0721 | 1127. | 246 | 2 | 492 | | | | < 3.0 |
| L-08 | | IWA ☐ MARIA DUCHITANGA → SS# PII<br>OWA ☐ ROOM # 1004 → Southside. | 2/2 | 0915 | 1125 | 130 | 2 | 260 | | | | < 5.8 |
| L-09 | | IWA ☐ JAIME QUISI → SS# PII<br>OWA ☐ ROOM # 1039 - South side. | 2/2 | 1207 | 1447 | 160 | 2 | 320 | | | | < 4.7 |
| L-10 | | IWA ☐ ANA ALVAREZ → SS # PII<br>OWA ☐ ROOM # 1017 → South side. | 2/2 | 1203 | 1448 | 165 | 2 | 330 | | | | < 4.5 |
| L-11 | | IWA ☐ JESUS VELEZ SS# PII<br>OWA ☐ ROOM # 1033 South side. | 2/2 | 1206 | 1449 | 163 | 2 | 326 | | | | < 4.7 |
| L-12 | | IWA ☐ SILVIO PEREZ SS# PII<br>OWA ☐ ROOM # 1025 South side. | 2/2 | 1208 | 1450 | 162 | 2 | 324 | | | | < 4.7 |
| L-13 | | IWA ☐ MIGUEL ALI SS# PII<br>OWA ☐ ROOM # 1024 North side. | 2/2 | 1205 | 1445 | 160 | 2 | 320 | | | | < 4.7 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | 6:00PM | 07/15 | | 6pm |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| | 7-15-02. | 1530 | | | |
| **ANALYST (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | NIOSH METHOD 7082. 12 HRS TAT | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER NIOSH 7082 Lead.

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106933

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: STUYVESANT H.S. 345 CHAMBERS. NYC. | DATE SUBMITTED: 7-15-02 |
| DATE SAMPLED: 7-15-02. | CONTACT: HAMID SAND( | WORK AREA: 10th Floor. | DATE LOGGED: |
| ROTOMETER NO: TEG L-18. | PROJECT NO: M477-15217/29881. | PROJECT MANAGER: CHRIS MCELOUN. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ MANUEL VISCAINO SS# PII<br>OWA ☐ ROOM # 1039 → North east side. | 2/2 | 1209. | 1400 | 171 | 2 | 342 | | | <44 | <44 |
| L-15 | | IWA ☐ ALEX BERNAL → SS# PII<br>OWA ☐ ROOM # 1039. Northwest side. | 2/2 | 1204 | 1501 | 177. | 2 | 354. | | | <42 | <42 |
| L-16 | | IWA ☐ MARIA DUCHITANGA SS# PII<br>OWA ☐ ROOM # 1004 → North side. | 2/2 | 1200 | 1342 | 102 | 2 | 204 | | | <74 | <74 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7-15-02 | TIME: 1530 | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: NIOSH Method 7082 12HRS TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER (Lead) NIOSH 7082

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-16-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 10th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-14-02
**DATE RECEIVED:** 07-16-02
**DATE ANALYZED:** 07-16-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20388 | J.Quisi ss# PII | <3.0 | 3.0 |
| L-02 | 20388 | A. Alvarez sS# PII | <3.0 | 3.0 |
| L-03 | 20388 | J. Velez SS# PII | <3.0 | 3.0 |
| L-04 | 20388 | S. Perez SS# PII | <3.0 | 3.0 |
| L-05 | 20388 | A. Ali SS# PII | 8.4 | 3.0 |
| L-06 | 20388 | H. Viscaino SS# PII | <3.9 | 3.9 |
| L-07 | 20388 | A. Bernal SS# PII | <3.0 | 3.0 |
| L-08 | 20388 | M. Duchitanga SS# PII | <5.8 | 5.8 |
| L-09 | 20388 | J.Quisi ss# PII | <4.7 | 4.7 |
| L-10 | 20388 | A. Alvarez sS# PII | <4.5 | 4.5 |
| L-11 | 20388 | J. Velez SS# PII | <4.7 | 4.7 |
| L-12 | 20388 | S. Perez SS# PII | <4.7 | 4.7 |
| L-13 | 20388 | A. Ali SS# PII | <4.7 | 4.7 |
| L-14 | 20388 | H. Viscaino SS# PII | <4.4 | 4.4 |
| L-15 | 20388 | A. Bernal SS# PII | <4.2 | 4.2 |
| L-16 | 20388 | M. Duchitanga SS# PII | <7.4 | 7.4 |

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE _____ OF _____

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plonski | CLIENT: SCA | SITE ADDRESS: Chambers St Stuyvesant HS. | DATE SUBMITTED: |
| DATE SAMPLED: 7.15.02 | CONTACT: Hamid Santos | WORK AREA: 10th. | DATE LOGGED: |
| ROTOMETER NO: L-18 | PROJECT NO.: M-477-15217-24881 | PROJECT MANAGER: CH. McElquin | DATE APPROVED / SIGNATURE: 7/30/3 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION (MINUTES) | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L01 | | IWA ☐ OWA ☐ Gil Calle room 1010 PII | 2 / | 16.15 | 20⁰² | 227 | 2 | 454 | | | | |
| L02 | | IWA ☐ OWA ☐ Cesar Chalen rm 1006 PII | 2 / 2 | 16.17 | 19⁵² | 215 | 2 | 430 | | | | |
| L03 | | IWA ☐ OWA ☐ ANTONIO CUSCO rm 1004 PII | 2 / 2 | 16.20 | 19⁵⁶ | 216 | 2 | 432 | | | | |
| L04 | | IWA ☐ OWA ☐ Mauricio Avila rm 901 PII | 2 / 2 | 17⁵⁸ | 19⁵⁸ | 120 | 2 | 240 | | | | |
| L05 | | IWA ☐ OWA ☐ Eloy Cuzco rm 903 PII | 2 / 2 | 18²⁵ | 20⁰⁵ | 101 | 2 | 202 | | | | |
| L06 | | IWA ☐ OWA ☐ Gil Calle 1010 PII | 2 / 2 | 20⁴⁰ | 23⁴² | 182 | 2 | 364 | | | | |
| L07 | | IWA ☐ OWA ☐ Cesar Chalen 1006 PII | 2 / 2 | 20⁴¹ | 23⁴³ | 182 | 2 | 364 | | | | |
| L08 | | IWA ☐ OWA ☐ Antonio Cuzco 1004 PII | 2 / 2 | 20⁴² | 23⁴⁵ | 183 | 2 | 366 | | | | |
| L09 | | IWA ☐ OWA ☐ Mauricio Avila rm 901 PII | 2 / 2 | 20⁴⁵ | 23⁴⁰ | 175 | 2 | 350 | | | | |
| L10 | | IWA ☐ OWA ☐ Eloy Cuzco rm 903 PII | 2 / 2 | 20⁴⁷ | 23³⁸ | 171 | 2 | 342 | | | | |
| L11 | | IWA ☐ OWA ☐ Nube Gallegos rm 907 PII | 2 / 2 | 22⁰⁷ | 23⁵⁹ | 112 | 2 | 224 | | | | |
| L12 | | IWA ☐ OWA ☐ Floor Bunay rm 913 PII | 2 / 2 | 22⁰⁸ | 23⁵⁷ | 109 | 2 | 218 | | | | |
| L13 L14 | | IWA ☐ OWA ☐ blank blank | / | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): A Stelle | DATE: 7.16.02 | TIME: 1AM | RECEIVED FROM TEG DROP BOX (SIGNATURE): T | DATE: 7/16/02 | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY (SIGNATURE) | DATE: 7/16 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 hours. turn. | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER: T802 NIOSH

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

**ATC ASSOCIATES, INC**
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-16-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 10th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-15-02
**DATE RECEIVED:** 07-16-02
**DATE ANALYZED:** 07-16-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L01 | 20393 | Gil Colle SS# PII | <3.3 | 3.3 |
| L02 | 20393 | Cesar Chalen SS# PII | <3.5 | 3.5 |
| L03 | 20393 | Antonio Cusco SS# PII | <3.5 | 3.5 |
| L04 | 20393 | Mauricio Avila SS# PII | <6.3 | 6.3 |
| L05 | 20393 | Eloy Cuzco SS# PII | <7.4 | 7.4 |
| L06 | 20393 | Gil Colle SS# PII | <4.1 | 4.1 |
| L07 | 20393 | Cesar Chalen SS# PII | <4.1 | 4.1 |
| L08 | 20393 | Antonio Cusco SS# PII | <4.1 | 4.1 |
| L09 | 20393 | Mauricio Avila S PII | <4.3 | 4.3 |
| L10 | 20393 | Eloy Cuzco SS# PII | <4.4 | 4.4 |
| L11 | 20393 | Nube Fallegos SS# PII | <6.7 | 6.7 |
| L12 | 20393 | Floa Bunao SW# PII | <6.9 | 6.9 |
| L13 | 20393 | Field Blank | <1.5 µg | 1.5 µg |
| L14 | 20393 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

12 HRS / AM

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

20399



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA | STUYVESANT HS NYC NY. | 7-16-02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-16-02 | HAMID SAVOJ. | 9th Floor. | |
| **ROTOMETER NO.** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TETG - 16 | M477-15217/29881 | CHAS McELOON | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | FIG 1 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ BEATRIZ CHAVEZ SS# PII<br>OWA ☐ RM # 901 → East side. | 2/2 | 0730 | 1115 | 225 | 2.0 | 450 | | | | <3.3 |
| L-02 | | IWA ☐ CARLOS ALI SS# PII<br>OWA ☐ RM # 903 SS# PII | 2/2 | 0732 | 1136 | 244 | 2 | 488 | | | | <3.1 |
| L-03 | | IWA ☐ WILSON OLIVO SS# PII<br>OWA ☐ RM # 907 South side. | 2/2 | 0734 | 1116 | 222 | 2.0 | 444 | | | | <3.3 |
| L-04 | | IWA ☐ LUIS TACURI SS# PII<br>OWA ☐ ROOM # 911 South east | 2/2 | 0736 | 1117 | 221 | 2.0 | 442 | | | | <3.3 |
| L-05 | | IWA ☐ MANUEL VISCAINO SS# PII<br>OWA ☐ ROOM # 911 South west | 2/2 | 0738 | 1002 | 144 | 2 | 288 | | | | <5.2 |
| L-06 | | IWA ☐ MARIA ALVAREZ SS# PII<br>OWA ☐ ROOM # 913 → South side | 2/2 | 0740 | 1000 | 140 | 2 | 280 | | | | <5.4 |
| L-07 | | IWA ☐ MARIA ALVAREZ SS# PII<br>OWA ☐ ROOM # 925 South side. | 2/2 | 1000 | 1150 | 190 | 2.0 | 380 | | | | <7.5 |
| L-08 | | IWA ☐ BEATRIZ CHAVEZ. SS# PII<br>OWA ☐ RM # 901 → East side. | 2/2 | 1210 | 1510 | 180 | 2 | 360 | | | | <4.2 |
| L-09 | | IWA ☐ CARLOS ALI SS# PII<br>OWA ☐ ROOM # 903 | 2/2 | 1211 | 1511 | 180 | 2 | 360 | | | | <4.2 |
| L-10 | | IWA ☐ WILSON OLIVO SS# PII<br>OWA ☐ RM # 907 South side. | 2/2 | 1208 | 1512 | 184 | 2 | 368 | | | | <4.1 |
| L-11 | | IWA ☐ LUIS TACURI SS# PII<br>OWA ☐ ROOM # 911 South west | 2/2 | 1209 | 1513 | 184 | 2 | 368 | | | | <4.1 |
| L-12 | | IWA ☐ MANUEL VILCAINO SS# PII<br>OWA ☐ ROOM # 911 Southwest | 2/2 | 1211 | 1514 | 183 | 2 | 366 | | | | <4.1 |
| L-13 | | IWA ☐ MARIA ALVAREZ. SS# PII<br>OWA ☐ ROOM # 925 - South side | 2/2 | 1213 | 1515 | 182 | 2 | 364 | | | | <4.1 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | 500pm | 7/17 6pm | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| Carlos Jofat | 7-16-02 | 1545 | | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | Fax Results to TEG! (212) 406 2535<br>NIOSH Method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106938

NYC 9/11 Public Portal Document

12 HRS TAT

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| Carlos Jofre | NYC SCA. | Stuyvesant H.S. P4C #4 | 7-16-02. |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-16-02. | Hamid Shoat. | 9th Floor. | |
| **ROTOMETER NO** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TE Id-16 | M 477-15217 / 29881 | Chris Mc Elroy | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ Serena Manuel SSA PII<br>OWA ☐ Room # 927 South side | 2 / 2 | 1905 | 1516 | 131 | 2 | 262 | | | | < 5.7 |
| L-15 | | IWA ☐ Tenezaca Julio SSA PII<br>OWA ☐ Room # 931 South side. | 2 / 2 | 1906 | 1517 | 131 | 2 | 262 | | | | < 5.7 |
| FB 1 | | IWA ☐<br>OWA ☐ Field Blank | — / — | — | — | — | — | — | | | | < 1.5 |
| FB 2 | | IWA ☐<br>OWA ☐ Field Blank | — / — | — | — | — | — | — | | | | < 1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | AG 07/17 | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY (SIGNATURE)** | **DATE** | **TIME** |
| Carlos Jofre | 7-16-02 | 1545 | | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | NIOSH Method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER Lead.

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-17-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 9th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-16-02
**DATE RECEIVED:** 07-17-02
**DATE ANALYZED:** 07-17-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20399 | Beatriz Chavez SS# PII | <3.3 | 3.3 |
| 02 | 20399 | Carlos Ali SS# PII | <3.1 | 3.1 |
| 03 | 20399 | Wilson Olivo SS# PII | <3.3 | 3.3 |
| 04 | 20399 | Luis Tacuri SS# PII | <3.3 | 3.3 |
| 05 | 20399 | Manuel Viscaino SS# PII | <5.2 | 5.2 |
| 06 | 20399 | Maria Alvarez SS# PII | <5.4 | 5.4 |
| 07 | 20399 | Maria Alvarez SS# PII | <7.5 | 7.5 |
| 08 | 20399 | Beatriz Chavez SS# PII | <4.2 | 4.2 |
| 09 | 20399 | Carlos Ali SS# PII | <4.2 | 4.2 |
| 10 | 20399 | Wilson Olivo SS# PII | <4.1 | 4.1 |
| 11 | 20399 | Luis Tacuri SS# PII | <4.1 | 4.1 |
| 12 | 20399 | Manuel Viscaino SS# PII | <4.1 | 4.1 |
| 13 | 20399 | Maria Alvarez SS# PII | <4.1 | 4.1 |
| 14 | 20399 | Serna Marisol SS# PII | <5.7 | 5.7 |
| 15 | 20399 | Tenezaca Twlio SS# PII | <5.7 | 5.7 |
| FB1 | 20399 | Field Blank | <1.5 µg | 1.5 µg |
| FB2 | 20399 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plank | CLIENT: SCA | SITE ADDRESS: Chambers St Stuyvesant HS | DATE SUBMITTED: |
| DATE SAMPLED: 7.16.02 | CONTACT: Hamid Saos | WORK AREA: 9th fl. | DATE LOGGED: |
| POTENTIOMETER NO.: L-18 | PROJECT NO.: M-477-15217-29881 | PROJECT MANAGER: Ch. McElgunn | DATE APPROVED / SIGNATURE: 20435 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L01 | | IWA ☐ OWA ☐ Walter Gallegos - PII rm 935 | 2/2 | 1805 | 1956 | 191 | 2 | 222 | | | | |
| L02 | | IWA ☐ OWA ☐ Rigoberto Cortes - PII rm 931 | 2/2 | 1620 | 1948 | 208 | 2 | 416 | | | | |
| L03 | | IWA ☐ OWA ☐ Romulo Calle - PII rm 927 | 2/2 | 1612 | 1950 | 218 | 2 | 436 | | | | |
| L04 | | IWA ☐ OWA ☐ Lady Pora PII rm 926 | 2/2 | 1612 | 1952 | 220 | 2 | 440 | | | | |
| L05 | | IWA ☐ OWA ☐ Teresa Bunay PII rm 913 | 2/2 | 1622 | 1955 | 213 | 2 | 426 | | | | |
| L06 | | IWA ☐ OWA ☐ Vivar Jose PII 939 | 2/2 | 1807 | 1958 | 111 | 2 | 222 | | | | |
| L07 | | IWA ☐ OWA ☐ Walter Gallegos PII drm 938 | 2/2 | 2034 | 2338 | 184 | 2 | 368 | | | | |
| L08 | | IWA ☐ OWA ☐ Rigoberto Cortes PII rm 936 | 2/2 | 2036 | 2340 | 184 | 2 | 368 | | | | |
| L09 | | IWA ☐ OWA ☐ Romulo Calle PII rm 927 | 2/2 | 2038 | 2350 | 192 | 2 | 384 | | | | |
| L10 | | IWA ☐ OWA ☐ Lady Pora PII rm 926 | 2/2 | 2040 | 2342 | 182 | 2 | 364 | | | | |
| L11 | | IWA ☐ OWA ☐ Teresa Bunay PII 913 | 2/2 | 2042 | 2343 | 181 | 2 | 362 | | | | |
| L12 | | IWA ☐ OWA ☐ Angulo Rosina PII rm 938 | 2/2 | 2202 | 2346 | 104 | 2 | 208 | | | | |
| L13/L14 | | IWA ☐ OWA ☐ field blank field blank | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): W Plank | DATE: 7.16.02 | TIME: 1AM | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): | DATE: | TIME: | RECEIVED BY: (SIGNATURE): ? | DATE: 7/17/2 | TIME: 9a |
| ANALYST: (SIGNATURE): | DATE: | TIME: | COMMENTS: 12 hours turnaround | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER: Mosh 7082

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-17-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 9th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-16-02
**DATE RECEIVED:** 07-17-02
**DATE ANALYZED:** 07-17-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20435 | Walter Gallegos SS# PII | <6.8 | 6.8 |
| 02 | 20435 | Rigoberto Cantos SS# PII | <3.6 | 3.6 |
| 03 | 20435 | Romulo Calle SS# PII | <3.4 | 3.4 |
| 04 | 20435 | Lady Pora SS# PII | <3.4 | 3.4 |
| 05 | 20435 | Teresa Bunay SS# PII | <3.5 | 3.5 |
| 06 | 20435 | Vivar Jose SS# PII | <6.8 | 6.8 |
| 07 | 20435 | Walter Gallegos SS# PII | <4.1 | 4.1 |
| 08 | 20435 | Rigoberto Cantos SS# PII | <4.1 | 4.1 |
| 09 | 20435 | Romulo Calle SS# PII | <3.9 | 3.9 |
| 10 | 20435 | Lady Pora SS# PII | <4.1 | 4.1 |
| 11 | 20435 | Teresa Bunay SS# PII | <4.1 | 4.1 |
| 12 | 20435 | Angulo Rossina SS# PII | <7.2 | 7.2 |
| 13 | 20435 | Field Blank | <1.5 µg | 1.5 µg |
| 14 | 20435 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

20943

PAGE 1 OF 2

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H S. | 7-17-02. |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-17-02. | HAMID SAVOJ. | 9th Floor | |
| **ROTOMETER NO.** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG - L 18. | H477 - 15217 / 29881 | CHRIS HOELGUN. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ MARIA ORTEGA SS# PII<br>OWA ☐ ROOM # 936. South. | 2/2 | 0720 | 1179 | 249 | 2 | 498 | | | | <3.0 |
| L-02 | | IWA ☐ BOLIVAR VICUNA SS# PII<br>OWA ☐ ROOM # 938. | 2/2 | 0721 | 1115 | 234 | 2 | 468 | | | | <3.2 |
| L-03 | | IWA ☐ LUIS AVILA SS# PII<br>OWA ☐ ROOM # 939. | 2/2 | 0722 | 1116 | 234 | 2 | 468 | | | | 3.2 |
| L-04 | | IWA ☐ MARISOL SCENA SS# PII<br>OWA ☐ ROOM # 940 | 2/2 | 0723 | 1117 | 234. | 2 | 468 | | | | 3.3 |
| L-05 | | IWA ☐ MARTHA CAIZA SS# PII<br>OWA ☐ ROOM # 935 | 2/2 | 0724 | 0930 | 126 | 2 | 252. | | | | 5.5 |
| L-06 | | IWA ☐ LUIS RODRIGUEZ SS# PII<br>OWA ☐ ROOM # 927. | 2/2 | 0725 | 0941 | 136 | 2 | 272 | | | | <5.5 |
| L-07 | | IWA ☐ MARIA MONTANEZ SS# PII<br>OWA ☐ ROOM # 931 | 2/2 | 0726 | 1128 | 242 | 2 | 484 | | | | 4.3 |
| L-08 | | IWA ☐ JULIA TENEZACA SS# PII<br>OWA ☐ ROOM # 1010. | 2/2 | 0930 | 1138 | 128 | 2 | 256 | | | | 9.7 |
| L-09. | | IWA ☐ MARTHA CAIZA SS# PII<br>OWA ☐ ROOM # 911. | 2/2 | 0932 | 1129 | 118 | 2 | 236 | | | | <6.4 |
| L-10 | | IWA ☐ LUIS RODRIGUEZ SS# PII<br>OWA ☐ ROOM # 926. | 2/2 | 0942. | 1128 | 106 | 2 | 212 | | | | 12.3 |
| L-11 | | IWA ☐ MARIA ORTEGA SS# PII<br>OWA ☐ ROOM # 936. | 2/2 | 1210 | 1505 | 175 | 2 | 350 | | | | 3.7 |
| L-12 | | IWA ☐ BOLIVAR VICUNA SS# PII<br>OWA ☐ ROOM # 938 | 2/1 | 1219 | 1506 | 167 | 1.5 | 251 | | | | <5.9 |
| L-13 | | IWA ☐ LUIS AVILA SS# PII<br>OWA ☐ ROOM # 939. | 2/2 | 1211 | 1507 | 176 | 2 | 352 | | | | <4.3 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Carlos Ojeda Jofat | 7-17-02 | 1650 | ACes 07/17 Cgn | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| | | | | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT #

FILTER MANUFACTURER E. EXPRESS

NYC-WTC_000106943

NYC 9/11 Public Portal Document

20443

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Carlos JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: STUYVESANT H.S. | DATE SUBMITTED: 7-17-02 |
| DATE SAMPLED: 7-17-02. | CONTACT: HAMID SAVOJ | WORK AREA: 9th Floor. | DATE LOGGED: |
| ROTOMETER NO.: TEG-L-18 | PROJECT NO.: A477-15217 / 29881 | PROJECT MANAGER: CHRIS MC GLONN. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ MARISOL SERNA SS# PII<br>OWA ☐ ROOM # 940 | 2/2 | 1221 | 1508 | 167 | 2 | 334 | | | | < 4.9 |
| L-15 | | IWA ☐ MARIA DOCHITANGA SS# PII<br>OWA ☐ ROOM # 931 | 2/1 | 1213 | 1509 | 176 | 1.5 | 264 | | | | < 5.7 |
| L-16 | | IWA ☐ JULIA TENEZACA SS# PII<br>OWA ☐ ROOM # 1010 | 2/2 | 1214 | 1510 | 176 | 2 | 352 | | | | < 4.3 |
| L-17 | | IWA ☐ MARTHA CAIZA SS# PII<br>OWA ☐ ROOM # 911 | 2/1 | 1215 | 1511 | 176 | 1.5 | 264 | | | | < 5.7 |
| L-18 | | IWA ☐ LUIS RODRIGUEZ SS# PII<br>OWA ☐ ROOM # 926. | 2/1 | 1216 | 1512 | 176 | 1.5 | 264 | | | | < 5.7 |
| FB 1 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | < 1.5 |
| FB 2 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | < 1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos Jofat | DATE: 7-17-02 | TIME: 1650 | RECEIVED FROM TEG DROP BOX (SIGNATURE): AC 07/17 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT #

FILTER MANUFACTURER EVIDLESS

NYC 9/11 Public Portal Document


# ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306


**REPORT DATE:** 07-18-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 9th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-17-02
**DATE RECEIVED:** 07-17-02
**DATE ANALYZED:** 07-17-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20443 | Maria Ortega SS# PII | <3.0 | 3.0 |
| L-02 | 20443 | Bolivar Vicuna SS# PII | <3.2 | 3.2 |
| L-03 | 20443 | Luis Avila SS# PII | 3.2 | 3.2 |
| L-04 | 20443 | Marisol Serna SS# PII | 3.3 | 3.2 |
| L-05 | 20443 | Martha Caiza SS# PII | 5.5 | 6.0 |
| L-06 | 20443 | Luis Rodriguez SS# PII | <5.5 | 5.5 |
| L-07 | 20443 | Maria Duchitango SS# PII | 4.3 | 3.1 |
| L-08 | 20443 | Julia Tenezaca SS# PII | 9.7 | 5.9 |
| L-09 | 20443 | Martha Caiza SS# PII | <6.4 | 6.4 |
| L-10 | 20443 | Luis Rodriguez SS# PII | 12.3 | 7.1 |
| L-11 | 20443 | Maria Ortega SS# PII | 3.7 | 4.3 |
| L-12 | 20443 | Bolivar Vicuna SS# PII | <5.9 | 5.9 |
| L-13 | 20443 | Luis Sliva SS# PII | <4.3 | 4.3 |
| L-14 | 20443 | Marisol Serna SS# PII | <4.5 | 4.5 |
| L-15 | 20443 | Maria Duchitanga SS# PII | <5.7 | 5.7 |
| L-16 | 20443 | Julia Tenezaca SS# PII | <4.3 | 4.3 |
| L-17 | 20443 | Martha Caiza SS# PII | <5.7 | 5.7 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| REPORT DATE: | 07-22-02 |
| CLIENT: | Taylor Environmental Group, Inc. |
| PROJECT NAME: | SCA/Stuyvesant HS<br>350 Chambers Street<br>7th, 8th, 10th Floors |
| PROJECT NUMBER: | M477-15217-29881 |
| SAMPLED BY: | Client |
| SAMPLE DATE | 07-19-02 |
| DATE RECEIVED: | 07-20-02 |
| DATE ANALYZED: | 07-20-02 |
| SAMPLE MEDIA: | Air Samples |
| ANALYSIS REQUIRED: | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20513 | R.Cales SS# PII / Room 817 | <4.2 | 4.2 |
| 02 | 20513 | J.Velez SS# PII / Room 803 | <4.2 | 4.2 |
| 03 | 20513 | E.Sarmiento SS# PII / Room 903A | <4.2 | 4.2 |
| 04 | 20513 | V.Fajardo SS# PII Room 1017A | <4.2 | 4.2 |
| 05 | 20513 | C.Chalen SS# PII / Room 701 | <4.2 | 4.2 |
| 06 | 20513 | R.Angulo SS# PII / Room 703 Left | <4.2 | 4.2 |
| 07 | 20513 | L.Parra SS# PII / Room 703 Middle | <4.2 | 4.2 |
| 08 | 20513 | F.Contos SS# PII / Room 703 Right | <4.2 | 4.2 |
| 09 | 20513 | L.Acosto SS# PII / Room 707 | <4.2 | 4.2 |
| 10 | 20513 | J.Calle SS# PII / Room 709 | <4.2 | 4.2 |
| 11 | 20513 | F.Ordonez SS# PII / Room 705 | <4.2 | 4.2 |
| 12 | 20513 | J.Sanchez SS# PII / Room 715 | <4.2 | 4.2 |
| 13 | 20513 | R.Cales SS# PII / Room 817 | <3.1 | 3.1 |
| 14 | 20513 | J.Velez SS# PII / Room 803 | <3.1 | 3.1 |
| 15 | 20513 | E.Sarmiento SS# PII / Room 903A | <3.1 | 3.1 |
| 16 | 20513 | C.Chalen SS# PII / Room 701 | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

[redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 4

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plonsky | CLIENT: SCA | SITE ADDRESS: Chambers St NYC Stuyvesant HS | DATE SUBMITTED: 7.19-02 |
| DATE SAMPLED: 7.17.02 | CONTACT: Hamid Savot | WORK AREA: 8th fl | DATE LOGGED: |
| ROTOMETER NO.: L-18 | PROJECT NO: K-477-15217 | PROJECT MANAGER: Jh. McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L01 | | IWA ☐ OWA ☐ Fabian Ordoner rm 839 PII | 2/2 | 1736 | 1934 | 118 | 2 | 236 | | | | |
| L02 | | IWA ☐ OWA ☐ Naranjo Raul rm 837 PII | 2/2 | 1624 | 1935 | 191 | 2 | 382 | | | | |
| L-03 | | IWA ☐ OWA ☐ Velez Jose rm 829 PII | 2/2 | 1626 | 1940 | 194 | 2 | 388 | | | | |
| L-04 | | IWA ☐ OWA ☐ Richard Avila rm 833 PII | 2/2 | 1635 | 1942 | 187 | 2 | 374 | | | | |
| L05 | | IWA ☐ OWA ☐ Nube Gallegos rm 835 PII | 2/2 | 1640 | 1943 | 183 | 2 | 366 | | | | |
| L06 | | IWA ☐ OWA ☐ Lucyna Foremska rm 840 PII | 2/2 | 1802 | 1944 | 102 | 2 | 204 | | | | |
| L07 | | IWA ☐ OWA ☐ Parra Lady rm 838 PII | 2/2 | 2034 | 2336 | 182 | 2 | 364 | | | | |
| L-08 | | IWA ☐ OWA ☐ Fabian Ordonez rm 839 PII | 2/2 | 2035 | 2337 | 182 | 2 | 364 | | | | |
| L-09 | | IWA ☐ OWA ☐ Naranjo Raul rm 837 PII | 2/2 | 2038 | 2338 | 200 | 2 | 400 | | | | |
| L10 | | IWA ☐ OWA ☐ Velez Jose rm 829 PII | 2/2 | 2022 | 2340 | 198 | 2 | 396 | | | | |
| L11 | | IWA ☐ OWA ☐ Richard Avila rm 833 PII | 2/2 | 2024 | 2341 | 197 | 2 | 394 | | | | |
| L12 | | IWA ☐ OWA ☐ Nube Gallegos rm 835 PII | 2/2 | 2026 | 2342 | 196 | 2 | 392 | | | | |
| L13 | | IWA ☐ OWA ☐ Lucyna Foremska rm 840 PII | 2/2 | 2028 | 2343 | 195 | 2 | 390 | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): W. Plo | DATE: 7.18.02 | TIME: 0030 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE): Im Ar | DATE: 7/19/2 | TIME: 9am |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106947

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 2 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plomb | CLIENT: SCA | SITE ADDRESS: Chambers St Stuyvesant St | DATE SUBMITTED: 7.18.02 |
| DATE SAMPLED: 7.17.02 | CONTACT: Hamid Sanei | WDPX AREA: 8th fl | DATE LOGGED: 20462 |
| ROTOMETER NO: L18 | PROJECT NO: K-477-1517 | PROJECT MANAGER: Ch McElyea | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L14 | | IWA ☐ OWA ☐ field blank | | | | | | | | | | |
| L15 | | IWA ☐ OWA ☐ field blank | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): W Pl | DATE: 7.18.02 | TIME: 8030 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE): J. Cruz | DATE: 7/18/2 | TIME: 9am |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106948

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-18-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 8th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-17-02
**DATE RECEIVED:** 07-18-02
**DATE ANALYZED:** 07-18-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20462 | Fabion Ordonez SS# PII | <6.4 | 6.4 |
| 02 | 20462 | Naronjo Raul SS# PII | <3.9 | 3.9 |
| 03 | 20462 | Velez Jose SS# PII | <3.9 | 3.9 |
| 04 | 20462 | Richard Avila SS# PII | <4.0 | 4.0 |
| 05 | 20462 | Nube Gallegos SS# PII | <4.1 | 4.1 |
| 06 | 20462 | Lucyna Foremska SS# PII | <7.4 | 7.4 |
| 07 | 20462 | Parra Lady SS# PII | <4.1 | 4.1 |
| 08 | 20462 | Fabion Ordonez SS# PII | <4.1 | 4.1 |
| 09 | 20462 | Naronjo Raul SS# PII | <3.8 | 3.8 |
| 10 | 20462 | Velez Jose SS# PII | <3.8 | 3.8 |
| 11 | 20462 | Richard Avila SS# PII | <3.8 | 3.8 |
| 12 | 20462 | Nube Gallegos SS# PII | <3.8 | 3.8 |
| 13 | 20462 | Lucyna Foremska SS# PII | <3.8 | 3.8 |
| 14 | 20462 | Field Blank | <1.5 µg | 1.5 µg |
| 15 | 20462 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

[redacted] [redacted]LOI[redacted]VI[redacted]MENTAL [redacted]GROUP[redacted] DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFFT | CLIENT: NYC SCA. | SITE ADDRESS: Stuyvesant HS. 20467 | DATE SUBMITTED: 7-18-02 |
| DATE SAMPLED: 7-18-02. | CONTACT: HAMID SAUD J. | WORK AREA: 8th Floor. | DATE LOGGED: |
| ROTOMETER NO: TEG - L 18 | PROJECT NO: 11477 - 15217 / 29881 | PROJECT MANAGER: CHRIS Mc ELGUN. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ MARTHA CAIZA SS# PII OWA ☐ ROOM # 839. | 2/2 | 0708 | 1125 | 257 | 2 | 514 | | | | 2.0 |
| L-02 | | IWA ☐ JAVIER SOLIS SS# PII OWA ☐ ROOM # 837. | 2/2 | 0709 | 1126 | 257 | 2 | 514 | | | | 2.0 |
| L-03 | | IWA ☐ ANA ALVAREZ # PII OWA ☐ ROOM # 835 | 2/2 | 0710 | 0855 | 105 | 2 | 210 | | | | 4.1 |
| L-04 | | IWA ☐ LUIS TACURI SS# PII OWA ☐ ROOM # 833 | 2/2 | 0711 | 1127 | 256 | 2 | 512 | | | | 2.0 |
| L-05 | | IWA ☐ MARIA ORTEGA SS# PII OWA ☐ ROOM # 836 | 2/2 | 0712 | 1128 | 256 | 2 | 512 | | | | 2.0 |
| L-06 | | IWA ☐ MARCELO ATIENCIA # PII OWA ☐ ROOM # 838 | 2/2 | 0713 | 1129 | 256 | 2 | 512 | | | | 2.0 |
| L-07 | | IWA ☐ ANGEL ASIMAL SS# PII OWA ☐ ROOM # 840 | 2/2 | 0714 | 1130 | 256 | 2 | 512 | | | | 2.0 |
| L-08 | | IWA ☐ ANA ALVAREZ SS# PII OWA ☐ ROOM # 829. | 2/2 | 0855 | 1131 | 156 | 2 | 312 | | | | 5.0 |
| L-09 | | IWA ☐ MARIN ORTEGA SS# PII OWA ☐ ROOM # 836 | 2/2 | 1201 | 1510 | 179 | 2 | 358 | | | | 4.5 |
| L-10 | | IWA ☐ MARCELO ATIENCIA # PII OWA ☐ ROOM # 836 | 2/2 | 1202 | 1511 | 179 | 2 | 358 | | | | 4.2 |
| L-11 | | IWA ☐ ANGEL ASIMAL SS# PII OWA ☐ ROOM # 840 | 2/1 | 1204 | 1400 | 176 | 1.5 | 264 | | | | 10.7 |
| L-12 | | IWA ☐ ANA ALVAREZ SS# PII OWA ☐ ROOM # 827. | 2/2 | 1206 | 1512 | 186 | 2 | 372 | | | | 5.3 |
| L-13 | | IWA ☐ MARTHA CAIZA SS# PII OWA ☐ ROOM # 804. | 2/1 | 1208 | 1513 | 185 | 1.5 | 278 | | | | 5.4 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos | DATE: 7-18-02 | TIME: 1624 | RECEIVED FROM TEG DROP BOX (SIGNATURE): 07/18 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH Method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT #: FILTER MANUFACTURER: E & Pecss

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-19-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 8th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-18-02
**DATE RECEIVED:** 07-18-02
**DATE ANALYZED:** 07-18-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20467 | Martha Caiza SS# PII | <2.9 | 2.9 |
| L-02 | 20467 | Javier Solis SS# PII | <2.9 | 2.9 |
| L-03 | 20467 | Ana Alvarez SS# PII | <7.0 | 7.0 |
| L-04 | 20467 | Luis Tacury SS# PII | <2.9 | 2.9 |
| L-05 | 20467 | Maria Ortega SS# PII | <2.9 | 2.9 |
| L-06 | 20467 | Marcelo Atiencia SS# PII | <2.9 | 2.9 |
| L-07 | 20467 | Angel Asmal SS# PII | <2.9 | 2.9 |
| L-08 | 20467 | Ana Alvarez SS# PII | <5.0 | 5.0 |
| L-09 | 20467 | Maria Ortega SS# PII | 4.5 | 4.2 |
| L-10 | 20467 | Marcelo Atiencia SS# PII | <4.2 | 4.2 |
| L-11 | 20467 | Angel Asmal SS# PII | 10.7 | 5.7 |
| L-12 | 20467 | Ana Alvarez SS# PII | 5.3 | 4.0 |
| L-13 | 20467 | Martha Caiza SS# PII | <5.4 | 5.4 |
| L-14 | 20467 | Luis Cuzco SS# PII | 12.0 | 6.3 |
| L-15 | 20467 | Field Blank | <1.5 µg | 1.5 µg |
| L-16 | 20467 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-19-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>350 Chambers St., 8th Floor |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-18-02 |
| **DATE RECEIVED:** | 07-19-02 |
| **DATE ANALYZED:** | 07-19-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20485 | Stanislaw Buslowski SS# PII | <4.1 | 4.1 |
| L-02 | 20485 | Gil Calle SS# PII | <3.8 | 3.8 |
| L-03 | 20485 | Foremsha Lucyna SS# PII | <4.0 | 4.0 |
| L-04 | 20485 | Ordonez Fabien SS# PII | <4.1 | 4.1 |
| L-05 | 20485 | Luis Rodriguez SS# PII | <4.1 | 4.1 |
| L-06 | 20485 | Calle Romulo SS# PII | <4.2 | 4.2 |
| L-07 | 20485 | Stanislaw Buslowski PII | <3.6 | 3.6 |
| L-08 | 20485 | Gil Calle SS PII | <3.6 | 3.6 |
| L-09 | 20485 | Foremsha Lucyna SS# PII | <3.8 | 3.8 |
| L-10 | 20485 | Ordonez Fabien SS# PII | <3.8 | 3.8 |
| L-11 | 20485 | Luis Rodriguez SS# PII | <3.8 | 3.8 |
| L-12 | 20485 | Romulo Guizhpi SS# PII | <3.8 | 3.8 |
| L-13 | 20485 | Calle Romulo SS# PII | <3.8 | 3.8 |
| L-14 | 20485 | Avila Henry SS# PII | <6.0 | 6.0 |
| L-15 | 20485 | Walter Gallego SS# PII | <1.5 µg | 1.5 µg |
| L-16 | 20485 | Field Blank | <1.5 µg | 1.5 µg |
| L-17 | 20485 | Field Blank | | |

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 2

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCH. | STUYVESANT H.S. | 7-19-02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-19-02 | HAROLD SAUDT | 8th Floor. + 10TH FL 2050 | |
| **ROTOMETER NO.** | **PROJECT NO** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG L-18 | H477-15217 / 29881 | CHRIS McELROY. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ ANA ALVAREZ SS# PII<br>OWA ☐ ROOM # 826. | 2/2 | 0710 | 1120 | 250 | 2 | 500 | | | | 14 |
| L-02 | | IWA ☐ MARISOL SERNA SS# PII<br>OWA ☐ ROOM # 809. | 2/2 | 0711 | 1121 | 250 | 2 | 500 | | | | 10.4 |
| L-03 | | IWA ☐ MARTHA CAIZA SS# PII<br>OWA ☐ ROOM # 807. | 2/2 | 0712 | 1123 | 251 | 2 | 502 | | | | <3.0 |
| L-04 | | IWA ☐ JULIA TENEZACA SS# PII<br>OWA ☐ ROOM # 803. → South East UNIT | 2/2 | 0713 | 1130 | 257 | 2 | 514 | | | | <2.9 |
| L-05 | | IWA ☐ CARLOS ALI SS# PII<br>OWA ☐ ROOM # 803 South. UNIT. | 2/2 | 0714 | 1122 | 258 | 2 | 516 | | | | 4.4 |
| L-06 | | IWA ☐ ALEX BERNAL SS# PII<br>OWA ☐ ROOM # 801 | 2/2 | 0715 | 1134 | 269 | 2 | 538 | | | | <2.8 |
| L-07 | | IWA ☐ PABLO URRILES SS# PII<br>OWA ☐ ROOM # 811 | 2/1 | 0716 | 1135 | 269 | 1.5 | 404 | | | | <3.7 |
| L-08 | | IWA ☐ KLEVER CALLE SS# PII<br>OWA ☐ ROOM # 1017 A. | 2/2 | 0717 | 1119 | 242 | 2 | 484 | | | | <3.1 |
| L-09 | | IWA ☐ ANA ALVAREZ SS# PII<br>OWA ☐ ROOM # 826 | 2/2 | 1203 | 1515 | 192 | 2 | 384 | | | | <3.9 |
| L-10 | | IWA ☐ MARISOL SERNA SS# PII<br>OWA ☐ ROOM # 809. | 2/2 | 1204 | 1516 | 192 | 2 | 384 | | | | <3.9 |
| L-11 | | IWA ☐ MARTHA CAIZA SS# PII<br>OWA ☐ ROOM # 807 | 2/2 | 1205 | 1517 | 192 | 2 | 384 | | | | <3.9 |
| L-12 | | IWA ☐ JULIA TENEZACA SS# PII<br>OWA ☐ ROOM # 803 | 2/1 | 1206 | 1518 | 192 | 1.5 | 288 | | | | <5.2 |
| L-13 | | IWA ☐ CARLOS ALI SS# PII<br>OWA ☐ ROOM # 803 | 2/1 | 1207 | 1519 | 192 | 1.5 | 288 | | | | <5.2 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | 7/19/02 | 6pm | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| Carlos Jofat | 7-19-02 | 1544 | | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | 12 Hour Turn around Fax 312-[illegible] | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site [illegible]

NYC-WTC_000106956

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H.S. | 7-19-02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7-19-02. | HAMID SAVOJ | 8th FLOOR + 10TH 20505 | |
| ROTOVETER NO | PROJECT NO | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG. L-18 | M477-15217/29881 | CHRIS MC ELGUN. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ ALEX Bernal SS# PII<br>OWA ☐ ROOM # 801 | 2 / 2 | 1208 | 1520 | 192 | 2 | 384 | | | | < 3.9 |
| L-15 | | IWA ☐ Pablo Ubeiles SS# PII<br>OWA ☐ ROOM 811 | 2 / 2 | 1209 | 1521 | 192 | 2 | 384 | | | | 8.4 |
| L-16 | | IWA ☐ CLEVER CALLE SS# PII<br>OWA ☐ ROOM # 1017 A | 2 / 1 | 1210 | 1522 | 192 | 1.5 | 288 | | | | 5.4 |
| FB1 ~~L-13~~ | | IWA ☐<br>OWA ☐ FIELD BLANK | / | — | — | — | — | — | | | | < 1.5 |
| FB2 | | IWA ☐<br>OWA ☐ FIELD BLANK | / | — | — | — | — | — | | | | < 1.5 |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | / | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | A Cin 07/19 | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| Carlos Jofat | 7-19-02 | 1544 | | | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER Lead

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-22-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
350 Chambers Street
8th Floor

**PROJECT NUMBER:** M477-15217-29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-19-02
**DATE RECEIVED:** 07-19-02
**DATE ANALYZED:** 07-19-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20505 | Room #826 / A.Alvarez SS# PII | 10.4 | 3.0 |
| L-02 | 20505 | Room #809 / M.Serna SS# PII | <3.0 | 3.0 |
| L-03 | 20505 | Room #807 / M.Caiza SS# PII | <3.0 | 3.0 |
| L-04 | 20505 | Room #803, SE Unit / J.Tenezaca SS# PII | <2.9 | 2.9 |
| L-05 | 20505 | Room #803, S Unit / C.Ali SS# PII | 4.4 | 2.9 |
| L-06 | 20505 | Room #801 / A.Bernal SS# PII | <2.8 | 2.8 |
| L-07 | 20505 | Room #811 / P.Wreiles SS# PII | <3.7 | 3.7 |
| L-08 | 20505 | Room #1017A / K.Calle SS# PII | <3.1 | 3.1 |
| L-09 | 20505 | Room #826 / A.Alvarez SS# PII | <3.9 | 3.9 |
| L-10 | 20505 | Room #809 / M.Serna SS# PII | <3.9 | 3.9 |
| L-11 | 20505 | Room #807 / M.Caiza SS# PII | <3.9 | 3.9 |
| L-12 | 20505 | Room #803, SE Unit / J.Tenezaca SS# PII | <5.2 | 5.2 |
| L-13 | 20505 | Room #803, S Unit / C.Ali SS# PII | <5.2 | 5.2 |
| L-14 | 20505 | Room #801 / A.Bernal SS# PII | <3.9 | 3.9 |
| L-15 | 20505 | Room #811 / P.Wreiles SS# PII | 6.4 | 3.9 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| L-16 | 20505 | Room #1017A / K.Calle SS# PII | 5.4 | 5.2 |
| FB-1 | 20505 | Field Blank | <1.5 µg | 1.5 µg |
| FB-2 | 20505 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m$^3$ and a permissible exposure level (PEL) of 50 µg/m$^3$ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

X0515

PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 7/20/02 |
| DATE ISSUED: 7/19/02 | CONTACT: Hamid Saadat | WORK AREA: 7th 8th, + 10th | DATE LOGGED: |
| ROTOMETER NO: L-16 | PROJECT NO: A477-152.17 / 29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ [redacted] PII<br>OWA ☐ Cales Rm 817 | 2.0 / 2.0 | 1600 | 1800 | 180 | 2.0 | 360 | | | | 44.2 |
| 02 | | IWA ☐ Jose PII<br>OWA ☐ Velez Rm 803 | 2.0 / 2.0 | 1602 | 1902 | 180 | 2.0 | 360 | | | | 44.2 |
| 03 | | IWA ☐ Edwin PII<br>OWA ☐ Sarmiento Rm 903A | 2.0 / 2.0 | 1604 | 1939 | 180 | 2.0 | 360 | | | | 44.2 |
| 04 | | IWA ☐ Victor Fuentes<br>OWA ☐ PII Rm 1017A | 2.0 / 2.0 | 1606 | 1906 | 180 | 2.0 | 360 | | | | 44.2 |
| 05 | | IWA ☐ Cesar Chalen<br>OWA ☐ PII Rm 701 | 2.0 / 2.0 | 1630 | 1930 | 180 | 2.0 | 360 | | | | 44.2 |
| 06 | | IWA ☐ Rossing Angulo<br>OWA ☐ PII Rm 703 Left | 2.0 / 2.0 | 1632 | 1932 | 180 | 2.0 | 360 | | | | 44.2 |
| 07 | | IWA ☐ Lady Parra<br>OWA ☐ PII 703 middle | 2.0 / 2.0 | 1634 | 1934 | 180 | 2.0 | 360 | | | | 44.2 |
| 08 | | IWA ☐ Fausto Contos<br>OWA ☐ PII 703 right | 2.0 / 2.0 | 1636 | 1936 | 180 | 2.0 | 360 | | | | 44.2 |
| 09 | | IWA ☐ Luis Acosta<br>OWA ☐ PII Rm 707 | 2.0 / 2.0 | 1638 | 1938 | 180 | 2.0 | 360 | | | | 44.2 |
| 10 | | IWA ☐ Jesse Calle<br>OWA ☐ PII Rm 709 | 2.0 / 2.0 | 1640 | 1940 | 180 | 2.0 | 360 | | | | 44.2 |
| 11 | | IWA ☐ Fabian Ordonez<br>OWA ☐ PII Rm 705 | 2.0 / 2.0 | 1645 | 1945 | 180 | 2.0 | 360 | | | | 44.2 |
| 12 | | IWA ☐ Juan Sanchez<br>OWA ☐ PII Rm 715 | 2.0 / 2.0 | 1647 | 1947 | 180 | 20 | 360 | | | | 44.2 |
| 13 | | IWA ☐ Ribelarta Cales<br>OWA ☐ PII Rm 817 | 2.0 / 2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | 43.1 |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | | | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY: (SIGNATURE) | 7/20/02 | 0100 | RECEIVED BY (SIGNATURE): R. Arandina | 7.20 | |
| ANALYST (SIGNATURE) | | | COMMENTS: 12 Hour TAT | | |

ORDER: PCM TEM; BGRD PRE DURING POST; OSHA; OTHER Dish method 7082

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106960

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant HS | DATE SUBMITTED: 7/20/02 |
| DATE SHIPPED: 7/19/02 | CONTACT: Hall & Savot | WORK AREA: 7th 8th Floor | DATE LOGGED: |
| ROTOMETER NO: L-16 | PROJECT NO.: m477-1527/2988 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☐ Jose Velez PII Rm 803 | 2.0 / 2.0 | 2002 | 0002 | 240 | 2.0 | 480 | | | | <3.1 |
| 15 | | IWA ☐ OWA ☐ Edwin Sarmiento PII Rm 903A | 2.0 / 2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | <3.1 |
| 16 | | IWA ☐ OWA ☐ cesar chaiven PII rm 701 | 2.0 / 2.0 | 2006 | 0006 | 240 | 2.0 | 480 | | | | <3.1 |
| 17 | | IWA ☐ OWA ☐ Rossing Angulo PII Rm 703 Left | 2.0 / 2.0 | 2008 | 0008 | 240 | 2.0 | 480 | | | | <3.1 |
| 18 | | IWA ☐ OWA ☐ Lady Parra PII 703 middle | 2.0 / 2.0 | 2010 | 0010 | 240 | 2.0 | 480 | | | | <3.1 |
| 19 | | IWA ☐ OWA ☐ Fausto Contos PII 703 right | 2.0 / 2.0 | 2012 | 0012 | 240 | 2.0 | 480 | | | | <3.1 |
| 20 | | IWA ☐ OWA ☐ Luis Acosto PII rm 707 | 2.0 / 2.0 | 2014 | 0014 | 240 | 2.0 | 480 | | | | <3.1 |
| 21 | | IWA ☐ OWA ☐ Juste Cylle PII rm 709 | 2.0 / 2.0 | 2016 | 0016 | 240 | 2.0 | 480 | | | | <3.1 |
| 22 | | IWA ☐ OWA ☐ Fabian ordonez PII rm 705 | 2.0 / 2.0 | 2018 | 0018 | 240 | 2.0 | 480 | | | | <3.1 |
| 23 | | IWA ☐ OWA ☐ Juan Sanchez PII rm 715 | 2.0 / 2.0 | 2020 | 0020 | 240 | 2.0 | 480 | | | | <3.1 |
| 24 | | IWA ☐ OWA ☐ Stanislaw Buslowski PII rm 701A | 2.0 / 2.0 | 2022 | 0022 | 240 | 2.0 | 480 | | | | <3.1 |
| 25 | | IWA ☐ OWA ☐ Lugyna Foremka PII rm 717 | 2.0 / 2.0 | 2024 | 0024 | 240 | 2.0 | 480 | | | | <3.1 |
| FB-26 | | IWA ☐ OWA ☐ FB-26 | / | | | | | | | | | <1.5 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | DATE 7/20 | TIME 0100 | RECEIVED BY: (SIGNATURE) R. Arrudima | DATE 7.20 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 Hour TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH Method 7082

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106961

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| Gerry McKenzie | NYC SCA | Stuyvesant H.S. | 7/20 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7/19/02 | Hamid Sawat | 7th & 8th Floor | |
| **ROTAMETER NO** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| L-16 | M477-15217/29881 | Chris McElgun | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| FB27 | | IWA ☐ OWA ☐ FB-27 | ✓ | | | | | | | | | 41.5 |
| FB-28 | | IWA ☐ OWA ☐ FB-28 | ✓ | | | | | | | | | 41.5 |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ✓ | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY (SIGNATURE)** | **DATE** | **TIME** |
| [signature] | 7/20 | 0100 | R. DiCicilia | 7.20 | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | 2 HOUR TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER Niosh method 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H.S. | 7-20-02. |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-20-02. | HAMID SAVOJ. | 7th Floor. | |
| **ROTOMETER NO** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG-L 18 | #477-15217 / 29881 | CHRIS MC ELROY. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ MARIA DUCHITANGA SS# PII<br>OWA ☐ ROOM # 703 Northeast UNIT | 2/2 | 0710 | 1121 | 251 | 2 | 502 | | | | <2.0 |
| L-02 | | IWA ☐ MARIA ORTEGA SS# PII<br>OWA ☐ ROOM # 703 Southeast. | 2/2 | 0711 | 1130 | 259 | 2 | 518 | | | | <2.9 |
| L-03 | | IWA ☐ JULIA. TENEZACA SS# PII<br>OWA ☐ ROOM # 703 → South west | 2/2 | 0712 | 1123 | 251 | 2 | 502 | | | | <3.0 |
| L-04 | | IWA ☐ LUIS TACURI SS# PII<br>OWA ☐ ROOM # 705 | 2/2 | 0713 | 1129 | 256 | 2 | 512 | | | | <2.9 |
| L-05 | | IWA ☐ MIGUEL ALI SS# PII<br>OWA ☐ ROOM # 707. | 2/2 | 0714 | 1119 | 245 | 2 | 490 | | | | <3.1 |
| L-06 | | IWA ☐ WILSON OLIVO SS# PII<br>OWA ☐ ROOM # 709. | 2/2 | 0715 | 1120 | 245 | 2 | 490 | | | | <3.1 |
| L-07 | | IWA ☐ JULIO BASTIDAS SS# PII<br>OWA ☐ ROOM # 715 | 2/2 | 0716 | 1128 | 252 | 2 | 504 | | | | <3.0 |
| L-08 | | IWA ☐ LUIS CUZCO SS# PII<br>OWA ☐ ROOM # 717 | 2/2 | 0717 | 1124. | 247 | 2 | 494 | | | | <3.1 |
| L-09 | | IWA ☐ BEATRIZ CHAVEZ. SS# PII<br>OWA ☐ ROOM # 727 | 2/2 | 0718. | 1126 | 248 | 2 | 496. | | | | <3.1 |
| L-10 | | IWA ☐ MARIA DUCHITANGA SS# PII<br>OWA ☐ ROOM # 703 Northeast Unit | 2/1 | 1205 | 1510 | 185 | 1.5 | 278 | | | | <5.4 |
| L-11 | | IWA ☐ HANNA ORTEGA SS# PII<br>OWA ☐ ROOM # 703 Southeast | 2/2 | 1206 | 1511 | 185 | 2 | 370 | | | | <4.1 |
| L-12 | | IWA ☐ JULIA TENEZACA SS# PII<br>OWA ☐ ROOM # 703 → Southwest | 2/1 | 1207 | 1515 | 188 | 1.5 | 282 | | | | <5.4 |
| L-13 | | IWA ☐ LUIS TACURI SS# PII<br>OWA ☐ ROOM # 705 | 2/1 | 1208 | 1514 | 186 | 1.5 | 279 | | | | <5.4 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | 4:30PM | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| Carlos A. Jofat | 7-20-02 | | R. Drouina | 7.20.02 | 16.30 |
| **ANALYST (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT #

FILTER MANUFACTURER E. EXPRESS

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H.S. | 7-20-02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7-20-02 | HAMID SAVOJ | 7th Floor. | |
| ROTOMETER NO | PROJECT NO | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG L-18. | M477-15217 / 29851 | CHRIS McELGUN. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ MIGUEL ALI SSA# PII<br>OWA ☐ ROOM #707. | 2/2 | 1209 | 1513 | 184 | 2 | 368 | | | | <4.1 |
| L-15 | | IWA ☐ WILSON OLIVO SS# PII<br>OWA ☐ ROOM # 709. | 2/2 | 1210 | 1500 | 170 | 2 | 340 | | | | <4.4 |
| L-16 | | IWA ☐ JULIO BASTIDAS SS# PII<br>OWA ☐ ROOM # 715 | 2/2 | 1211 | 1517 | 186 | 2 | 372 | | | | <4.1<br>3.7 |
| L-17 | | IWA ☐ LUIS CRUZCO SS# PII<br>OWA ☐ ROOM # 717 | 2/1 | 1212 | 1516 | 184 | 1.5 | 276 | | | | <5.4 |
| L-18 | | IWA ☐ BEATRIZ CHAVEZ SS# PII<br>OWA ☐ ROOM # 727. | 2/2 | 1213 | 1518 | 185 | 2 | 370 | | | | <4.1 |
| FB1 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | <1.5 |
| FB2 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | | | |
| RELINQUISHED BY: (SIGNATURE) Carlos Jofat | DATE 7-20-02 | TIME | RECEIVED BY: (SIGNATURE) R. Dracidina | DATE 7.20.02 | TIME 16.30 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER LEAD

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF _____

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERRY MICHALCZUK | NYC SCIA | STUYVESANT HS. 345 CHAMBERS ST. NY. | 07.20.02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-20.02 | HAMID SAVOJ | 7th FLOOR | |
| **ROTOMETER NO** | **PROJECT NO** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG-L16 | #477-15217 /29881 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | f/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ FELIX CALLE SS# PII<br>OWA ☐ ROOM # 726 | 2/2 | 16.00 | 19.00 | 180 | 2 | 360 | | | | <4.2 |
| L-02 | | IWA ☐ PAUL LOJA SS# PII<br>OWA ☐ ROOM # 731 | 2/2 | 16.01 | 19.01 | 180 | 2 | 360 | | | | <4.2 |
| L-03 | | IWA ☐ JOSE CONPOVENDO SS# PII<br>OWA ☐ ROOM # 736 | 2/2 | 16.02 | 19.02 | 180 | 2 | 360 | | | | <4.2 |
| L-04 | | IWA ☐ JOSE RIBOMERTO CANTOS<br>OWA ☐ SS # PII ROOM - 735 | 2/2 | 16.03 | 19.03 | 180 | 2 | 360 | | | | <4.2 |
| L-05 | | IWA ☐ EDWIN SARMIENTO SS# PII<br>OWA ☐ ROOM 737 | 2/2 | 16.04 | 19.04 | 180 | 2 | 360 | | | | <4.2 |
| L-06 | | IWA ☐ MAURICIO AVILA SS PII<br>OWA ☐ ROOM # 739 | 2/2 | 16.05 | 19.05 | 180 | 2 | 360 | | | | <4.2 |
| L-07 | | IWA ☐ LUCYNA PORGINSKA SS# PII<br>OWA ☐ ROOM # 738 | 2/2 | 16.06 | 19.06 | 180 | 2 | 360 | | | | <4.2 |
| L-08 | | IWA ☐ JUAN SANCHEZ SS# PII<br>OWA ☐ ROOM 740 | 2/2 | 16.07 | 19.07 | 180 | 2 | 360 | | | | <4.2 |
| L-09 | | IWA ☐ ROMULO CALLI SS # PII<br>OWA ☐ ROOM 729 | 2/2 | 16.09 | 19.02 | 180 | 2 | 360 | | | | <4.2 |
| L-10 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 f/cc |
| L-11 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 f/cc |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| TERRY | 7.20.02 | 19.30 | at BTL | 7/21/02 | |
| **ANALYST (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| at BTL | 7/21/02 | 7:50 | FAX FOR THE SCHOOL # 212 406 - 2535 (12 HOURS TURNAROUND) | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD

LOT # E. EXPRESS FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

SIGNATURE

THANKS

NYC-WTC_000106965

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-22-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
350 Chambers Street
7th Floor

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE 07-20-02
DATE RECEIVED: 07-21-02
DATE ANALYZED: 07-21-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20520 | F.Calle SS# PII / Room #726 | <4.2 | 4.2 |
| L-02 | 20520 | P.Loja SS# PII / Room #731 | <4.2 | 4.2 |
| L-03 | 20520 | J.Compovende SS# PII / Room #736 | <4.2 | 4.2 |
| L-04 | 20520 | J.Cantos SS# PII / Room #735 | <4.2 | 4.2 |
| L-05 | 20520 | E.Sarmiento SS# PII / Room #737 | <4.2 | 4.2 |
| L-06 | 20520 | M.Avila SS# PII / Room #739 | <4.2 | 4.2 |
| L-07 | 20520 | L.Foremska SS# PII / Room #738 | <4.2 | 4.2 |
| L-08 | 20520 | J.Sanchez SS# PII / Room #740 | <4.2 | 4.2 |
| L-09 | 20520 | R.Calli SS# PII / Room #729 | <4.2 | 4.2 |
| L-10 | 20520 | Field Blank | <1.5 µg | 1.5 µg |
| L-11 | 20520 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC-WTC_000106966

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H.S. | 7-21-02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-21-02. | HAMID SHUOJ. | 7TH FLOOR | |
| **ROTOMETER NO** | **PROJECT NO** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG-L 18. | M477-15217 / 29881 | CHRIS McELGUN. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/cc (mg/m³) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ ANA ALVAREZ. SS# PII<br>OWA ☐ ROOM # 701 | 2/2 | 0708 | 1120 | 252 | 2 | 504 | | | | 23.0 |
| L-02 | | IWA ☐ SEGUNDO LEON SS# PII<br>OWA ☐ ROOM # 705 | 2/1 | 0709 | 1121 | 252 | 1.5 | 378 | | | | 24.0 |
| L-03 | | IWA ☐ MIGUEL ALI SS# PII<br>OWA ☐ ROOM # 707 | 2/2 | 0710 | 1122 | 252 | 2 | 504 | | | | 23.0 |
| L-04 | | IWA ☐ ANGEL NARANJO SS# PII<br>OWA ☐ ROOM # 709 | 2/2 | 0711 | 1123 | 252 | 2 | 504 | | | | 23.0 |
| L-05 | | IWA ☐ JOSE PEREZ SS# PII<br>OWA ☐ ROOM # 715 | 2/2 | 0712 | 1124 | 252 | 2 | 504 | | | | 23.0 |
| L-06 | | IWA ☐ MARCELO ARIENZA SS# PII<br>OWA ☐ ROOM # 717 | 2/1 | 0713 | 1125 | 252 | 1.5 | 378 | | | | 24.0 |
| L-07 | | IWA ☐ ELEVEN CALLE. SS# PII<br>OWA ☐ ROOM # 727 | 2/1 | 0714 | 1126 | 252 | 1.5 | 378 | | | | 24.0 |
| L-08 | | IWA ☐ MARTHA CAIZA. SS# PII<br>OWA ☐ ROOM # 729. | 2/2 | 0715 | 1127 | 252 | 2 | 504 | | | | 23.0 |
| L-09 | | IWA ☐ CIL CALLE SS# PII<br>OWA ☐ ROOM # 704 | 2/2 | 0830 | 1128 | 178 | 2 | 356 | | | | 24.2 |
| L-10 | | IWA ☐ ANA ALVAREZ SS# PII<br>OWA ☐ ROOM # 726 | 2/2 | 1200 | 1515 | 195 | 2 | 390 | | | | 23.8 |
| L-11 | | IWA ☐ SEGUNDO LEON SS# PII<br>OWA ☐ ROOM # 715 | 2/2 | 1201 | 1516 | 195 | 2 | 390 | | | | 23.8 |
| L-12 | | IWA ☐ MIGUE ALI SS# PII<br>OWA ☐ ROOM # 702. | 2/2 | 1202 | 1517 | 195 | 2 | 390 | | | | 23.8 |
| L-13 | | IWA ☐ ANGEL NARANJO SS# PII<br>OWA ☐ ROOM # 738 | 2/1 | 1203 | 1518 | 195 | 1.5 | 293 | | | | 25.1 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Carlos Jofat | 7-21-02 | 1615 | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| | | | R. Dandilla | 7.21.02 | 16.15 |
| **ANALYST (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT # FILTER MANUFACTURER E. EXPRESS

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JORAT | NYC SCA. | STUYVESANT | 7-21-02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7-21-02. | HAMID SAVOJ. | 7TH FLOOR. | |
| **ROTOMETER NO** | **PROJECT NO** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG L-18 | A477-15217 / 29881 | CHRIS MC ELROY. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ JOSE PEREZ SS# PII<br>OWA ☐ ROOM # 736 | 2/2 | 1201 | 1519 | 195 | 2 | 390 | | | | 43.8 |
| L-15 | | IWA ☐ MARCELO ATIENCIA SS# PII<br>OWA ☐ ROOM# 717 | 2/2 | 1205 | 1520 | 195 | 2 | 390 | | | | 43.8 |
| L-16 | | IWA ☐ FLOYER CALLE SS# PII<br>OWA ☐ ROOM# 727 | 2/1 | 1206 | 1521 | 195 | 1.5 | 293 | | | | 45.1 |
| L-17 | | IWA ☐ MARTHA CRUZ PII<br>OWA ☐ ROOM # 740 | 2/2 | 1207 | 1522 | 195 | 2 | 390 | | | | 43.8 |
| L-18 | | IWA ☐ GIL CALLE SS# PII<br>OWA ☐ ROOM # 701A | 2/1 | 1208 | 1523 | 195 | 1.5 | 293 | | | | 45.1 |
| FB1 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | 41.5 |
| FB2. | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | 41.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | 7-21-02 | 1615 | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY (SIGNATURE)** | **DATE** | **TIME** |
| | | | R. Arredia | 7.21.02 | 16.15 |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT # FILTER MANUFACTURER E. Cypress

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| Gary McKenzie | N.Y.C SCA | Stuyvesant H.S | 7/22 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7/21/02 | Hamid Shoai | 7th Floor | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| L-18 | M477-15217/29891 | Chris McElgun | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☒ Juan Sanchez PII Rm 702 OWA ☐ | 2.0 / 2.0 | 1800 | 1930 | 210 | 2.0 | 420 | | | | |
| 02 | | IWA ☒ Jose Velez PII Rm 704 OWA ☐ | 2.0 / 2.0 | 1802 | 1932 | 210 | 2.0 | 420 | | | | |
| 03 | | IWA ☒ Luis Naranjo PII Rm 726 OWA ☐ | 2.0 / 2.0 | 1804 | 1934 | 210 | 2.0 | 420 | | | | |
| 04 | | IWA ☒ Justo Calle PII Rm 731 OWA ☐ | 2.0 / 2.0 | 1806 | 1936 | 210 | 2.0 | 420 | | | | |
| 05 | | IWA ☒ Mauricio Avila PII Rm 735 OWA ☐ | 2.0 / 2.0 | 1808 | 1938 | 210 | 2.0 | 420 | | | | |
| 06 | | IWA ☒ Sergio Gallegos PII Rm 736 OWA ☐ | 2.0 / 2.0 | 1810 | 1940 | 210 | 2.0 | 420 | | | | |
| 07 | | IWA ☒ Fausto Santos PII Rm 737 OWA ☐ | 2.0 / 2.0 | 1812 | 1942 | 210 | 2.0 | 420 | | | | |
| 08 | | IWA ☒ Alcivar Naranjo PII Rm 739 OWA ☐ | 2.0 / 2.0 | 1814 | 1944 | 210 | 2.0 | 420 | | | | |
| 09 | | IWA ☒ Juan Sanchez PII Rm [redacted]738 OWA ☐ | 2.0 / 2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | |
| 10 | | IWA ☒ Jose Velez PII Rm [redacted] OWA ☐ | 2.0 / 2.0 | 2002 | 0002 | 240 | 2.0 | 480 | | | | |
| 11 | | IWA ☒ Luis Naranjo PII Rm 726 OWA ☐ | 2.0 / 2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | |
| 12 | | IWA ☒ Justo Calle PII Rm 731 OWA ☐ | 2.0 / 2.0 | 2006 | 0006 | 240 | 2.0 | 480 | | | | |
| 13 | | IWA ☒ Mauricio Avila PII Rm 735 OWA ☐ | 2.0 / 2.0 | 2008 | 0008 | 240 | 2.0 | 480 | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| [signature] | 7/22 | 0030 | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| | | | [signature] | 7/22/02 | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER USOSH METHOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: N.Y.C SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 1/22 |
| DATE SUPPLIED: 7/21/02 | CONTACT: Hamed Sawos | WORK AREA: 7th Floor | DATE LOGGED: 20522 |
| ROTOMETER NO: L-18 | PROJECT NO: M477-1521 / 29881 | PROJECT MANAGER: Chris McElgon | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☒ Sergio PII<br>OWA ☐ Gallegos Rm 736 | 2.0 / 2.0 | 2010 | 0010 | 240 | 2.0 | 480 | | | | |
| 15 | | IWA ☒ Fasto PII<br>OWA ☐ Cantos Rm 737 | 2.0 / 2.0 | 2012 | 0012 | 240 | 2.0 | 480 | | | | |
| 16 | | IWA ☒ Alcivor PII<br>OWA ☐ Naranjo Rm 739 | 2.0 / 2.0 | 2014 | 0014 | 240 | 2.0 | 480 | | | | |
| FB-17 | | IWA ☐<br>OWA ☐ FB-17 | | | | | | | | | | |
| FB-18 | | IWA ☐<br>OWA ☐ FB-18 | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Gary McKenzie | DATE: 1/22 | TIME: 0030 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY (SIGNATURE): | DATE: 7/22/2 | TIME: |
| ANALYST (SIGNATURE) | DATE: | TIME: | COMMENTS: | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH METHOD 7082

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-22-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
350 Chambers Street
7th Floor

**PROJECT NUMBER:** M477-15217-29881

**SAMPLED BY:** Client

**SAMPLE DATE:** 07-21-02
**DATE RECEIVED:** 07-22-02
**DATE ANALYZED:** 07-22-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20525 | J.Sanchez SS# PII / Room 702 | <3.6 | 3.6 |
| 02 | 20525 | J.Velez SS# PII / Room 704 | <3.6 | 3.6 |
| 03 | 20525 | L.Naranjo SS# PII / Room 726 | <3.6 | 3.6 |
| 04 | 20525 | J.Calle SS# PII / Room 731 | <3.6 | 3.6 |
| 05 | 20525 | M.Avila SS# PII / Room 735 | <3.6 | 3.6 |
| 06 | 20525 | S.Gallegos SS# PII / Room 736 | <3.6 | 3.6 |
| 07 | 20525 | F.Cantos SS# PII / Room 737 | <3.6 | 3.6 |
| 08 | 20525 | A.Naranjo SS# PII / Room 739 | <3.6 | 3.6 |
| 09 | 20525 | J.Sanchez SS# PII / Room 738 | <3.1 | 3.1 |
| 10 | 20525 | J.Velez SS# PII / Room 740 | <3.1 | 3.1 |
| 11 | 20525 | L.Naranjo SS# PII / Room 726 | <3.1 | 3.1 |
| 12 | 20525 | J.Calle SS# PII / Room 731 | <3.1 | 3.1 |
| 13 | 20525 | M.Avila SS# PII / Room 735 | <3.1 | 3.1 |
| 14 | 20525 | S.Gallegos SS# PII / Room 736 | <3.1 | 3.1 |
| 15 | 20525 | F.Cantos SS# PII / Room 737 | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 9/22/02 |
| DATE SAMPLED: 9/22/02 | CONTACT: Hymie Sanos | WORK AREA: 6th floor. | DATE LOGGED: 20547 |
| ROTOMETER NO.: 16 | PROJECT NO: M 477-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☑ OWA ☐ Beatriz Chavez Room 639 PII | 2.0 / 2.0 | 800 am | 1130 am | 210 | 2.0 | 420 | | | | 18.3 |
| 2 | | IWA ☑ OWA ☐ Julio Bastidas Room 640 PII | 2.0 / 2.0 | 802 Am | 1132 Am | 210 | 2.0 | 420 | | | | < 3.6 |
| 3 | | IWA ☑ OWA ☐ Marcelo Atlencia Room 638 PII | 2.0 / 2.0 | 804 Am | 1134 Am | 210 | 2.0 | 420 | | | < | 3.6 |
| 4 | | IWA ☑ OWA ☐ Pablo Uralles Room 615B PII | 2.0 / 2.0 | 920 Am | 1136 Am | 136 | 2.0 | 272 | | | | 6.5 |
| 5 | | IWA ☑ OWA ☐ Gabriel Toledo Room 636 PII | 2.0 / 2.0 | 922 Am | 1138 Am | 136 | 2.0 | 272 | | | < | 5.5 |
| 6 | | IWA ☑ OWA ☐ David Vlkes Room 629 PII | 2.0 / 2.0 | 924 Am | 1140 Am | 136 | 2.0 | 272 | | | < | 5.5 |
| 7 | | IWA ☑ OWA ☐ Luis Cuzco Room 635 PII | 2.0 / 2.0 | 926 Am | 1142 Am | 136 | 2.0 | 272 | | | | 6.3 |
| 8 | | IWA ☑ OWA ☐ Beatriz Chavez Room 639 PII | 2.0 / 2.0 | 1200 pm | 310 pm | 190 | 2.0 | 380 | | | < | 3.9 |
| 9 | | IWA ☑ OWA ☐ Julio Bastidas Room 640 PII | 2.0 / 2.0 | 1202 pm | 312 pm | 190 | 2.0 | 380 | | | | 12.8 |
| 10 | | IWA ☑ OWA ☐ Marcelo Atlencia Room 638 PII | 2.0 / 2.0 | 1204 pm | 314 pm | 190 | 2.0 | 380 | | | | 11.3 |
| 11 | | IWA ☑ OWA ☐ Pablo Uralles Room 615B PII | 2.0 / 2.0 | 1206 pm | 316 pm | 190 | 2.0 | 380 | | | | 5.3 |
| 12 | | IWA ☑ OWA ☐ Gabriel Toledo Room 636 PII | 2.0 / 2.0 | 1208 pm | 318 pm | 190 | 2.0 | 380 | | | | 5.8 |
| 13 | | IWA ☑ OWA ☐ David Vlkes Room 629 PII | 2.0 / 2.0 | 1210 pm | 3268m | 190 | 2.0 | 380 | | | | 6.3 |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): | | | RECEIVED FROM TEG DROP BOX (SIGNATURE): 9/07/22 | | |
| RELINQUISHED BY (SIGNATURE): | 9/22/02 | 438pm | RECEIVED BY: (SIGNATURE) | | |
| ANALYST (SIGNATURE) | | | COMMENTS: 12 HOUR Turnaround NIOSH 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT # FILTER/MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106972

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 2 OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 7/22/02 |
| DATE SAMPLED: 7/22/02 | CONTACT: Howard Saint | WORK AREA: 6th floor | DATE LOGGED: 20642 |
| ROTOMETER NO.: 16 | PROJECT NO.: M4977-1521 7 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED/ SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☑ OWA ☐ Luis Cuzco Room 635 PII | 2.0 / 2.0 | 1212 pm | 322 pm | 190 | 2.0 | 380 | | | | 439 |
| 15 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | 41.5 |
| 16 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | 41.5 |
| 17 | | IWA ☑ OWA ☐ Segundo Leon Room 627 PII | 2.0 / 2.0 | 1214 pm | 324 pm | 180 | 2.0 | 380 | | | | 41.7 |
| 18 | | IWA ☑ OWA ☐ Carlos Alt Room 615 PII | 2.0 / 2.0 | 120 pm | 326 pm | 126 | 2.0 | 252 | | | | 460 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) 7/22 | DATE | TIME |
| RELINQUISHED BY (SIGNATURE) | DATE 7/22/02 | TIME | RECEIVED BY (SIGNATURE) | DATE | TIME |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR Turnaround NIOSH 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT # ____ FILTER MANUFACTURER ____

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106973

NYC 9/11 Public Portal Document


# ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306


**REPORT DATE:** 07-23-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
6th Floor

**PROJECT NUMBER:** M477-15217

**SAMPLED BY:** Client

**SAMPLE DATE** 07-22-02
**DATE RECEIVED:** 07-22-02
**DATE ANALYZED:** 07-22-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20542 | Beatriz Chavez SS# PII | 18.3 | 3.6 |
| 02 | 20542 | Julio Bastidas SS# PII | <3.6 | 3.6 |
| 03 | 20542 | Marcelo Atlencia SS# PII | <3.6 | 3.6 |
| 04 | 20542 | Pablo Urgiles SS# PII | 6.5 | 5.5 |
| 05 | 20542 | Gabriel Toledo SS# PII | <5.5 | 5.5 |
| 06 | 20542 | David Vivar SS# PII | <5.5 | 5.5 |
| 07 | 20542 | Luis Cuzco SS# PII | 6.3 | 5.5 |
| 08 | 20542 | Beatriz Chavez SS# PII | <3.9 | 3.9 |
| 09 | 20542 | Julio Bastidas SS# PII | 12.8 | 3.9 |
| 10 | 20542 | Marcelo Atlencia SS# PII | 11.3 | 3.9 |
| 11 | 20542 | Pablo Urgiles SS# PII | 5.3 | 3.9 |
| 12 | 20542 | Gabriel Toledo SS# PII | 5.8 | 3.9 |
| 13 | 20542 | David Vivar SS# PII | 6.3 | 3.9 |
| 14 | 20542 | Luis Cuzco SS# PII | <3.9 | 3.9 |
| 15 | 20542 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20542 | Field Blank | <1.5 µg | 1.5 µg |
| 17 | 20542 | Segundo Leon SS# PII | 4.7 | 3.9 |
| 18 | 20542 | Carbs Ali SS# PII | <6.0 | 6.0 |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted]

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF [redacted]

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/23/02 |
| DATE SAMPLED: 7/22/02 | CONTACT: Manny Sanchez | WORK AREA: 6th Floor | DATE LOGGED: |
| ROTOMETER NO: L-18 | PROJECT NO: M477-15247/29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Lady OWA ☐ Parra PII Rm 627 | 2.0 / 2.0 | 1600 | 1930 | 210 | 2.0 | 420 | | | | <3.6 |
| 02 | | IWA ☐ Luis OWA ☐ Rodriguez PII Rm 629 | 2.0 / 2.0 | 1602 | 1932 | 210 | 2.0 | 420 | | | | <3.6 |
| 03 | | IWA ☐ Jose OWA ☐ Vivar PII Rm 635 | 2.0 / 2.0 | 1604 | 1934 | 210 | 2.0 | 420 | | | | <3.6 |
| 04 | | IWA ☐ Juan OWA ☐ Sanchez PII Rm 636 | 2.0 / 2.0 | 1606 | 1936 | 210 | 2.0 | 420 | | | | <3.6 |
| 05 | | IWA ☐ Fabian OWA ☐ Ordonez PII Rm 638 | 2.0 / 2.0 | 1608 | 1938 | 210 | 2.0 | 420 | | | | <3.6 |
| 06 | | IWA ☐ A. OWA ☐ Naranjo PII Rm. Library Right | 2.0 / 2.0 | 1610 | 1940 | 210 | 2.0 | 420 | | | | <3.6 |
| 07 | | IWA ☐ Raul OWA ☐ Naranjo PII Rm. Library middle | 2.0 / 2.0 | 1612 | 1942 | 210 | 2.0 | 420 | | | | <3.6 |
| 08 | | IWA ☐ Walter OWA ☐ Gallegos PII Rm. Library left | 2.0 / 2.0 | 1614 | 1944 | 210 | 2.0 | 420 | | | | <3.6 |
| 09 | | IWA ☐ Felix OWA ☐ Calle PII Rm 615B | 2.0 / 2.0 | 1616 | 1946 | 210 | 2.0 | 420 | | | | <3.6 |
| 10 | | IWA ☐ Lady OWA ☐ Parra PII Rm 627 | 2.0 / 2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | <3.1 |
| 11 | | IWA ☐ Luis OWA ☐ Rodriguez PII Rm 629 | 2.0 / 2.0 | 2002 | 0002 | 240 | 2.0 | 480 | | | | <3.1 |
| 12 | | IWA ☐ Jose OWA ☐ Vivar PII Rm 635 | 2.0 / 2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | <3.1 |
| 13 | | IWA ☐ Juan OWA ☐ Sanchez PII Rm 636 | 2.0 / 2.0 | 2006 | 0006 | 240 | 2.0 | 480 | | | | <3.1 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | DATE 7/24/02 | TIME 0100 | RECEIVED BY: (SIGNATURE) R. Droudina | DATE 7.23.02 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 Hour TAT (212) 406-2535 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH MET. 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106976

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/23 |
| DATE SAMPLED: 7/22/02 | CONTACT: Hmo Shot | WORK AREA: 6th Floor | DATE LOGGED: |
| ROTOMETER NO: L-18 | PROJECT NO: MW77-15217/29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | f/cc mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ Fabian PII<br>OWA ☐ Ordonez Rm 638 | 2.0<br>2.0 | 2008 | 0008 | 240 | 2.0 | 480 | | | | <3.1 |
| 15 | | IWA ☐ A. PII<br>OWA ☐ Naranjo Library right | 2.0<br>2.0 | 2010 | 0010 | 240 | 2.0 | 480 | | | | <3.1 |
| 16 | | IWA ☐ Fay PII<br>OWA ☐ Naranjo Library middle | 2.0<br>2.0 | 2012 | 0012 | 240 | 2.0 | 480 | | | | <3.1 |
| ☐ | | IWA ☐ Walter PII<br>OWA ☐ Gallegos Library Left | 2.0<br>2.0 | 2014 | 0014 | 240 | 2.0 | 480 | | | | <3.1 |
| 18 | | IWA ☐ Felix PII<br>OWA ☐ Calle Rm 615B | 2.0<br>2.0 | 2016 | 0016 | 240 | 2.0 | 480 | | | | <3.1 |
| FB-19 | | IWA ☐<br>OWA ☐ FB-19 | | | | | | | | | | <1.5 |
| FB-20 | | IWA ☐<br>OWA ☐ FB-20 | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | DATE 7/24/02 | TIME 0100 | RECEIVED BY: (SIGNATURE) R. Dandina | DATE 7.23.02 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 Hour TAT (212)-406-2535 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH MET. 7400

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106977

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-23-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
6th Floor

**PROJECT NUMBER:** M477-15217/29801

**SAMPLED BY:** Client

**SAMPLE DATE** 07-23-02
**DATE RECEIVED:** 07-23-02
**DATE ANALYZED:** 07-23-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20561 | Lady Parra SS# PII | <3.6 | 3.6 |
| 02 | 20561 | Luis Rodriguez SS# PII | <3.6 | 3.6 |
| 03 | 20561 | Juse Vivar SS# PII | <3.6 | 3.6 |
| 04 | 20561 | Juan Sanchez SS# PII | <3.6 | 3.6 |
| 05 | 20561 | Fabian Ordonez SS# PII | <3.6 | 3.6 |
| 06 | 20561 | A. Naranjo SS# PII | <3.6 | 3.6 |
| 07 | 20561 | Raul Naranjo SS# PII | <3.6 | 3.6 |
| 08 | 20561 | Walter Gallegos SS# PII | <3.6 | 3.6 |
| 09 | 20561 | Felix Colle SS# PII | <3.6 | 3.6 |
| 10 | 20561 | Lady Parra SS# PII | <3.1 | 3.1 |
| 11 | 20561 | Luis Rodriguez SS# PII | <3.1 | 3.1 |
| 12 | 20561 | Jusc Vivar SS# PII | <3.1 | 3.1 |
| 13 | 20561 | Juan Sanchez SS# PII | <3.1 | 3.1 |
| 14 | 20561 | Fabian Ordonez SS# PII | <3.1 | 3.1 |
| 15 | 20561 | A. Naranjo SS# PII | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20561 | Raul Naranjo SS# PII | <3.1 | 3.1 |
| 17 | 20561 | Walter Gallegos SS# PII | <3.1 | 3.1 |
| 18 | 20561 | Felix Colle SS# PII | <3.1 | 3.1 |
| 19 | 20561 | Field Blank | <1.5 µg | 1.5 µg |
| 20 | 20561 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229)

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H. S. 345 Chambers | DATE SUBMITTED: 7/23 |
| DATE SAMPLED: 7/23/02 | CONTACT: Mr. D Smoot | WORK AREA: 6th floor | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO: M477-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVER-AGE) | LITERS | FIELDS | FIBERS | F/MM² | TEM |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☑ OWA ☐ Jose Perez Room 615 PII | 2.0 / 2.0 | 730 am | 430 pm | 240 | 2.0 | 480 | | | | 30.5 |
| 2 | | IWA ☑ OWA ☐ Martha Calza Room 615E PII | 2.0 / 2.0 | 732 am | 1132 am | 240 | 2.0 | 480 | | | | <3.1 |
| 3 | | IWA ☑ OWA ☐ Silvia Castello 601 PII | 2.0 / 2.0 | 734 am | 1134 am | 240 | 2.0 | 480 | | | | <3.1 |
| 4 | | IWA ☑ OWA ☐ Gil Calle room 501C PII | 2.0 / 1.5 | 736 am | 1136 am | 240 | 1.75 | 420 | | | | <3.1 |
| 5 | | IWA ☑ OWA ☐ Pablo Uralles room 503 PII | 2.0 / 2.0 | 738 am | 1138 am | 240 | 2.0 | 480 | | | | <3.1 |
| 6 | | IWA ☑ OWA ☐ Ramiro Bastidas room 501B PII | 2.0 / 2.0 | 740 am | 1140 am | 240 | 2.0 | 480 | | | | <3.1 |
| 7 | | IWA ☑ OWA ☐ Maria Ortega room 807 PII | 2.0 / 2.0 | 930 am | 1142 am | 132 | 2.0 | 264 | | | | <5.7 |
| 8 | | IWA ☐ OWA ☐ Ovilio Bastidas Room 615 PII | 2.0 / 2.0 | 1208 pm | 300 | 180 | 2.0 | 360 | | | | <4.1 |
| 9 | | IWA ☑ OWA ☐ Martha Calza Room 509 PII | 2.0 / 2.0 | 1202 pm | 302 | 180 | 2.0 | 360 | | | | <4.2 |
| 10 | | IWA ☑ OWA ☐ Luis Rodriguez Room 601 PII | 2.0 / 2.0 | 1204 pm | 304 | 180 | 2.0 | 360 | | | | <4.2 |
| 11 | | IWA ☑ OWA ☐ Pablo Uralles room K571 PII | 2.0 / 2.0 | 120 pm | 320 | 120 | 2.0 | 240 | | | | <6.3 |
| 12 | | IWA ☑ OWA ☐ Gil Calle room 525 PII | 2.0 / 2.0 | 122 pm | 322 | 120 | 2.0 | 240 | | | | <6.3 |
| 13 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 14 | | Field Blank | | | | | | | | | | 1.5 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) Alex 07/23 6p | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE 7/23/02 | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR Turnaround NIOSH 7082 Prefield | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-24-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
6th Floor

**PROJECT NUMBER:** M477-15217

**SAMPLED BY:** Client

**SAMPLE DATE** 07-23-02
**DATE RECEIVED:** 07-23-02
**DATE ANALYZED:** 07-23-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20577 | Jose Perez SS# PII | 3.5 | 3.1 |
| 02 | 20577 | Martha Caiza SS# PII | <3.1 | 3.1 |
| 03 | 20577 | Silvia Castillo SS# PII | <3.1 | 3.1 |
| 04 | 20577 | Gil Calle SS# PII | <3.1 | 3.1 |
| 05 | 20577 | Pablo Urgiles SS# PII | <3.1 | 3.1 |
| 06 | 20577 | Ramiro Bastidus SS# PII | <3.1 | 3.1 |
| 07 | 20577 | Maria Ortega SS# PII | <5.7 | 5.7 |
| 08 | 20577 | Julio Bastidas SS# PII | <4.1 | 4.1 |
| 09 | 20577 | Martha Caiza SS# PII | <4.2 | 4.2 |
| 10 | 20577 | Luis Rodriguez SS# PII | <4.2 | 4.2 |
| 11 | 20577 | Pablo Urgiles SS# PII | <6.3 | 6.3 |
| 12 | 20577 | Gil Calle SS# PII | <6.3 | 6.3 |
| 13 | 20577 | Field Blank | <1.5 µg | 1.5 µg |
| 14 | 20577 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#12816001

PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary Mckenzie | CLIENT: N.Y.C SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/24/02 |
| DATE SAMPLED: 7/23/02 | CONTACT: Harold Sykes | WORK AREA: 5th Floor | DATE LOGGED: |
| ROTOMETER NO: F-18 | PROJECT NO: M477-1521/29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Jose PII<br>OWA ☐ Vivar Rm 501 (C) | 2.0 / 2.0 | 1600 | 1930 | 210 | 2.0 | 420 | | | | |
| 02 | | IWA ☐ Angel PII<br>OWA ☐ Siguenza Rm 501 (B) | 2.0 / 2.0 | 1602 | 1932 | 210 | 2.0 | 420 | | | | |
| 03 | | IWA ☐ Justo PII<br>OWA ☐ Calle Rm 503 | 2.0 / 2.0 | 1604 | 1934 | 210 | 2.0 | 420 | | | | |
| 04 | | IWA ☐ Henri PII<br>OWA ☐ Avila Rm 505 | 2.0 / 2.0 | 1606 | 1936 | 210 | 2.0 | 420 | | | | |
| 05 | | IWA ☐ Romulo PII<br>OWA ☐ Quizhpi Rm 511 | 2.0 / 2.0 | 1608 | 1938 | 210 | 2.0 | 420 | | | | |
| 06 | | IWA ☐ Juan PII<br>OWA ☐ Sanchez Rm 513 | 2.0 / 2.0 | 1610 | 1940 | 210 | 2.0 | 420 | | | | |
| 07 | | IWA ☐ Raul Naranjo PII<br>OWA ☐ ~~Sanchez~~ Rm 525 | 2.0 / 2.0 | 1612 | 1942 | 210 | 2.0 | 420 | | | | |
| 08 | | IWA ☐ Jose PII<br>OWA ☐ Campoverde Rm 531 | 2.0 / 2.0 | 1614 | 1944 | 210 | 2.0 | 420 | | | | |
| 09 | | IWA ☐ Walter PII<br>OWA ☐ Gallegos Rm 507 | 2.0 / 2.0 | 1616 | 1946 | 210 | 2.0 | 420 | | | | |
| 10 | | IWA ☐ Jose PII<br>OWA ☐ Velez Rm 1024 A | 2.0 / 2.0 | 1618 | 1948 | 210 | 2.0 | 420 | | | | |
| 11 | | IWA ☐ Jose PII<br>OWA ☐ Vivar Rm 501 (C) | 2.0 / 2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | |
| 12 | | IWA ☐ Angel PII<br>OWA ☐ Siguenza Rm 501 (B) | 2.0 / 2.0 | 2002 | 0002 | 240 | 2.0 | 480 | | | | |
| 13 | | IWA ☐ Justo PII<br>OWA ☐ Calle Rm 503 | 2.0 / 2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Gary Mckenzie | DATE: 7/24/02 | TIME: 0700 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7.24.02 | TIME: 1.00 | RECEIVED BY: (SIGNATURE): | DATE: 7/24/02 | TIME: 9:00 AM |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS | | |

CYCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER NIOSH METAID 7182

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106982

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#20001



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/24/02 |
| DATE SAMPLED: 7/23/02 | CONTACT: Hanno Sweg | WORK AREA: 5th Floor | DATE LOGGED: |
| ROTOMETER NO: L-18 | PROJECT NO: M477-15217/29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ Henri PII<br>OWA ☐ Avila Rm 505 | 2.0/2.0 | 2006 | 0006 | 240 | 2.0 | 480 | | | | |
| 15 | | IWA ☐ Romulo PII<br>OWA ☐ Quizhpi Rm 511 | 2.0/2.0 | 2008 | 0008 | 240 | 2.0 | 480 | | | | |
| 16 | | IWA ☐ Juan PII<br>OWA ☐ Sanchez Rm 513 | 2.0/2.0 | 2010 | 0010 | 240 | 2.0 | 480 | | | | |
| 17 | | IWA ☐ Raul Naranjo PII<br>OWA ☐ ~~Sanchez~~ Rm 525 | 2.0/2.0 | 2012 | 0012 | 240 | 2.0 | 480 | | | | |
| 18 | | IWA ☐ Jose PII<br>OWA ☐ Campoverde Rm 531 | 2.0/2.0 | 2014 | 0014 | 240 | 2.0 | 480 | | | | |
| 19 | | IWA ☐ Walter PII<br>OWA ☐ Gallegos Rm 507 | 2.0/2.0 | 2016 | 0016 | 240 | 2.0 | 480 | | | | |
| 20 | | IWA ☐ Jose PII<br>OWA ☐ Velez Rm 1024M | 2.0/2.0 | 2018 | 0018 | 240 | 2.0 | 480 | | | | |
| 21 | | IWA ☐<br>OWA ☐ F. BLANK (1) | | | | | | | | | | |
| 22 | | IWA ☐<br>OWA ☐ F. BLANK (2) | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Gary McKenzie | DATE: 7/24/02 | TIME: 0100 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): Gary McKenzie | DATE: 7/24/02 | TIME: 1.00 | RECEIVED BY: (SIGNATURE): | DATE: 7/24/02 | TIME: 9:00 |
| ANALYST (SIGNATURE): | DATE: | TIME: | COMMENTS: | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH METHOD 7082

LOT #:

FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-24-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>5th Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-23-02 |
| **DATE RECEIVED:** | 07-24-02 |
| **DATE ANALYZED:** | 07-24-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20601 | JoseVivar SS# PII | <3.6 | 3.6 |
| 02 | 20601 | Angel Siguendo sS# PII | <3.6 | 3.6 |
| 03 | 20601 | Justo Calle SS# PII | <3.6 | 3.6 |
| 04 | 20601 | Henry Avila SS# PII | <3.6 | 3.6 |
| 05 | 20601 | Romulo Quizhri SS# PII | <3.6 | 3.6 |
| 06 | 20601 | Juan Sanchez SS# PII | <3.6 | 3.6 |
| 07 | 20601 | Raul Naranjo SS# PII | <3.6 | 3.6 |
| 08 | 20601 | Jose Campoverde SS# PII | <3.6 | 3.6 |
| 09 | 20601 | Walter Gallegos SS# PII | <3.6 | 3.6 |
| 10 | 20601 | Jose Velez SS# PII | <3.6 | 3.6 |
| 11 | 20601 | JoseVivar SS# PII | <3.1 | 3.1 |
| 12 | 20601 | Angel Siguendo sS# PII | <3.1 | 3.1 |
| 13 | 20601 | Justo Calle SS# PII | <3.1 | 3.1 |
| 14 | 20601 | Henry Avila SS# PII | <3.1 | 3.1 |
| 15 | 20601 | Romulo Quizhri SS# PII | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20601 | Juan Sanchez SS# PII | <3.1 | 3.1 |
| 17 | 20601 | Raul Naranjo SS# PII | <3.1 | 3.1 |
| 18 | 20601 | Jose Campoverde SS# PII | <3.1 | 3.1 |
| 19 | 20601 | Walter Gallegos SS# PII | <3.1 | 3.1 |
| 20 | 20601 | Jose Velez SS# PII | <3.1 | 3.1 |
| 21 | 20601 | Field Blank | <1.5 µg | 1.5 µg |
| 22 | 20601 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted] PAGE [redacted] OF [redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 7/24/02
DATE SAMPLED: 7/24/02 | CONTACT: Hans Swos | WORK AREA: 5th Floor | DATE LOGGED: 7/24/02
ROTOMETER NO.: 160 | PROJECT NO.: M477-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED/AUTHORIZED: 7/24/02

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☑ OWA ☐ Luis Rodriguez Room 501B PII | 2.0 / 2.0 | 730 am | 1120 am | 230 | 2.0 | 460 | | | | < 3.3 |
| 2 | | IWA ☑ OWA ☐ Maria Ortega Room 507 PII | 2.0 / 2.0 | 732 am | 1122 am | 230 | 2.0 | 460 | | | | 4.5 |
| 3 | | IWA ☑ OWA ☐ Miguel Ali Room 511 PII | 2.0 / 2.0 | 734 am | 1124 am | 230 | 2.0 | 460 | | | | 5.7 |
| 4 | | IWA ☑ OWA ☐ Angel Narranjo Room 525 PII | 2.0 / 2.0 | 736 am | 1126 am | 230 | 2.0 | 460 | | | | < 3.3 |
| 5 | | IWA ☑ OWA ☐ Silvio Perez Room 531 PII | 2.0 / 2.0 | 738 am | 1128 am | 230 | 2.0 | 460 | | | | < 3.3 |
| 6 | | IWA ☑ OWA ☐ Silvia Castilla Room 407 PII | 2.0 / 2.0 | 830 am | 1130 am | 180 | 2.0 | 360 | | | | < 4.2 |
| 7 | | IWA ☑ OWA ☐ Angel Asmat Room 405 PII | 2.0 / 2.0 | 832 am | 1132 am | 180 | 2.0 | 360 | | | | < 4.2 |
| 8 | | IWA ☑ OWA ☐ Luis Rodriguez Room 507 PII | 2.0 / 2.0 | 1150 | 310 | 200 | 2.0 | 400 | | | | < 3.8 |
| 9 | | IWA ☑ OWA ☐ Maria Ortega Room 511 PII | 2.0 / 2.0 | 1152 | 312 | 200 | 2.0 | 400 | | | | < 3.8 |
| 10 | | IWA ☑ OWA ☐ Miguel Ali Room 501B PII | 2.0 / 2.0 | 1154 | 314 | 200 | 2.0 | 400 | | | | < 3.8 |
| 11 | | IWA ☑ OWA ☐ Angel Narranjo Room 525 PII | 2.0 / 2.0 | 1156 | 316 | 200 | 2.0 | 400 | | | | < 3.8 |
| 12 | | IWA ☑ OWA ☐ Silvio Perez Room 531 PII | 2.0 / 2.0 | 1158 | 318 | 200 | 2.0 | 400 | | | | < 3.8 |
| 13 | | IWA ☑ OWA ☐ Silvia Castilla Room 403 PII | 2.0 / 2.0 | 1200 | 320 | 200 | 2.0 | 400 | | | | 7.5 |

RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) A. Cha 07/24 | DATE | TIME
RELINQUISHED BY: (SIGNATURE) | DATE 7/24/02 | TIME 5:20PM | RECEIVED BY: (SIGNATURE) | DATE | TIME
ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR Turnaround

CIRCLE: PCM TEM | BGND PRE DURING POST | OSHA | OTHER NY-10 STP 1052
LOT #
FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106986

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 chambers | DATE SUBMITTED: 8/2/02 |
| DATE SAMPLED: 8/2/02 | CONTACT: Hamid Sayat | WORK AREA: 2nd / 5th Floors | DATE LOGGED: |
| ROTOMETER NO: 16 | PROJECT NO: 1477-1521? | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☐ Luis Cueto room 501A PII | 2.0 / 2.0 | 730 am | 1130 am | 240 | 2.0 | 480 | | | | |
| 2 | | IWA ☐ OWA ☐ Luis Avila room 231 PII | 2.0 / 2.0 | 732 am | 1132 am | 240 | 2.0 | 480 | | | | |
| 3 | | IWA ☐ OWA ☐ Luis Avila room 231 PII | 2.0 / 2.0 | 1200 pm | 200 pm | 120 | 2.0 | 240 | | | | |
| 4 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | |
| 5 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | | | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY (SIGNATURE) | 8/2/02 | 915 pm | RECEIVED BY (SIGNATURE) | 8/2/02 | 924 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 Hour Turnaround NIOSH Method 7400 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NJ Asbestos

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

Fax 40 (212) 619-2743

EMSL ANALYTICAL INC 212-290-2538 08/02/2002 21:27 PAGE 02/02

03021049S

02 AUG -2 PM 5:27

NYC-WTC_000106987

NYC 9/11 Public Portal Document



EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (515) 358-1780 Phone: 516-358-2955

Project: M477-15217/ SCA/ STUYVESANT H.S. 345 CHAMBERS

Customer ID: TAYL50
Customer PO:
Received: 08/02/02 4:24 PM

EMSL Order: 030210495
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| | Client Sample Description | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 1 | LUIS CUZCO ROOM 501A | 0001 | 8/2/2002 | 480 L | <8.3 µg/m³ | |
| 2 | LUIS AVILA ROOM 231 | 0002 | 8/2/2002 | 480 L | <8.3 µg/m³ | |
| 3 | LUIS AVILA ROOM 231 | 0003 | 8/2/2002 | 240 L | <17.0 µg/m³ | |
| 4 | Field blank | 0004 | 8/2/2002 | n/a | <4.0 µg/filter | |
| 5 | Field blank | 0005 | 8/2/2002 | n/a | <4.0 µg/filter | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581

P w/o QC



NYC-WTC_000106988

[redacted] TAYLOR ENVIRONMENTAL GROUP [redacted] BAILEY MONITORING SHEET AND CHAIN OF CUSTODY FOR [redacted] PAGE 1 OF 2

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| M. Plonsky | SCA | Stuyvesant HS 350 Chambers St N.YC | 7/25/02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7.24.02 Wed | Hamid Sayaj | 4th, 9th floor | |
| PHOTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| L-18 | M-477-15217-29881 | Ch. McClean | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC fig/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L01 | | IWA ☐ OWA ☐ 4fl - rm 407 Naranjo Luis PII | 2/2 | 1558 | 1919 | 201 | 2 | 402 | | | | 43.7 |
| L02 | | IWA ☐ OWA ☐ 4fl - rm 405 Richard Avila PII | 2/2 | 1602 | 1921 | 199 | 2 | 398 | | | | 43.8 |
| L03 | | IWA ☐ OWA ☐ 4fl - rm 403 Raul Loja PII | 2/2 | 1603 | 1920 | 197 | 2 | 394 | | | | 43.8 |
| L04 | | IWA ☐ OWA ☐ 4fl - 401 - Lady Parra clrm PII | 2/2 | 1605 | 1924 | 199 | 2 | 398 | | | | 43.8 |
| L05 | | IWA ☐ OWA ☐ 4fl - rm 404 - Stanislow Buslowski - PII | 2/2 | 1607 | 1928 | 201 | 2 | 402 | | | | 43.7 |
| L06 | | IWA ☐ OWA ☐ 4fl - rm 411 - Nube Callejo PII | 2/2 | 1609 | 1930 | 201 | 2 | 402 | | | | 43.7 |
| L07 | | IWA ☐ OWA ☐ 4fl - rm 413 - Romulo Quizhpi PII | 2/2 | 1610 | 1926 | 196 | 2 | 392 | | | | 43.8 |
| L08 | | IWA ☐ OWA ☐ 9th fl rm 911 Cesar Arolen PII | 2/2 | 1645 | 1971 | 166 | 2 | 332 | | | | 44.5 |
| L09 | | IWA ☐ OWA ☐ 4fl - rm 407 - Naranjo Luis PII | 2/2 | 2000 | 2226 | 144 | 2 | 288 | | | | 45.2 |
| L10 | | IWA ☐ OWA ☐ 4fl - rm 405 - Richard Avila PII | 2/2 | 2002 | 2338 | 216 | 2 | 432 | | | | 43.5 |
| L11 | | IWA ☐ OWA ☐ 4fl rm 403 Raul Loja PII | 2/2 | 2004 | 2331 | 207 | 2 | 414 | | | | 43.6 |
| L12 | | IWA ☐ OWA ☐ 4fl rm 401 Lady Parra PII | 2/2 | 2003 | 2326 | 203 | 2 | 406 | | | | 43.7 |
| L13 | | IWA ☐ OWA ☐ 4fl rm 429 Stanislow Buslowski PII | 2/2 | 2005 | 2316 | 191 | 2 | 382 | | | | 43.9 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| M Orb | 7-25-02 | 0030 | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| | | | R. DiMedina | 7.25.02 | 00.30 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | 12 hour turnaround Niosh 7082 | | |

CIRCLE: PCM TEM — BCRO PRE DURING POST — OSHA — OTHER — LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-25-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>4th Floor, 9 Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-24-02 |
| **DATE RECEIVED:** | 07-25-02 |
| **DATE ANALYZED:** | 07-25-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L01 | 20634 | 4 fl Naranjo Luis SS# PII | <3.7 | 3.7 |
| L02 | 20634 | 4 fl Richard Avila SS# PII | <3.8 | 3.8 |
| L03 | 20634 | 4 fl Raul Laja SS# PII | <3.8 | 3.8 |
| L04 | 20634 | 4 fl Lady Parra SS# PII | <3.8 | 3.8 |
| L05 | 20634 | 4 fl Stanislav Buslowski SS# PII | <3.7 | 3.7 |
| L06 | 20634 | 4 fl Nube Gallegos SS# PII | <3.7 | 3.7 |
| L07 | 20634 | 4 fl Romulo Quizphi SS# PII | <3.8 | 3.8 |
| L08 | 20634 | 9 fl Cesar Cholck SS# PII | <4.5 | 4.5 |
| L09 | 20634 | 4 fl Naranjo Luis SS# PII | <5.2 | 5.2 |
| L10 | 20634 | 4 fl Richard Avila SS# PII | <3.5 | 3.5 |
| L11 | 20634 | 4 fl Raul Laja SS# PII | <3.6 | 3.6 |
| L12 | 20634 | 4 fl Lady Parra SS# PII | <3.7 | 3.7 |
| L13 | 20634 | 4 fl Stanislav Buslowski SS# PII | <3.9 | 3.9 |
| L14 | 20634 | 4 fl Nube Gallegos SS# PII | <4.0 | 4.0 |
| L15 | 20634 | 4 fl Romulo Quizphi SS# PII | <3.7 | 3.7 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| L16 | 20634 | 9 fl Cesar Cholek SS# PII | <5.1 | 5.1 |
| BL1 | 20634 | Field Blank | <1.5 µg | 1.5 µg |
| BL2 | 20634 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted] PAGE [redacted] OF [redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: Stuyvesant H.S. 20607 | DATE SUBMITTED: 7-25-02. |
| DATE SAMPLED: 7-25-02. | CONTACT: HAMID SAVOS. | WORK AREA: 4th Floor. | DATE LOGGED: |
| ROTOMETER NO: TEG · L-18 | PROJECT NO: M477 - 15217 / 29881 | PROJECT MANAGER: CHRIS McELGUN. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ BEATRIZ CHAVEZ. SS# PII OWA ☐ ROOM # 437. | 2/2 | 0715 | 1128 | 153 | 2 | 306 | | | | 12.2 |
| L-02 | | IWA ☐ SYLVIA CASTILLO SS# PII OWA ☐ ROOM # 435 | 2/2 | 0716 | 1124 | 156 | 2 | 312 | | | | <4.9 |
| L-03 | | IWA ☐ BERTHA TACHE SS# PII OWA ☐ ROOM # 433 | 2/2 | 0717 | 1123 | 155 | 2 | 310 | | | | 8.7 |
| L-04 | | IWA ☐ LUIS RODRIGUEZ SS# PII OWA ☐ ROOM # 431 | 2/2 | 0718 | 1126. | 157 | 2 | 314 | | | | <4.8 |
| L-05 | | IWA ☐ DAVID VIVAR SS# PII OWA ☐ ROOM # 429. | 2/2 | 0719 | 1129 | 159 | 2 | 318 | | | | <4.8 |
| L-06 | | IWA ☐ LUIS AVILA SS# PII OWA ☐ ROOM # 427. | 2/2 | 0720 | 1128 | 158 | 2 | 316 | | | | <4.8 |
| L-07 | | IWA ☐ ALEXIS BERNAL SS# PII OWA ☐ ROOM # 413 | 2/2 | 0721 | 1127 | 157 | 2 | 314 | | | | <4.9 |
| L-08 | | IWA ☐ MARIA ALVAREZ SS# PII OWA ☐ ROOM # 411 | 2/2 | 0722 | 1125 | 155 | 2 | 310 | | | | 9.1 |
| L-09 | | IWA ☐ BEATRIZ CHAVEZ SS# PII OWA ☐ ROOM # 437 | 2/2 | 1156 | 1515 | 199 | 2 | 398 | | | | 4.6 |
| L-10 | | IWA ☐ SYLVIA CASTILLO SS# PII OWA ☐ ROOM # 435 | 1/2 | 1157 | 1516 | 199 | 2 | 398 | | | | 7.9 |
| L-11 | | IWA ☐ BERTHA TACHE. SS# PII OWA ☐ ROOM # 433 | 2/2 | 1158 | 1517 | 199 | 2 | 398 | | | | 13.0 |
| L-12 | | IWA ☐ LUIS RODRIGUEZ SS# PII OWA ☐ ROOM # 431 | 2/1 | 1159 | 1511 | 192 | 1.5 | 288 | | | | <3.9 |
| L-13 | | IWA ☐ DAVID VIVAR SS# PII OWA ☐ ROOM # 429. | 2/2 | 1200 | 1513 | 193 | 2 | 386 | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos Jofat | DATE: 7-25-02 | TIME: 1707 | RECEIVED FROM TEG DROP BOX (SIGNATURE): Alex 07/25 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH Method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT #: FABRICATOR: A. ENVIROTECH.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106993

NYC 9/11 Public Portal Document

[redacted] PAGE [redacted] OF [redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: STUYVESANT H.S. 20607 | DATE SUBMITTED: 7-25-02 |
| DATE SAMPLED: 7-25-02. | CONTACT: HAMID SAVOJ. | WORK AREA: 4th Floor. | DATE LOGGED: |
| ROTOMETER NO.: TEG - L 18 | PROJECT NO.: H477-15217 / 24881 | PROJECT MANAGER: CHRIS McELROY. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ LUIS AVILA SS# PII<br>OWA ☐ ROOM # 427. | 2/2 | 1201 | 1510 | 189 | 2 | 378 | | | 4 | 4 |
| L-15 | | IWA ☐ ALEXIS BERNAL SS# PII<br>OWA ☐ ROOM # 413 | 2/2 | 1203 | 1512 | 189 | 2 | 378 | | | 5 | 5 |
| L-16 | | IWA ☐ MARIA ALVAREZ SS# PII<br>OWA ☐ ROOM # 411. | 2/2 | 1204 | 1509 | 185 | 2 | 370 | | | 4.1 | 4.5 |
| FB1 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | <4.1 | <4.5 |
| FB2 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos Jofat | DATE: 7-25-02 | TIME: 1702 | RECEIVED FROM TEG DROP BOX (SIGNATURE): A Ch 07/25 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH Method 7082. | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER Lead.

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-26-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
4th Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-25-02
**DATE RECEIVED:** 07-25-02
**DATE ANALYZED:** 07-25-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20667 | Beatriz Chavez SS# PII | 12.2 | 4.9 |
| L-02 | 20667 | Bulvia Castillo SS# PII | <4.9 | 4.9 |
| L-03 | 20667 | Bertha Tache SS# PII | 8.7 | 4.9 |
| L-04 | 20667 | Luis Rodriguez SS# PII | <4.8 | 4.8 |
| L-05 | 20667 | David Vivar SS# PII | <4.8 | 4.8 |
| L-06 | 20667 | Luis Avila SS# PII | <4.8 | 4.8 |
| L-07 | 20667 | Alexis Bernal SS# PII | <4.8 | 4.8 |
| L-08 | 20667 | Maria Alvarez SS# PII | <4.9 | 4.9 |
| L-09 | 20667 | Beatriz Chavez SS# PII | 5.1 | 3.8 |
| L-10 | 20667 | Bulvia Castillo SS# PII | 4.6 | 3.8 |
| L-11 | 20667 | Bertha Tache SS# PII | 7.9 | 3.8 |
| L-12 | 20667 | Luis Rodriguez SS# PII | 13.0 | 5.2 |
| L-13 | 20667 | David Vivar SS# PII | <3.9 | 3.9 |
| L-14 | 20667 | Luis Avila SS# PII | 4.4 | 4.0 |
| L-15 | 20667 | Alexis Bernal SS# PII | 5.5 | 4.0 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| L-16 | 20667 | Maria Alvarez SS# PII | <4.1 | 4.1 |
| FB-1 | 20667 | Field Blank | <1.5 µg | 1.5 µg |
| FB-2 | 20667 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Fawls | CLIENT: SCA | SITE ADDRESS: Stuyvesant H. S. | DATE SUBMITTED: 9/24/02 |
| DATE SAMPLED: 7/24/02 | CONTACT: Manny Sanos | WORK AREA: 4th & 5th floors. | DATE LOGGED: 20615 |
| ROTOMETER NO: 16 | PROJECT NO: M479-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: 20615 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☑ OWA ☐ Angel Asmal PII Room 405 | 2.0 / 2.0 | 1202 | 322 | 200 | 2.0 | 400 | | | | <.38 |
| 15 | | IWA ☑ OWA ☐ Wilson Olivo PII Room 401 NORTH | 2.0 / 2.0 | 1206 | 324 | 198 | 2.0 | 396 | | | | <3.8 |
| 16 | | IWA ☑ OWA ☐ Julio Bastidas PII Room 401 East | 2.0 / 2.0 | 1208 | 326 | 198 | 2.0 | 396 | | | | 5.9 |
| 17 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 18 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE): Alex 07/24 Gym | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME: 526PM | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000106997

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-25-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>5th Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-24-02 |
| **DATE RECEIVED:** | 07-24-02 |
| **DATE ANALYZED:** | 07-24-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20615 | Luis Rodrigue SS# PII | <3.3 | 3.3 |
| 02 | 20615 | Marial Ortega SS# PII | 4.5 | 3.3 |
| 03 | 20615 | Miguel Ali SS# PII | 3.7 | 3.3 |
| 04 | 20615 | Angel Narranjo SS# PII | <3.3 | 3.3 |
| 05 | 20615 | Silvio Perez SS# PII | <3.3 | 3.3 |
| 06 | 20615 | Silvia Castilla SS# PII | <4.2 | 4.2 |
| 07 | 20615 | Angel Asmal SS# PII | <4.2 | 4.2 |
| 08 | 20615 | Luis Rodrigue SS# PII | <3.8 | 3.8 |
| 09 | 20615 | Marial Ortega SS# PII | <3.8 | 3.8 |
| 10 | 20615 | Miguel Ali SS# PII | <3.8 | 3.8 |
| 11 | 20615 | Angel Narranjo SS# PII | <3.8 | 3.8 |
| 12 | 20615 | Silvio Perez SS# PII | <3.8 | 3.8 |
| 13 | 20615 | Silvia Castilla SS# PII | 7.5 | 3.8 |
| 14 | 20615 | Angel Asmal SS# PII | <3.8 | 3.8 |
| 15 | 20615 | Wilson Olivio SS# PII | <3.8 | 3.8 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20615 | Julio Bastidas SS# PII | 5.9 | 3.8 |
| 17 | 20615 | Field Blank | <1.5 µg | 1.5 µg |
| 18 | 20615 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H.S. | 7-28-02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7-28-02. | HAMID SAVOY | 3RD FL. | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG - L 18 | M477 - 15.217/29 881 | CHRIS MCELROY | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | FIBERS f/cc (f/ml) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ WILSON OLIVO SS# PII<br>OWA ☐ ROOM# 325 | 2/2 | 0712 | 1125 | 253 | 2 | 506 | | | | <3.0 |
| L-02 | | IWA ☐ LUIS AVILA SS# PII<br>OWA ☐ ROOM # 305 | 2/2 | 0713 | 1126 | 253 | 2 | 506 | | | | <3.0 |
| L-03 | | IWA ☐ SERGIO APOLO SS# PII<br>OWA ☐ ROOM# 303 | 2/2 | 0714 | 1127 | 253 | 2 | 506 | | | | <3.0 |
| L-04 | | IWA ☐ ANGEL NARANJO SS# PII<br>OWA ☐ ROOM# 301A | 2/2 | 0715 | 1128 | 253 | 2 | 506 | | | | <3.0 |
| L-05 | | IWA ☐ WILSON OLIVO SS# PII<br>OWA ☐ ROOM # 325 | | | | VOID | | | | | | |
| L-06 | | IWA ☐ LUIS AVILA SS# PII<br>OWA ☐ ROOM # 305 | 2/2 | 1204 | 1510 | 186 | 2 | 372 | | | | <4.0 |
| L-07 | | IWA ☐ SERGIO APOLO SS# PII<br>OWA ☐ ROOM # 303 | 2/1 | 1205 | 1509. | 185 | 1.5 | 278 | | | | <5.4 |
| L-08 | | IWA ☐ ANGEL NARANJO SS# PII<br>OWA ☐ ROOM # 301A | 2/2 | 1206 | 1514. | 188 | 2 | 376 | | | | <4.0 |
| L-09 | | IWA ☐<br>OWA ☐ F/13 " | | | | " | | | | | | <1.5 |
| L-10 | | IWA ☐<br>OWA ☐ F/13 " | | | | " | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Carlos Ofelt | 7-27-02 | 1610 | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| | | | R. Broudine | 7.28.02 | 16.15 |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD.

LOT # FILTER MANUFACTURER E. Express

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-29-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
3rd Floor

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-28-02
DATE RECEIVED: 07-28-02
DATE ANALYZED: 07-28-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20723 | Wilson Olivo SS# PII | <3.0 | 3.0 |
| L-02 | 20723 | Luis Avila SS# PII | <3.0 | 3.0 |
| L-03 | 20723 | Sergio Apolo S# PII | <3.0 | 3.0 |
| L-04 | 20723 | Angel Naranjo SS# PII | <3.0 | 3.0 |
| L-06 | 20723 | Luis Avila SS# PII | <4.0 | 4.0 |
| L-07 | 20723 | Sergio Apolo S# PII | <5.4 | 5.4 |
| L-08 | 20723 | Angel Naranjo SS# PII | <4.0 | 4.0 |
| L-09 | 20723 | Field Blank | <1.5 µg | 1.5 µg |
| L-10 | 20723 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC-WTC_000107001

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: TERENCE MICHAELOUK | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT HS CHAMBERS ST. NY NY | DATE SUBMITTED: 07.28.02 |
| DATE SAMPLED: 07.28.02 | CONTACT: HAMID SHAWQ | WORK AREA: 3rd FLOOR # 20727 | DATE LOGGED: |
| ROTOMETER NO: TEG L-16 | PROJECT NO: M477-15217 /20,881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ VICTOR FAJARDO RM 313<br>OWA ☐ SS # PII | 2 / 2 | 16.00 | 19.30 | 210 | 2 | 420 | | | | |
| 02 | | IWA ☐ VICTOR FAJARDO RM 313<br>OWA ☐ SS # PII | 2 / 2 | 20.00 | 23.00 | 180 | 2 | 360 | | | | |
| 03 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| 04 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): TerenceMichaelouk | DATE: 07.28.02 | TIME: 24.30 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): TerenceMichaelouk | DATE: 07.29.02 | TIME: 1.00 | RECEIVED BY (SIGNATURE): TERENCE MICHAELOUK J. | DATE: 7/29/2 | TIME: |
| ANALYST: (SIGNATURE): | DATE: | TIME: | COMMENTS: 12 HRS TAT NIOSH METHOD 7082 | | |

CIRCLE: PCM TEM

BORO PRE DURING POST

OSHA OTHER LEAD

LOT # 13782 FILTER MANUFACTURER ENVI. EXP.

NYC-WTC_000107002

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-29-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>3rd Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-28-02 |
| **DATE RECEIVED:** | 07-29-02 |
| **DATE ANALYZED:** | 07-29-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20727 | Victor Fajardo SS# PII | <3.6 | 3.6 |
| 02 | 20727 | Victor Fajardo SS# PII | <4.2 | 4.2 |
| 03 | 20727 | Field Blank | <1.5 µg | 1.5 µg |
| 04 | 20727 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879). (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted]

TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD — PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: N.Y.C SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/27/02 |
| DATE SAMPLED: 7/26/02 | CONTACT: | WORK AREA: Floor 3, 8, + 9 | DATE LOGGED: |
| ROTOMETER NO.: L-18 | PROJECT NO: M477-15217 / 29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | Fiber f/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Nube PII<br>OWA ☐ Gallegos Rm 329 | Z / 2 | 1600 | 1930 | 210 | 2 | 420 | | | | <3.6 |
| 02 | | IWA ☐ Jose PII<br>OWA ☐ Gamposerde Rm 333 | Z / 2 | 1602 | 1932 | 210 | 2 | 420 | | | | <3.6 |
| 03 | | IWA ☐ Justo PII<br>OWA ☐ Calle Rm 335 | Z / 2 | 1604 | 1934 | 210 | 2 | 420 | | | | <3.6 |
| 04 | | IWA ☐ Luis PII<br>OWA ☐ Naranjo Rm 802 | Z / 2 | 1606 | 1936 | 210 | 2 | 420 | | | | <3.6 |
| 05 | | IWA ☐ Juan PII<br>OWA ☐ Sanchez Rm 807 | Z / 2 | 1608 | 1938 | 210 | 2 | 420 | | | | <3.6 |
| 06 | | IWA ☐ Raul PII<br>OWA ☐ Naranjo Rm 817 | Z / 2 | 1610 | 1940 | 210 | 2 | 420 | | | | <3.6 |
| 07 | | IWA ☐ Alsivan PII<br>OWA ☐ Naranjo Rm 327 | Z / 2 | 1612 | 1942 | 210 | 2 | 420 | | | | <3.6 |
| 08 | | IWA ☐ Lady PII<br>OWA ☐ Parra Rm 337 | Z / 2 | 1614 | 1944 | 210 | 2 | 420 | | | | <3.6 |
| 09 | | IWA ☐ Romulo PII<br>OWA ☐ Quizpi Rm 911 | Z / 2 | 1616 | 1946 | 210 | 2 | 420 | | | | <3.6 |
| 10 | | IWA ☐ Lucyna PII<br>OWA ☐ Foremska Rm 926 | Z / 2 | 1618 | 1948 | 210 | 2 | 420 | | | | <3.6 |
| 11 | | IWA ☐ Angel PII<br>OWA ☐ Suquencio Rm 339 | Z / 2 | 1620 | 1950 | 210 | 2 | 420 | | | | <3.6 |
| 12 | | IWA ☐ Nube PII<br>OWA ☐ Gallegos Rm 327 | Z / 2 | 2000 | 0000 | 240 | 2 | 480 | | | | <3.1 |
| 13 | | IWA ☐ Jose PII<br>OWA ☐ Gamposerde Rm 333 | Z / 2 | 2002 | 0002 | 240 | 2 | 480 | | | | <3.1 |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | | | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | 7/27/02 | 0030 | RECEIVED BY: (SIGNATURE) R. Stroudina | 7/27/02 | 03.00 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

[redacted] PAGE [redacted] OF [redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: N.Y.C SCA | SITE ADDRESS: Stuyvesant HS | DATE SUBMITTED: 7/27/02 |
| DATE SAMPLED: 7/26/02 | CONTACT: | WORK AREA: Floor 3, 8, 9 | DATE LOGGED: |
| ROTOMETER NO.: L-18 | PROJECT NO.: M477-15217/29881 | PROJECT MANAGER: Chris McElyea | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ Josefo Calle PII Rm 335<br>OWA ☐ ~~Gamaporeda~~ | 2/2 | 2004 | 0004 | 240 | 2 | 480 | | | | <3.1 |
| 15 | | IWA ☐ Luis PII<br>OWA ☐ Naranja Rm 802 | 2/2 | 2006 | 0006 | 240 | 2 | 480 | | | | <3.1 |
| 16 | | IWA ☐ Juan PII<br>OWA ☐ Sanchez Rm 807 | 2/2 | 2008 | 0008 | 240 | 2 | 480 | | | | <3.1 |
| 17 | | IWA ☐ Raul PII<br>OWA ☐ Naranjo Rm 817 | 2/2 | 2010 | 0010 | 240 | 2 | 480 | | | | <3.1 |
| 18 | | IWA ☐ Alsivan PII<br>OWA ☐ Naranjo Rm 327 | 2/2 | 2012 | 0012 | 240 | 2 | 480 | | | | <3.1 |
| 19 | | IWA ☐ Lady PII<br>OWA ☐ Parra Rm 337 | 2/2 | 2014 | 0014 | 240 | 2 | 480 | | | | <3.1 |
| 20 | | IWA ☐ Romulo PII<br>OWA ☐ Quizhpi Rm 911 | 2/2 | 2016 | 0016 | 240 | 2 | 480 | | | | <3.1 |
| 21 | | IWA ☐ Lucyna PII<br>OWA ☐ Foremska Rm 925 | 2/2 | 2018 | 0018 | 240 | 2 | 480 | | | | <3.1 |
| 22 | | IWA ☐ Angel PII<br>OWA ☐ Suquen Cio Rm 339 | 2/2 | 2020 | 0020 | 240 | 2 | 480 | | | | <3.1 |
| FB-23 | | IWA ☐<br>OWA ☐ FB-23 | | | | | | | | | | <1.5 |
| FB-24 | | IWA ☐<br>OWA ☐ FB-24 | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | | | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY (SIGNATURE): Gary McKenzie | 7/27/02 | 0030 | RECEIVED BY (SIGNATURE): R. Arguelina | 7.27.02 | 03.00 |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS: / | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — DSHA — other Mold Test 582

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-29-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>3rd, 8th & 9th floors |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-27-02 |
| **DATE RECEIVED:** | 07-27-02 |
| **DATE ANALYZED:** | 07-27-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20699 | Nube Gallegos SS# PII | <3.6 | 3.6 |
| 02 | 20699 | Jose Gampoverde SS# PII | <3.6 | 3.6 |
| 03 | 20699 | Justo Calle SS# PII | <3.6 | 3.6 |
| 04 | 20699 | Luis Nanrango SS# PII | <3.6 | 3.6 |
| 05 | 20699 | Juan Sanchez SS# PII | <3.6 | 3.6 |
| 06 | 20699 | Raul Naranjo SS# PII | <3.6 | 3.6 |
| 07 | 20699 | Alsivan Naranjo SS# PII | <3.6 | 3.6 |
| 08 | 20699 | Lady Parra SS# PII | <3.6 | 3.6 |
| 09 | 20699 | Romulo Guiznpi SS# PII | <3.6 | 3.6 |
| 10 | 20699 | Lucyna Foremska SS# PII | <3.6 | 3.6 |
| 11 | 20699 | Angel Sugvencio SS# PII | <3.1 | 3.1 |
| 12 | 20699 | Nube Gallegos SS# PII | <3.1 | 3.1 |
| 13 | 20699 | Jose Gampoverde SS# PII | <3.1 | 3.1 |
| 14 | 20699 | Justo Calle SS# PII | <3.1 | 3.1 |
| 15 | 20699 | Luis Nanrango SS# PII | <3.1 | 3.1 |
| 16 | 20699 | Juan Sanchez SS# PII | | |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 17 | 20699 | Raul Naranjo SS# PII | <3.1 | 3.1 |
| 18 | 20699 | Alsivan Naranjo SS# PII | <3.1 | 3.1 |
| 19 | 20699 | Lady Parra SS# PII | <3.1 | 3.1 |
| 20 | 20699 | Romulo Guiznpi SS# PII | <3.1 | 3.1 |
| 21 | 20699 | Lucyna Foremska SS PII | <3.1 | 3.1 |
| 22 | 20699 | Angel Sugvencio SS# PII | <3.1 | 3.1 |
| FB-23 | 20699 | Field Blank | <1.5 µg | 1.5 µg |
| FB-24 | 20699 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CARLOS JOFAT | NYC SCA. | STUYVESANT H.S. | 7-27-02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7-27-02 | HAMID SAUOJ. | 9th ; 8th ; 3rd | |
| ROTOMETER NO. | PROJECT NO | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG L18. | M477-15217/29881 | CHRIS McELOON. | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | Ref Fig 3 EBC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ MARCELO ATIENCIA SS# PII<br>OWA ☐ ROOM # 802 A. | 2/2 | 0710 | 1115 | 245 | 2 | 490 | | | | 3.1 |
| L-02 | | IWA ☐ MIGUEL ALI SS# PII<br>OWA ☐ ROOM # 807 | 2/2 | 0711 | 1116 | 245 | 2 | 490 | | | | |
| L-03 | | IWA ☐ LUIS CUZCO SS# PII<br>OWA ☐ ROOM # 817. | 2/2 | 0712 | 1117 | 245 | 2 | 490 | | | | |
| L-04 | | IWA ☐ ANA ALVAREZ SS# PII<br>OWA ☐ ROOM # 329. | 2/2 | 0712 | 1118 | 245 | 2 | 490 | | | | |
| L-05 | | IWA ☐ JAVIER SOLIS SS# PII<br>OWA ☐ ROOM # 911. | 2/2 | 0713 | 1119. | 245 | 2 | 490 | | | | 4 |
| L-06 | | IWA ☐ MARCELO ATIENCIA SS# PII<br>OWA ☐ ROOM # 802A | 2/2 | 1205 | 1505 | 180 | 2 | 360 | | | | 4.2 |
| L-07 | | IWA ☐ MIGUEL ALI SS# PII<br>OWA ☐ ROOM # 1039. | 2/2 | 1206 | 1506 | 180 | 2 | 360 | | | | |
| L-08 | | IWA ☐ LUIS CUZCO SS# PII<br>OWA ☐ ROOM # 817. | 2/2 | 1207 | 1507 | 180 | 2 | 360 | | | | |
| L-09 | | IWA ☐ ANA ALVAREZ SS# PII<br>OWA ☐ ROOM # 329. | 2/2 | 1208 | 1508 | 180 | 2 | 360 | | | | |
| L-10 | | IWA ☐ JAVIER SOLIS SS# PII<br>OWA ☐ ROOM # 911. | 2/2 | 1209. | 1509 | 180 | 2 | 360 | | | | 4 |
| FB 1 | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | 4.5 |
| FB 2. | | IWA ☐<br>OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | 4.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | | | |
| RELINQUISHED BY: (SIGNATURE) Carlos Jofat | DATE 7-27-02 | TIME 1530. | RECEIVED BY: (SIGNATURE) | DATE 7/27/1 | TIME 1600 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER LEAD

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-29-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>9th, 8th, 3rd Floors |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-27-02 |
| **DATE RECEIVED:** | 07-27-02 |
| **DATE ANALYZED:** | 07-27-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20703 | Marcelo Atiencia SS# PII | <3.1 | 3.1 |
| L-02 | 20703 | Miguel Ali SS# PII | <3.1 | 3.1 |
| L-03 | 20703 | Luis Cuzco SS# PII | <3.1 | 3.1 |
| L-04 | 20703 | Ana Alvarez SS# PII | <3.1 | 3.1 |
| L-05 | 20703 | Javier Solis SS# PII | <3.1 | 3.1 |
| L-06 | 20703 | Marcelo Atiencia SS# PII | <4.2 | 4.2 |
| L-07 | 20703 | Miguel Ali SS# PII | <4.2 | 4.2 |
| L-08 | 20703 | Luis Cuzco SS# PII | <4.2 | 4.2 |
| L-09 | 20703 | Ana Alvarez SS# PII | <4.2 | 4.2 |
| L- 10 | 20703 | Javier Solis SS# PII | <4.2 | 4.2 |
| FB-11 | 20703 | Field Blank | <1.5 µg | 1.5 µg |
| FB-12 | 20703 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**

NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.

NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

[redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 7/27/02 |
| DATE SAMPLED: 7/27/02 | CONTACT: | WORK AREA: 3rd & 10th floors | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M479-1527 | PROJECT MANAGER: Chris McFeeley | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | ng/m³ F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☑ OWA ☐ ~~Dafter~~ Jose Velez room 325 PII | 2.0 / 2.0 | 410 pm | 720 pm | 190 | 2.0 | 380 | | | | <3.9 |
| 2 | | IWA ☑ OWA ☐ Antonio Cuzco room 327 PII | 2.0 / 2.0 | 412 pm | 722 pm | 190 | 2.0 | 380 | | | | <3.9 |
| 3 | | IWA ☑ OWA ☐ Victor Fachado room 335 PII | 2.0 / 2.0 | 414 pm | 724 pm | 190 | 2.0 | 380 | | | | <3.9 |
| 4 | | IWA ☑ OWA ☐ Henry Avila room 337 PII | 2.0 / 2.0 | 416 pm | 726 pm | 190 | 2.0 | 380 | | | | <3.9 |
| 5 | | IWA ☑ OWA ☐ Edwin Sarmient room 339 PII | 2.0 / 2.0 | 418 pm | 728 pm | 190 | 2.0 | 380 | | | | <3.9 |
| 6 | | IWA ☑ OWA ☑ Jose Velez room 325 PII | 2.0 / 2.0 | 800 pm | 1130 pm | 210 | 2.0 | 420 | | | | <3.6 |
| 7 | | IWA ☑ OWA ☐ Antonio Cuzco room 327 PII | 2.0 / 2.0 | 802 pm | 1132 pm | 210 | 2.0 | 420 | | | | <3.6 |
| 8 | | IWA ☑ OWA ☐ Victor Fachado room 335 PII | 2.0 / 2.0 | 804 pm | 1134 pm | 210 | 2.0 | 420 | | | | <3.6 |
| 9 | | IWA ☑ OWA ☐ Henry Avila room 337 PII | 2.0 / 2.0 | 806 pm | 1136 pm | 210 | 2.0 | 420 | | | | <3.6 |
| 10 | | IWA ☑ OWA ☐ Edwin Sarmient room 339 PII | 2.0 / 2.0 | 808 pm | 1138 pm | 210 | 2.0 | 420 | | | | <3.6 |
| 11 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 12 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | 2077 | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): [signature] | DATE: 7/27/02 | TIME: | RECEIVED FROM TEG DROP BOX (SIGNATURE): [signature] at ATC | DATE: 7/28/02 | TIME: 600 |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12Hour Turnaround | | |

CIRCLE: PCM TEM BGRD FRE DURING POST OSHA OTHER NEOSH 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-29-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>3rd & 10th Floors |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-27-02 |
| **DATE RECEIVED:** | 07-27-02 |
| **DATE ANALYZED:** | 07-27-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 1 | 20717 | Jose Velez SS# PII | <3.9 | 3.9 |
| 2 | 20717 | Antonio Cuzco SS# PII | <3.9 | 3.9 |
| 3 | 20717 | Victor Farjado SS# PII | <3.9 | 3.9 |
| 4 | 20717 | Henry Avila SS# PII | <3.9 | 3.9 |
| 5 | 20717 | Edwin Sarmient SS# PII | <3.9 | 3.9 |
| 6 | 20717 | Jose Velez SS# PII | <3.6 | 3.6 |
| 7 | 20717 | Antonio Cuzco SS# PII | <3.6 | 3.6 |
| 8 | 20717 | Victor Farjado SS# PII | <3.6 | 3.6 |
| 9 | 20717 | Henry Avila SS# PII | <3.6 | 3.6 |
| 10 | 20717 | Edwin Sarmient SS# PII | <3.6 | 3.6 |
| 11 | 20717 | Field Blank | <1.5 µg | 1.5 µg |
| 12 | 20717 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC-WTC_000107012

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE ____ OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plonski | CLIENT: NYCSCA | SITE ADDRESS: 350 Chambers St | DATE SUBMITTED: |
| DATE SAMPLED: 7.25.02 | CONTACT: H. Savoj | WORK AREA: 4th fl, 3rd, # 20673 | DATE LOGGED: |
| ROTAMETER NO: L-18 | PROJECT NO: M-477-15217-29881 | PROJECT MANAGER: Ch. McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L01 | | IWA ☐ OWA ☐ Justo Calle clrm 450 PII | 2/2 | 16²⁴ | 19²⁶ | 182 | 2 | 364 | | | | |
| L02 | | IWA ☐ OWA ☐ Jose Vivar clrm 451 PII | 2/2 | 16²² | 19²⁸ | 186 | 2 | 372 | | | | |
| L03 | | IWA ☐ OWA ☐ Victor Calle clrm 439 PII | 2/2 | 16²³ | 19²⁹ | 189 | 2 | 378 | | | | |
| L04 | | IWA ☐ OWA ☐ Juan Sanchez clrm 437 PII | 2/2 | 16¹⁷ | 19³¹ | 194 | 2 | 388 | | | | |
| L05 | | IWA ☐ OWA ☐ Raul Naranjo clrm 435 PII | 2/2 | 16¹⁵ | 19³² | 197 | 2 | 394 | | | | |
| L06 | | IWA ☐ OWA ☐ Victor Fajardo clrm 433 PII | 2/2 | 16¹³ | 19³³ | 200 | 2 | 400 | | | | |
| L07 | | IWA ☐ OWA ☐ Buslawski Stanislaw clrm 307 PII | 2/2 | 16²⁹ | 19³⁴ | 185 | 2 | 370 | | | | |
| L08 | | IWA ☐ OWA ☐ Liliana Cardenas clrm 315 PII | 2/2 | 16³² | 19³⁶ | 183 | 2 | 366 | | | | |
| L09 | | IWA ☐ OWA ☐ Justo Calle clrm 450 PII | 2/2 | 20⁰⁹ | 23³⁶ | 207 | 2 | 414 | | | | |
| L10 | | IWA ☐ OWA ☐ Jose Vivar clrm ~~451~~ 407 PII | 2/2 | 20¹⁰ | 23³⁸ | 208 | 2 | 416 | | | | |
| L11 | | IWA ☐ OWA ☐ Victor Calle clrm 439 PII | 2/2 | 20¹² | 23⁴¹⁰ | 208 | 2 | 416 | | | | |
| L12 | | IWA ☐ OWA ☐ Juan Sanchez clrm 437 PII | 2/2 | 20¹³ | 23⁴¹ | 208 | 2 | 416 | | | | |
| L13 | | IWA ☐ OWA ☐ Raul Naranjo clrm 435 PII | 2/2 | 20¹⁵ | 23⁴² | 207 | 2 | 414 | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): W Plonski | 7.26.02 | 1AM | RECEIVED FROM TEG DROP BOX (SIGNATURE): | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE): I 2 | DATE: 7/26/02 | TIME: 9am |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS: 12 hour T/A NIOSH 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER

LOT#

FILTER MANUFACTURER

NYC-WTC_000107013

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE ____ OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plonka | CLIENT: NYCSCA | SITE ADDRESS: 345 Chambers St Stuyvesant HS. | DATE SUBMITTED: |
| DATE SAMPLED: 7.25.02 | CONTACT: H. Salvi | WORK AREA: 4th Floor #20673 | DATE LOGGED: |
| ROTOMETER NO.: L-18 | PROJECT NO.: M-477-15217-29881 | PROJECT MANAGER: Ch. Mc Elgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L 14 | | IWA ☐ OWA ☐ Victor Fajardo c/rm 433 PII | 2/2 | 20⁰⁷ | 23⁴⁵ | 208 | 2 | 416 | | | | |
| L15 | | IWA ☐ OWA ☐ Buslowski Stanislaw c/rm 307 PII | 2/2 | 20⁰⁷ | 23⁴⁶ | 219 | 2 | 438 | | | | |
| L16 | | IWA ☐ OWA ☐ Liliana Cardenas PII | 2/2 | 20¹⁹ | 23⁴⁷ | 208 | 2 | 416 | | | | |
| FB1 | | IWA ☐ OWA ☐ field blank | | | | | | | | | | |
| FB2 | | IWA ☐ OWA ☐ field blank | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): CW | DATE: 7/26 | TIME: 1AM | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY (SIGNATURE): | DATE: | TIME: | RECEIVED BY: (SIGNATURE): | DATE: 7/26/2 | TIME: 9a |
| ANALYST (SIGNATURE): | DATE: | TIME: | COMMENTS: 12 hour t/a NIOSH 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Sampler ORANGE: Site Copy

NYC-WTC_000107014

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-26-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>4th Floor & 3 Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-25-02 |
| **DATE RECEIVED:** | 07-25-02 |
| **DATE ANALYZED:** | 07-25-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20673 | Justo Calle SS# PII | 5.4 | 4.1 |
| L-02 | 20673 | Jose Vivar SS# PII | 5.4 | 4.0 |
| L-03 | 20673 | Victor Calle SS# PII | <4.0 | 4.0 |
| L-04 | 20673 | Juan Sanches SS# PII | 4.8 | 3.9 |
| L-05 | 20673 | Raul Naranjo SS# PII | <3.8 | 3.8 |
| L-06 | 20673 | Victor Fajordo SS# PII | 2.9 | 3.8 |
| L-07 | 20673 | Buslowski Stanislaw SS# PII | 4.1 | 4.1 |
| L-08 | 20673 | Liliana Cardenos sS# PII | <4.1 | 4.1 |
| L-09 | 20673 | Justo Calle SS# PII | <3.6 | 3.6 |
| L-10 | 20673 | Josc Vivar SS# PII | <3.6 | 3.6 |
| L-11 | 20673 | Victor Calle SS# PII | <3.6 | 3.6 |
| L-12 | 20673 | Juan Sanches SS# PII | <3.6 | 3.6 |
| L-13 | 20673 | Raul Naranjo SS# PII | <3.6 | 3.6 |
| L-14 | 20673 | Victor Fajordo SS# PII | <3.6 | 3.6 |
| L-15 | 20673 | Buslowski Stanislaw SS# PII | <3.4 | 3.4 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| L-16 | 20673 | Liliana Cardenos sS# PII | <3.6 | 3.6 |
| FB-1 | 20673 | Field Blank | <1.5 µg | 1.5 µg |
| FB-2 | 20673 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

**CERTIFICATION AND SIGNATURES**

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: STUYVESANT H.S. 20693 | DATE SUBMITTED: 7-26-02 |
| DATE SAMPLED: 7-26-02. | CONTACT: HAMID SAVOJ | WORK AREA: 9th; 8th; 3rd; 4th floors | DATE LOGGED: |
| ROTOMETER NO: TEG L-18 | PROJECT NO: 14477-15217/29881 | PROJECT MANAGER: CHRIS McCLOUD. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ ASHAL ANGEL SS# PII<br>OWA ☐ ROOM # 907. | 2/2 | 0710 | 1115 | 245 | 2 | 490 | | | < 3.1 | < 1.3 |
| L-02 | | IWA ☐ CHAVEZ BEATRIZ SS# PII<br>OWA ☐ ROOM # 802 A | 2/2 | 0711 | 1116 | 245 | 2 | 490 | | | < 3.1 | |
| L-03 | | IWA ☐ ELVIA AHAYA SS# PII<br>OWA ☐ ROOM # 807. | 2/2 | 0712 | 1117 | 245 | 2 | 490 | | | 3.7 | |
| L-04 | | IWA ☐ JORGE NARANJO SS# PII<br>OWA ☐ ROOM # 307 | 2/2 | 0713 | 1118 | 245 | 2 | 490 | | | < 3.1 | |
| L-05 | | IWA ☐ MARISOL SERNA SS# PII<br>OWA ☐ ROOM # 315 | 2/2 | 0714 | 1119 | 245 | 2 | 490 | | | 6.3 | |
| L-06 | | IWA ☐ JULIO BASTIDAS SS# PII<br>OWA ☐ ROOM # 435 | 2/2 | 0715 | 1120 | 245 | 2 | 490 | | | 2.6 | |
| L-07. | | IWA ☐ SILVIO PEREZ SS# PII<br>OWA ☐ ROOM # 450. | 2/2 | 0716 | 1121 | 245 | 2 | 490 | | | < 3.1 | |
| L-08 | | IWA ☐ ASHAL ANGEL SS# PII<br>OWA ☐ ROOM # 907 | 2/2 | 1202 | 1530 | 198 | 2 | 396 | | | 10.6 | |
| L-09 | | IWA ☐ CHAVEZ BEATRIZ SS# PII<br>OWA ☐ ROOM # 817 | 2/1 | 1203 | 1521 | 198 | 1.5 | 297 | | | < 5.1 | |
| L-10 | | IWA ☐ ELVIA AHAYA SS# PII<br>OWA ☐ ROOM # 807 | 2/2 | 1204 | 1522 | 198 | 2 | 396 | | | 4.4 | |
| L-11 | | IWA ☐ JORGE NARANJO SS# PII<br>OWA ☐ ROOM # 307. | 2/1 | 1205 | 1523 | 198 | 1.5 | 297 | | | < 5.1 | |
| L-12 | | IWA ☐ MARISOL SERNA SS# PII<br>OWA ☐ ROOM # 1017 A. | 2/1 | 1206 | 1524 | 198 | 1.5 | 297 | | | < 5.1 | |
| L-13 | | IWA ☐ JULIO BASTIDAS PII<br>OWA ☐ ROOM # 802 A. | 2/2 | 1207 | 1525 | 198 | 2 | 396 | | | < 3.8 | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED BY: (SIGNATURE) Mary McHenry | DATE 7/26/02 | TIME 1930 | RECEIVED FROM TEG DROP BOX (SIGNATURE) 7/26/02 | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Carlos Jofat | DATE 7-26-02 | TIME 1600 | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: NIOSH Method -7062 (12 Hour TAT) | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER LEAD

LOT # FILTER MANUFACTURER C. EXPRESS

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107017

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: CARLOS JOFAT | CLIENT: NYC SCA. | SITE ADDRESS: STUYVESANT H.S 20693 | DATE SUBMITTED: 7-26-02. |
| DATE SAMPLED: 7-26-02. | CONTACT: HAMID SAVOJ | WORK AREA: 9th ; 8th & 3rd FL. | DATE LOGGED: |
| ROTOMETER NO: TEG-L 18. | PROJECT NO.: A477-15217 / 29881 | PROJECT MANAGER: CHRIS McGLOUN. | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-14 | | IWA ☐ SILVIO PEREZ SS# PII OWA ☐ ROOM # 807. | 2 / 1 | 1108 | 1526 | 198 | 1.5 | 297. | | | | <.51 |
| FB 2 | | IWA ☐ OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | <.05 |
| FB 2 | | IWA ☐ OWA ☐ FIELD BLANK | | — | — | — | — | — | | | | <.05 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Tony Mchugh | DATE: 7/26/02 | TIME: 1930 | RECEIVED FROM TEG DROP BOX (SIGNATURE): ACh 07/26 Ojeru | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) Carlos Ojeru Jofat | DATE: 7-26-02 | TIME: 1600 | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH Method 7082 (12 Hour TAT) | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER LEAD

LOT # FILTER MANUFACTURER: E-Z PLESS

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-29-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
8th, 9th, 3rd & 4th floors

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-26-02
**DATE RECEIVED:** 07-26-02
**DATE ANALYZED:** 07-26-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-1 | 20693 | Asmal. Angel SS# PII | <3.1 | 3.1 |
| L-2 | 20693 | Chavez Beatriz SS# PII | <3.1 | 3.1 |
| L-3 | 20693 | Elvia Ahaya SS# PII | 3.7 | 3.1 |
| L-4 | 20693 | Jorce Naranjo SS# PII | <3.1 | 3.1 |
| L-5 | 20693 | Marisol Serna SS# PII | 6.3 | 3.1 |
| L-6 | 20693 | Julio Bastidas SS# PII | 2.6 | 3.1 |
| L-7 | 20693 | Silvio Pere SS# PII | <3.1 | 3.1 |
| L-8 | 20693 | Asmal. Angel SS# PII | 10.6 | 3.8 |
| L-9 | 20693 | Chavez Beatriz SS# PII | <5.1 | 5.1 |
| L-10 | 20693 | Elvia Ahaya SS# PII | 4.4 | 3.8 |
| L-11 | 20693 | Jorce Naranjo SS# PII | <5.1 | 5.1 |
| L-12 | 20693 | Marisol Serna SS# PII | <5.1 | 5.1 |
| L-13 | 20693 | Julio Bastidas SS# PII | <3.8 | 3.8 |
| L-14 | 20693 | Silvio Pere SS# PII | <5.1 | 5.1 |
| FB-1 | 20693 | Field Blank | <1.5 µg | 1.5 µg |
| FB-2 | 20693 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: VCH

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#20823 PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plonski | CLIENT: NYC SCA | SITE ADDRESS: 345 Chambers St Stuyvesant HS | DATE SUBMITTED: 8/1/02 |
| DATE SAMPLED: 7.31.02 | CONTACT: H. Savoj | WORK AREA: 6th floor | DATE LOGGED: |
| ROTOMETER NO: L-18 | PROJECT NO.: M-477-15217-29891 | PROJECT MANAGER: Ch. McElqui | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ Luis Rodriguez OWA ☐ Library - across Microfilm computers | 2/2 | 1600 | 1920 | 200 | 2 | 400 | | | | |
| L-02 | | IWA ☐ Rigoberto Cortes OWA ☐ Library - across circulation desk | 2/2 | 1601 | 1924 | 203 | 2 | 406 | | | | |
| L-03 | | IWA ☐ Raul Lopez OWA ☐ Library by maps section | 2/2 | 1602 | 1922 | 200 | 2 | 400 | | | | |
| L-04 | | IWA ☐ Rosalio Calle PII OWA ☐ rm 615E | 2/2 | 1604 | 1926 | 202 | 2 | 404 | | | | |
| L 05 | | IWA ☐ Luis Rodriguez OWA ☐ Library - across Microfilm computers | 2 | 2003 | 2326 | 203 | 2 | 406 | | | | |
| L-06 | | IWA ☐ Romulo Calle PII OWA ☐ rm 615 E | 2/2 | 2004 | 2324 | 200 | 2 | 400 | | | | |
| L-07 | | IWA ☐ Raul Lopez OWA ☐ in library - by maps section | 2 | 2005 | 2332 | 207 | 2 | 414 | | | | |
| L-08 | | IWA ☐ OWA ☐ field blank | | | | | | | | | | |
| L-09 | | IWA ☐ OWA ☐ field blank | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 8.1.02 | TIME: 0030 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE: 8/01/02 | TIME: 9:00 am |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/1/02 | TIME: 0100 | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: 12h. t/a NIOSH - 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples

NYC-WTC_000107021

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 08-01-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
6th Floor - Library

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 08-01-02
**DATE RECEIVED:** 08-01-02
**DATE ANALYZED:** 08-01-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20823 | Luis Rodriguez Library - Accross Microfilm Computer | <3.8 | 3.8 |
| L-02 | 20823 | Rigoberto Contas Library - Across Circulation Desk | <3.7 | 3.7 |
| L-03 | 20823 | Roul Loja Library by Maps Section | <3.8 | 3.8 |
| L-04 | 20823 | Ronaldo Calle SS# PII in 615E | <3.7 | 3.7 |
| L-05 | 20823 | Luis Rodriguez Library - Accross Microfilm Computer | <3.7 | 3.7 |
| L-06 | 20823 | Romulo Calle SS# PII Rm 615E | <3.8 | 3.8 |
| L-07 | 20823 | Raul Loja in Library by Maps Section | <3.6 | 3.6 |
| L-08 | 20823 | Field Blank | <1.5 µg | 1.5 µg |
| L-09 | 20823 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted]

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#2W823 PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: W. Plonsky | CLIENT: NYC SCA | SITE ADDRESS: 345 Chambers St Stuyvesant HS | DATE SUBMITTED: 8/1/02 |
| DATE SAMPLED: 7.31.02 | CONTACT: H. Savoj | WORK AREA: 6th floor | DATE LOGGED: |
| ROTOMETER NO: L-18 | PROJECT NO: M-477-15217-29891 | PROJECT MANAGER: Ch. McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| L-01 | | IWA ☐ Luis Rodriguez<br>OWA ☐ Library - across Microfilm computers | 2/2 | 16⁰⁰ | 19²⁰ | 200 | 2 | 400 | | | | |
| L-02 | | IWA ☐ Rigoberta Condes<br>OWA ☐ Library - across circulation desk | 2/2 | 16⁰¹ | 19²⁴ | 203 | 2 | 406 | | | | |
| L-03 | | IWA ☐ Raul Lopa<br>OWA ☐ Library by maps section | 2/2 | 16⁰² | 19²² | 200 | 2 | 400 | | | | |
| L-04 | | IWA ☐ Rondulo Calle PII<br>OWA ☐ rm 615E | 2/2 | 16⁰⁴ | 19¹⁶ | 202 | 2 | 404 | | | | |
| L-05 | | IWA ☐ Luis Rodriguez<br>OWA ☐ Library - across Microfilm computers | 2 | 20⁰³ | 23²⁶ | 203 | 2 | 406 | | | | |
| L-06 | | IWA ☐ Rondulo Calle PII<br>OWA ☐ rm 615 E | 2/2 | 20⁰⁴ | 23²⁴ | 200 | 2 | 400 | | | | |
| L-07 | | IWA ☐ Raul Lopa<br>OWA ☐ in library - by maps section | 2 | 20⁰⁵ | 23³² | 207 | 2 | 414 | | | | |
| L-08 | | IWA ☐<br>OWA ☐ field blank | ✓ | | | | | | | | | |
| L-09 | | IWA ☐<br>OWA ☐ field blank | ✓ | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 8.1.02 | TIME: | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE: 8/01/02 | TIME: 9:00 am |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/1/02 | TIME: 0100 | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: 12h. t/a NIOSH - 7082 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 08-01-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
6th Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 08-01-02
**DATE RECEIVED:** 08-01-02
**DATE ANALYZED:** 08-01-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| L-01 | 20823 | Luis Rodriguez Library - Accross Microfilm Computer | <3.8 | 3.8 |
| L-02 | 20823 | Rigoberto Contas Library - Across Circulation Desk | <3.7 | 3.7 |
| L-03 | 20823 | Roul Loja Library by Maps Section | <3.8 | 3.8 |
| L-04 | 20823 | Ronaldo Calle SS# PII in 615E | <3.7 | 3.7 |
| L-05 | 20823 | Luis Rodriguez Library - Accross Microfilm Computer | <3.7 | 3.7 |
| L-06 | 20823 | Romulo Calle SS# PII Rm 615E | <3.8 | 3.8 |
| L-07 | 20823 | Raul Loja in Library by Maps Section | <3.6 | 3.6 |
| L-08 | 20823 | Field Blank | <1.5 µg | 1.5 µg |
| L-09 | 20823 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

Holiday — PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 8/6/02 |
| DATE SAMPLED: 8/5/02 | CONTACT: | WORK AREA: Room 351 | DATE LOGGED: |
| ROTOVETER NO: L-16 | PROJECT NO: M477-15217 / 29881 | PROJECT MANAGER: Chris McElroy | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC July 2nd 3 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Pablo Urgiles PII Rm 351 / OWA ☐ | 2/2 | 1200 | 1530 | 210 | 2 | 420 | | | | <3.6 |
| 02 | | IWA ☐ Victor Fajardo PII Rm 351 / OWA ☐ | 2/2 | 1600 | 1930 | 210 | 2 | 420 | | | | <3.6 |
| 03 | | IWA ☐ Jose Campoverdo PII Rm 373 / OWA ☐ | 2/2 | 1602 | 1932 | 210 | 2 | 420 | | | | <3.6 |
| 04 | | IWA ☐ Victor Fajardo PII Rm 351 / OWA ☐ | 2/2 | 2000 | 0000 | 240 | 2 | 480 | | | | <3.1 |
| 05 | | IWA ☐ Jose Campoverdo PII Rm 373 / OWA ☐ | 2/2 | 2002 | 0002 | 240 | 2 | 480 | | | | <3.1 |
| FB-6 | | IWA ☐ / OWA ☐ FB-6 | | | | | | | | | | <1.5 |
| FB-7 | | IWA ☐ / OWA ☐ FB-7 | | | | | | | | | | <1.5 |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Gary Mck | DATE: 8/6/02 | TIME: | RECEIVED FROM TEG DROP BOX (SIGNATURE): Kiz | DATE: 08-06-02 | TIME: 9:00 am |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 Hour TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH METHod 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK. Samples ORANGE: Site Copy

NYC-WTC_000107027

NYC 9/11 Public Portal Document

08202105.1F 1 1

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NY. C SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 8/5/02 |
| DATE SAMPLED: 8/2/02 | CONTACT: Hamid Saves | WORK AREA: 4th Floor | DATE LOGGED: |
| ROTOMETER NO: L-16 | PROJECT NO.: 11477-1521 7 / 29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Jose Camposverde PII Rm 402 / OWA ☐ | 2/2 | 1600 | 1930 | 210 | 2 | 420 | | | | |
| 02 | | IWA ☐ Victor Fajardo Rm 450 PII / OWA ☐ | 2/2 | 1602 | 1932 | 210 | 2 | 420 | | | | |
| 03 | | IWA ☐ Jose Camposverde PII Rm 402 / OWA ☐ | 2/2 | 2000 | 0000 | 240 | 2 | 480 | | | | |
| 04 | | IWA ☐ Victor Fajardo PII Rm 450 / OWA ☐ | 2/2 | 2002 | 0002 | 240 | 2 | 480 | | | | |
| 05 | | IWA ☐ Walter Gallegos PII Rm 451 / OWA ☐ | 2/2 | 2004 | 0004 | 240 | 2 | 480 | | | | |
| 06 | | IWA ☐ Edwin Sarmiento PII Rm 453 / OWA ☐ | 2/2 | 2006 | 0006 | 240 | 2 | 480 | | | | |
| FB-7 | | IWA ☐ / OWA ☐ FB-7 | | | | | | | | | | |
| FB-8 | | IWA ☐ / OWA ☐ FB-8 | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEC DROP BOX (SIGNATURE): | DATE: 8/3/02 | TIME: 0050 | RECEIVED FROM TEC DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/3/02 | TIME: 0000 | RECEIVED BY: (SIGNATURE): Javier Quispe@3M Sh. | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: | | |

CIRCLE: PCM TEM — BCAB PRE DURING POST — OSHA — OTHER: NIOSH Method 7082

LOT #:

FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Sampler ORANGE: Site Copy

EMSL-MANHATTAN RECEIVED 02 AUG -3 AM 12:58

EMSL ANALYTICAL INC 08/03/2002 09:00 212-290-2538 PAGE 04/04

NYC-WTC_000107028

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217/29881 / Stuyvesant H.S. NY SCA / 4th Floor

Customer ID: TAYL50
Customer PO:
Received: 08/03/02 12:58 AM
EMSL Order: 030210517
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|
| 01 Jose Campoverde PII PII Rm 402 | 0001 | | 420 L | <9.5 µg/m³ | |
| 02 Victor Fajardo PII PII Rm 450 | 0002 | | 420 L | <9.5 µg/m³ | |
| 03 Jose Campoverde PII PII Rm 402 | 0003 | | 480 L | <8.3 µg/m³ | |
| 04 Victor Fajardo PII PII Rm 450 | 0004 | | 480 L | <8.3 µg/m³ | |
| 05 Walter Guilegos PII PII Rm 451 | 0005 | | 480 L | <8.3 µg/m³ | |
| 06 Edwin Sarmiento PII PII Rm 453 | 0006 | | 480 L | <8.3 µg/m³ | |
| FB7 Field blank 7 | 0007 | | n/a | <4.0 µg/filter | |
| FB8 Field blank 8 | 0008 | | n/a | <4.0 µg/filter | |

Eric B. [illegible]
Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependant on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #1C2581



NYC-WTC_000107029

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers St. | DATE SUBMITTED: 8/3/02 |
| DATE SAMPLED: 8/3/02 | CONTACT: HAMID SAADAT | WORK AREA: 4TH FL. ROOMS. | DATE LOGGED IN: 20394 |
| ROTOMETER NO: 16 | PROJECT NO: M497-152(7 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☑ OWA ☐ Jose Perez room 453 PII | 2.0 / 2.0 | 730 am | 1130 am | 240 | 2.0 | 480 | | | | <3.1 |
| 2 | | IWA ☑ OWA ☐ Angel Asval room 451 PII | 2.0 / 2.0 | 732 am | 1132 am | 240 | 2.0 | 480 | | | | |
| 3 | | IWA ☑ OWA ☐ Jose Perez room 453 PII | 2.0 / 2.0 | 1130 am | 330 pm | 240 | 2.0 | 480 | | | | |
| 4 | | IWA ☑ OWA ☐ Angel Asval room 451 PII | 2.0 / 2.0 | 1132 am | 332 pm | 240 | 2.0 | 480 | | | | |
| 5 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 6 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/3/02 | TIME: 420 | RECEIVED BY (SIGNATURE) | DATE: 8/3/02 | TIME: 16:20 |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS: 12 Hour Turnaround NIOSH 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Field Copy

NYC-WTC_000107030

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 08-05-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 08-03-02
**DATE RECEIVED:** 08-03-02
**DATE ANALYZED:** 08-03-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20894 | Jose Perez SS# PII | <3.1 | 3.1 |
| 02 | 20894 | Angel Asval SS# PII | <3.1 | 3.1 |
| 03 | 20894 | Jose Perez SS# PII | <3.1 | 3.1 |
| 04 | 20894 | Angel Asval SS# PII | <3.1 | 3.1 |
| 05 | 20894 | Field Blank | <1.5 µg | 1.5 µg |
| 06 | 20894 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE/ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 8/4/02 |
| DATE SAMPLED: 8/3/02 | CONTACT: Hamid Sanoi | WORK AREA: 453, 301c | DATE LOGGED: |
| ROTOMETER NO.: L-16 | PROJECT NO.: M477-15217/29881 | PROJECT MANAGER: Chris McElwee | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☐ Richard Avila — PII Rm 301c | Z / Z | 1600 | 1930 | 210 | Z | 420 | | | | |
| 02 | | IWA ☐ OWA ☐ Teresa Bunay — PII Rm 453 | Z / Z | 1603 | 1933 | 210 | Z | 420 | | | | |
| 03 | | IWA ☐ OWA ☐ Raul Lotta — PII Rm 371 | Z / Z | 1780 | 1935 | 155 | Z | 310 | | | | |
| 04 | | IWA ☐ OWA ☐ Richard Avila — PII Rm 301c | Z / Z | 2000 | 0000 | 240 | Z | 480 | | | | |
| 05 | | IWA ☐ OWA ☐ Teresa Bunay — PII Rm 453 | Z / Z | 2002 | 2202 | 120 | Z | 240 | | | | |
| 06 | | IWA ☐ OWA ☐ Raul Lotta — PII Rm 301c | Z / Z | 2004 | 0004 | 240 | Z | 480 | | | | |
| FB-1 | | IWA ☐ OWA ☐ FB-1 | / | | | | | | | | | |
| FB-2 | | IWA ☐ OWA ☐ FB-2 | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 8/4/2 | TIME: 1:00 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/4/02 | TIME: 0000 | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

02 AUG -4 AM 12:05

EMSL HAWTHORNE RECEIVED

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER WTC METHOD 7082

LOT # FILTER MANUFACTURER

08/05/2002 12:10 212-290-2538 EMSL ANALYTICAL INC PAGE 01/01

NYC-WTC_000107033

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217/29881 / NYC SCA / Stuyvesant H.S.

Customer ID: TAYL50
Customer PO:
Received: 08/04/02 12:26 AM
EMSL Order: 030210570
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 01 | Richard Avila PII Rm 301C | 0001 | 8/4/02 | 420 L | <9.5 µg/m³ | |
| 02 | Teresa Bunay PII PII Rm H53 | 0002 | 8/4/02 | 420 L | <9.5 µg/m³ | |
| 03 | Raul Loja PII Rm 371 | 0003 | 8/4/02 | 310 L | <13.0 µg/m³ | |
| 04 | Richard Avila PII Rm 301C | 0004 | 8/4/02 | 480 L | <8.3 µg/m³ | |
| 05 | Teresa Bunay PII PII Rm H53 | 0005 | 8/4/02 | 240 L | <17.0 µg/m³ | |
| 06 | Raul Loja PII Rm 371 | 0006 | 8/4/02 | 480 L | <8.3 µg/m³ | |
| FB7 | Field blank 7 | 0007 | 8/4/02 | n/a | <4.0 µg/filter | |
| FB8 | Field blank 8 | 0008 | 8/4/02 | n/a | <4.0 µg/filter | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581

P w/o QC



NYC-WTC_000107034

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

03021059\

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: NYRON WILLIAMS | CLIENT: SCA | SITE ADDRESS: STUYVESANT HIGH SCHOOL | DATE SUBMITTED: |
| DATE SAMPLED: 08-04-02 | CONTACT: HAMID SAVAJ | WORK AREA: 3RD | DATE LOGGED: |
| ROTOMETER NO: TEG L 16 | PROJECT NO.: M477-15017/29881 | PROJECT MANAGER: CHRIS MCELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ LUIS CUZCO Room 3716 OWA ☐ SS# PII | ☒ ☒ | 07:10 | 11:25 | 255 | 2 | 510 | | | | |
| 02 | | IWA ☐ PABLO URGILES Room 350 OWA ☐ SS# PII | ☒ ☒ | 09:15 | 11:26 | 131 | 2 | 262 | | | | |
| 03 | | IWA ☐ LUIS CUZCO ROOM 3716 OWA ☐ SS# PII | ☒ ☒ | 10:00 | 14:00 | 120 | 2 | 240 | | | | |
| 04 | | IWA ☐ PABLO URGILES ROOM 350 OWA ☐ SS# PII | ☒ ☒ | 10:01 | 15:01 | 180 | 2 | 360 | | | | |
| 05 | | IWA ☐ OWA ☐ FIELD BLANK | ☐ | | | | | | | | | |
| 06 | | IWA ☐ OWA ☐ FIELD BLANK | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |
| | | IWA ☐ OWA ☐ | ☐ | | | | | | | | | |

02 AUG 4 PM 4:04

EMSL ANALYTICAL, INC. RECEIVED

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 8-4-2 | TIME: 16:15 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE: 08-04-02 | TIME: 15:30 |
| RELINQUISHED BY: (SIGNATURE) | DATE: 08-04-02 | TIME: 15:30 | RECEIVED BY: (SIGNATURE) Javier.ulisse@ems1. | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER

LOT # FILTER MANUFACTURER

08/05/2002 09:01 212-290-2538 EMSL ANALYTICAL INC PAGE 05/05

NYC-WTC_000107035

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122800058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15017/29881 / SCA / Stuyvesant High School / 3rd

Customer ID: TAYL50
Customer PO:
Received: 08/04/02 4:04 PM
EMSL Order: 030210591
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|
| 01 Lues Cuzco room 371E / PII | 0001 | | 510 L | 11.0 µg/m³ | |
| 02 Pablo Uniles room 350 / PII | 0002 | | 262 L | <15.0 µg/m³ | |
| 03 Lues Cuzco room 371E / PII | 0003 | | 240 L | <17.0 µg/m³ | |
| 04 Pablo Uniles room 350 / PII | 0004 | | 360 L | 15.0 µg/m³ | |
| 05 Field blank | 0005 | | n/a | µg/g | |
| 06 Field blank | 0006 | | n/a | µg/g | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter The laboratory is not responsible to data reported in ug/cc which is dependant on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581



NYC-WTC_000107036

NYC 9/11 Public Portal Document

[redacted] 0230406810

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McGuire | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H-S | DATE SUBMITTED: 8/5/02 |
| DATE SAMPLED: 8/4/02 | CONTACT: HAMID SAVOY | WORK AREA: 3rd + 8th Floor | DATE LOGGED: |
| ROTAMETER NO: L-18 | PROJECT NO.: M427-15217 / 29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Victor Fajardo PII Rm 350 / OWA ☐ | 2/2 | 1600 | 1930 | 210 | 2 | 420 | | | | |
| 02 | | IWA ☐ Victor Fajardo PII Rm 350 / OWA ☐ | 2/2 | 2000 | 0000 | 240 | 2 | 480 | | | | |
| FB-3 | | IWA ☐ / OWA ☐ FB-3 | | | | | | | | | | |
| FB-4 | | IWA ☐ / OWA ☐ FB-4 | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |
| | | IWA ☐ / OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Gary McGuire | DATE: 8/5/02 | TIME: 0030 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: 12 HOUR TAT | | |

CIRCLE: PCM TEM / BGRD PRE DURING POST / OSHA / OTHER NIOSH METHOD 7400

LOT #:

FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

EMSL MANHATTAN RECEIVED 02 AUG -5 AM 12:31

08/05/2002 09:01 212-290-2538 EMSL ANALYTICAL INC PAGE 02/05

NYC-WTC_000107037

NYC 9/11 Public Portal Document



**EMSL Analytical, inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: NYC SCA/M477-15217/29881/Stuyvesant H.S./3rd & 8th Floor.

Customer ID: TAYL50
Customer PO:
Received: 08/05/02 8:02 AM
EMSL Order: 030210613
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 01 | Victor Fajardo PII PII Rm 350 | 0001 | | 420 L | <9.5 µg/m³ | |
| 02 | Victor Fajardo PII PII Rm 350 | 0002 | | 480 L | <8.3 µg/m³ | |
| FB-3 | FB-3 | 0003 | | n/a | <4.0 µg/filter | |
| FB-4 | FB-4 | 0004 | | n/a | <4.0 µg/filter | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible to data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581



NYC-WTC_000107038

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#40750 PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H-S | DATE SUBMITTED: 8/6/02 |
| DATE SAMPLED: 8/5/02 | CONTACT: Hamid Savoj | WORK AREA: Room 351, 373 | DATE LOGGED: |
| ROTOMETER NO.: L-16 | PROJECT NO.: M477-15217 / 29881 | PROJECT MANAGER: Chris McElwee | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | f/cc 2+3 |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ Pablo PII<br>OWA ☐ Urgiles Rm 351 | 2/2 | 1200 | 1530 | 210 | 2 | 420 | | | | <3.6 |
| 02 | | IWA ☐ Victor PII<br>OWA ☐ Fajardo Rm 351 | 2/2 | 1600 | 1930 | 210 | 2 | 420 | | | | <3.6 |
| 03 | | IWA ☐ Jose PII<br>OWA ☐ Camposverde Rm 373 | 2/2 | 1602 | 1932 | 210 | 2 | 420 | | | | <3.6 |
| 04 | | IWA ☐ Victor PII<br>OWA ☐ Fajardo Rm 351 | 2/2 | 2000 | 0000 | 240 | 2 | 480 | | | | <3.1 |
| 05 | | IWA ☐ Jose PII<br>OWA ☐ Camposverde Rm 373 | 2/2 | 2002 | 0002 | 240 | 2 | 480 | | | | <3.1 |
| FB-6 | | IWA ☐<br>OWA ☐ FB-6 | | | | | | | | | | <1.5 |
| FB-7 | | IWA ☐<br>OWA ☐ FB-7 | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Gary McK | DATE: 8/6/02 | TIME: | RECEIVED FROM TEG DROP BOX (SIGNATURE): Kim | DATE: 08-06-02 | TIME: 9:00 AM |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 Hour TAT | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH METHod 7082

LOT # FIELD MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-07-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
3rd Floor

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 08-05-02
DATE RECEIVED: 08-06-02
DATE ANALYZED: 08-06-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20951 | Inside Room 351 near Entrance to Hallway | <1.8 | 1.8 |
| 02 | 20951 | Inside Room 373 near Entrance to Hallway | <1.6 | 1.6 |
| 03 | 20951 | Inside Room 351 near Entrance to Hallway | <1.9 | 1.9 |
| 04 | 20951 | Inside Room 373 near Entrance to Hallway | <2.2 | 2.2 |
| 05 | 20951 | Field Blank | <1.5 µg | 1.5 µg |
| 06 | 20951 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP, INC.

# LEAD AREA AIR MONITORING SAMPLE RESULTS 3RD THROUGH 10TH FLOORS

**PROJECT #: M477-15217**
**LLW#: 29881**

130A JERICHO TPKE., FLORAL PARK, NY 11001 ▪ PHONE (516) 358-2955 ▪ FAX (516) 358-1780

NYC-WTC_000107042

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

[redacted] 2450

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: AL. ILLAZAKOV | CLIENT: SCA | SITE ADDRESS: Stuyvisdnt H.S. "M" | DATE SUBMITTED: 7/14/02 |
| DATE SAMPLED: 7/14/02 | CONTACT: Hamid Sayoy | WORK AREA: 10th floor | DATE LOGGED: |
| ROTOMETER NO: TEG- L18 | PROJECT NO: M477-1527/29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| AL-01 | | IWA ☐ OWA ☑ Entrance of Room # 1001 | 2/2 | 16:10 | 19:10 | 180 | 2 | 360 | | | | |
| AL-02 | | IWA ☐ OWA ☑ # 1007 | 2/2 | 16:12 | 19:12 | 180 | 2 | 360 | | | | |
| AL-03 | | IWA ☐ OWA ☑ # 1009 | 2/2 | 16:14 | 23:14 | 420 | 2 | 840 | | | | |
| AL-04 | | IWA ☐ OWA ☑ # 1017 | 2/2 | 16:16 | 23:16 | 420 | 2 | 840 | | | | |
| AL-05 | | IWA ☐ OWA ☑ # 1033 | 2/2 | 17:00 | 23:30 | 390 | 2 | 780 | | | | |
| AL-06 | | IWA ☐ OWA ☑ # 1025 | 2/2 | 20:20 | 23:40 | 200 | 2 | 400 | | | | |
| AL-07 | | IWA ☐ OWA ☑ # 1039 | 2/2 | 20:22 | 23:52 | 210 | 2 | 420 | | | | |
| AL-08 | | IWA ☐ OWA ☐ F/B " | | | | | | | | | | |
| AL-09 | | IWA ☐ OWA ☐ F/B " | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 7/15/02 | TIME: 0115 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE: 7/15/2 | TIME: 0115 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 hr. T.A.T. Fax results to "Taylor" | | |

CIRCLE: Lead PCM TEM BORD PRE DURING POST OSHA OTHER Niosh 7082

LOT # FILTER MANUFACTURER: AmBient

NYC-WTC_000107044

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-15-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 10th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-14-02
**DATE RECEIVED:** 07-15-02
**DATE ANALYZED:** 07-15-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| LA-01 | 20367 | Entrance of Room 1001 | <4.2 | 4.2 |
| LA-02 | 20367 | Entrance of Room 1007 | <4.2 | 4.2 |
| LA-03 | 20367 | Entrance of Room 1009 | <1.8 | 1.8 |
| LA-04 | 20367 | Entrance of Room 1017 | <1.8 | 1.8 |
| LA-05 | 20367 | Entrance of Room 1033 | <1.9 | 1.9 |
| LA-06 | 20367 | Entrance of Room 1025 | <3.8 | 3.8 |
| LA-07 | 20367 | Entrance of Room 1039 | <3.6 | 3.6 |
| LA-08 | 20367 | Field Blank | <1.5 µg | 1.5 µg |
| LA-09 | 20367 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] DAILY MONITORING SHEET [redacted] D [redacted] N [redacted] US [redacted] T [redacted] [redacted] [redacted] [redacted]

# TAYLOR ENVIRONMENTAL GROUP

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francois | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 7/15/02 |
| DATE SAMPLED: 7/15/02 | CONTACT: | WORK AREA: 10th fl. | DATE LOGGED: |
| FOTOVETER NO.: 16 | PROJECT NO.: M477-15217 LL# 29881 | PROJECT MANAGER: Chris Mc. Elgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | 46.5 |
| 15 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | 46.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/15/02 | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR TURNAROUND NIOSH 7082 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER: NIOSH 7082

LOT #: FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107047

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-16-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 10th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-15-02
**DATE RECEIVED:** 07-15-02
**DATE ANALYZED:** 07-15-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20387 | Inside Classroom 1017 Near Entrance to Hallway | <3.1 | 3.1 |
| 02 | 20387 | Inside Classroom 1025 Near Entrance to Hallway | <3.1 | 3.1 |
| 03 | 20387 | Inside Classroom 1033 Near Entrance to Hallway | <3.1 | 3.1 |
| 04 | 20387 | Inside Classroom 1039 Near Entrance to Hallway | <3.1 | 3.1 |
| 05 | 20387 | Inside Classroom 1024 Near Entrance to Hallway | <3.1 | 3.1 |
| 06 | 20387 | Inside Classroom 1064 Near Entrance to Hallway | <3.1 | 3.1 |
| 07 | 20387 | Inside Classroom 1017 Near Entrance to Hallway | <3.1 | 3.1 |
| 08 | 20387 | Inside Classroom 1025 Near Entrance to Hallway | <3.1 | 3.1 |
| 09 | 20387 | Inside Classroom 1033 Near Entrance to Hallway | 3.8 | 3.1 |
| 10 | 20387 | Inside Classroom 1039 Near Entrance to Hallway | 3.1 | 3.1 |
| 11 | 20387 | Inside Classroom 1024 Near Entrance to Hallway | <3.1 | 3.1 |
| 12 | 20387 | Inside Classroom 1006 Near Entrance to Hallway | <6.2 | 6.2 |
| 13 | 20387 | Inside Classroom 1004 Near Entrance to Hallway | <6.2 | 6.2 |
| 14 | 20387 | Field Blank | <1.5 µg | 1.5 µg |
| 15 | 20387 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TEGEEN MICHALOWK | CLIENT: SCA NYC | SITE ADDRESS: STUYVESANT H.S 345 CHAMBERS ST. MANHO | DATE SUBMITTED: TAN 07.15.02 |
| DATE SAMPLED: 07.15.02 | CONTACT: HAMID SADAT | WORK AREA: 10TH FLOOR - 9TH FLOOR | DATE LOGGED: |
| ROTOMETER NO: TEG L-16 | PROJECT NO: M477-90217 LLW #299881 | PROJECT MANAGER: CHRIS NG ELGUN | DATE APPROVED / SIGNATURE: AJ392 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 1010 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.00 | 20.00 | 240 | 2.0 | 480 | | | | |
| 02 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 1006 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.01 | 22.01 | 360 | 2.0 | 720 | | | | |
| 03 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 1004 NEAR ENTRANCE TO HALWAY | 2.0 / 2.0 | 16.02 | 21.32 | 330 | 2.0 | 660 | | | | |
| 04 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 904 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 18.25 | 24.25 | 300 | 2.0 | 600 | | | | |
| 05 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 901 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 18.27 | 24.27 | 300 | 2.0 | 600 | | | | |
| 06 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 1010 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.00 | 23.40 | 220 | 2.0 | 440 | | | | |
| 07 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 907 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 22.15 | 24.15 | 120 | 2.0 | 240 | | | | |
| 08 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 911 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 22.17 | 24.17 | 120 | 2.0 | 240 | | | | |
| 09 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 913 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 22.19 | 24.19 | 120 | 2.0 | 240 | | | | |
| 10 | | IWA ☐ OWA ☐ FIELD BLANK | | | | | | | | | | |
| 11 | | IWA ☐ OWA ☐ FIELD BLANK | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Tegeen Michalowk | DATE: 07.15.02 | TIME: 01.00 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE): ? | DATE: 7/16/1 | TIME: 4 on |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: 12 HOUR TURNAROUND NIOSH METHOD 7082 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH METOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-16-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers St., 10th Floor |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-15-02 |
| **DATE RECEIVED:** | 07-16-02 |
| **DATE ANALYZED:** | 07-16-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20392 | Inside Classroom 1010 Near Entrance to Hallway | <3.1 | 3.1 |
| 02 | 20392 | Inside Classroom 1006 Near Entrance to Hallway | <2.1 | 2.1 |
| 03 | 20392 | Inside Classroom 1004 Near Entrance to Hallway | <2.3 | 2.3 |
| 04 | 20392 | Inside Classroom 909 Near Entrance to Hallway | <2.5 | 2.5 |
| 05 | 20392 | Inside Classroom 901 Near Entrance to Hallway | <2.5 | 2.5 |
| 06 | 20392 | Inside Classroom 1010 Near Entrance to Hallway | <3.4 | 3.4 |
| 07 | 20392 | Inside Classroom 907 Near Entrance to Hallway | <6.3 | 6.3 |
| 08 | 20392 | Inside Classroom 911 Near Entrance to Hallway | <6.3 | 6.3 |
| 09 | 20392 | Inside Classroom 913 Near Entrance to Hallway | <6.3 | 6.3 |
| 10 | 20392 | Field Blank | <1.5 µg | 1.5 µg |
| 11 | 20392 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| Sylvester Francis | SCA | Stuyvesant H.S. 345 Chambers | 7/16/02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 7/16/02 | Hamid Saoi | 9th Fl. | |
| **ROTOMETER NO.** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| 18 | M477-15217 29881 | Chris McElgunn | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ Room 907 inside classroom near entrance to corridor | 2.0 / 2.0 | 730 | 1130 | 240 | 2.0 | 480 | | | | < 3.1 |
| 2 | | IWA ☐ OWA ☑ Room 907 inside classroom near entrance to corridor. | 2.0 / 2.0 | 732 | 1132 | 240 | 2.0 | 480 | | | | < 3.1 |
| 3 | | IWA ☐ OWA ☑ Room 907 inside classroom near entrance to corridor | 2.0 / 2.0 | 734 | 1134 | 240 | 2.0 | 480 | | | | < 3.1 |
| 4 | | IWA ☐ OWA ☑ Room 911 inside classroom near entrance to corridor | 2.0 / 2.0 | 736 | 1136 | 240 | 2.0 | 480 | | | | < 3.1 |
| 5 | | IWA ☐ OWA ☑ Room 913 inside classroom near entrance to corridor. | 2.0 / 2.0 | 738 | 1138 | 240 | 2.0 | 480 | | | | < 3.1 |
| 6 | | IWA ☐ OWA ☑ Room 925 inside classroom near entrance to corridor | 2.0 / 2.0 | 1015 | 315 | 300 | 2.0 | 600 | | | | < 2.5 |
| 7 | | IWA ☐ OWA ☑ Room 901 inside classroom near entrance to corridor | 2.0 / 2.0 | 1130 | 316 | 226 | 2.0 | 452 | | | | < 3.3 |
| 8 | | IWA ☐ OWA ☑ Room 903 inside classroom near entrance to corridor | 2.0 / 2.0 | 1132 | 317 | 225 | 2.0 | 450 | | | | < 3.3 |
| 9 | | IWA ☐ OWA ☑ Room 907 inside classroom near entrance to corridor | 2.0 / 2.0 | 1134 | 318 | 224 | 2.0 | 448 | | | | < 3.3 |
| 10 | | IWA ☐ OWA ☑ Room 911 inside classroom near entrance to corridor | 2.0 / 2.0 | 1136 | 319 | 223 | 2.0 | 446 | | | | < 3.4 |
| 11 | | IWA ☐ OWA ☑ Room 913 inside classroom near entrance to corridor | 2.0 / 2.0 | 1138 | 320 | 222 | 2.0 | 444 | | | | < 3.4 |
| 12 | | IWA ☐ OWA ☑ Field Blank | 2.0 | | | | | | | | | < 1.5 |
| 13 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | < 1.5 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | AC 7/16 | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| S. F. | 7/16/02 | 5:00pm | | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** NIOSH Method 7082 12 HOUR Turnaround. | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT # ____ FILTER MANUFACTURER ____

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107051

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-17-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers St., 9th Floor |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-16-02 |
| **DATE RECEIVED:** | 07-16-02 |
| **DATE ANALYZED:** | 07-16-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20398 | Rm 901 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 02 | 20398 | Rm 903 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 03 | 20398 | Rm 907 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 04 | 20398 | Rm 911 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 05 | 20398 | Rm 913 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 06 | 20398 | Rm 925 Inside Classroom Near Entrance to Corridor | <2.5 | 2.5 |
| 07 | 20398 | Rm 901 Inside Classroom Near Entrance to Corridor | <3.3 | 3.3 |
| 08 | 20398 | Rm 903 Inside Classroom Near Entrance to Corridor | <3.3 | 3.3 |
| 09 | 20398 | Rm 907 Inside Classroom Near Entrance to Corridor | <3.3 | 3.3 |
| 10 | 20398 | Rm 911 Inside Classroom Near Entrance to Corridor | <3.4 | 3.4 |
| 11 | 20398 | Rm 913 Inside Classroom Near Entrance to Corridor | <3.4 | 3.4 |
| 12 | 20398 | Field Blank | <1.5 µg | 1.5 µg |
| 13 | 20398 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229)

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/17 |
| DATE SAMPLED: 7/16/02 | CONTACT: Hans Savos | WORK AREA: 9th Fl. | DATE LOGGED: |
| ROTOMETER NO.: L-16 | PROJECT NO.: M477-15217/28881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: 20434 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☑ Room 927 at Entrance | 2.0 / 2.0 | 1415 | 1915 | 300 | 2.0 | 600 | | | | |
| 02 | | IWA ☐ OWA ☑ Room 931 at Entrance | 2.0 / 2.0 | 1500 | 1930 | 270 | 2.0 | 540 | | | | |
| 03 | | IWA ☐ OWA ☑ Room 935 at Entrance | 2.0 / 2.0 | 1502 | 1932 | 270 | 2.0 | 540 | | | | |
| 04 | | IWA ☐ OWA ☑ Room 913 at Entrance | 2.0 / 2.0 | 1504 | 1934 | 270 | 2.0 | 540 | | | | |
| 05 | | IWA ☐ OWA ☑ Room 925 at Entrance | 2.0 / 2.0 | 1506 | 1936 | 270 | 2.0 | 540 | | | | |
| 06 | | IWA ☐ OWA ☑ Room 927 at Entrance | 2.0 / 2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | |
| 07 | | IWA ☐ OWA ☑ Room 931 at Entrance | 2.0 / 2.0 | 2001 | 0001 | 240 | 2.0 | 480 | | | | |
| 08 | | IWA ☐ OWA ☑ Room 935 at Entrance | 2.0 / 2.0 | 2002 | 0002 | 240 | 2.0 | 480 | | | | |
| 09 | | IWA ☐ OWA ☑ Room 913 at Entrance | 2.0 / 2.0 | 2003 | 0003 | 240 | 2.0 | 480 | | | | |
| 10 | | IWA ☐ OWA ☑ Room 925 at Entrance | 2.0 / 2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | |
| 11 | | IWA ☐ OWA ☑ Room 939 at Entrance | 2.0 / 2.0 | 2005 | 0005 | 240 | 2.0 | 480 | | | | |
| 12 | | IWA ☐ OWA ☑ Room 938 at Entrance | 2.0 / 2.0 | 2030 | 0006 | 216 | 2.0 | 432 | | | | |
| 13 | | IWA ☐ OWA ☒ Room 940 at Entrance | 2.0 / 2.0 | 2031 | 0007 | 216 | 2.0 | 432 | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | 0106 | 7/17 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY: (SIGNATURE) | | | RECEIVED BY: (SIGNATURE) | 7/17/02 | 9a |
| ANALYST: (SIGNATURE) | | | COMMENTS: 12 Hour TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH METHOD 7082

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 7/17 |
| DATE SAMPLED: 7/16/02 | CONTACT: Mario Sanos | WORK AREA: 9th Fl | DATE LOGGED: |
| ROTOMETER NO.: L-16 | PROJECT NO.: M477-15217/28881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: 2043 4 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☐ Room 926 at Entrance | 2.0 / 2.0 | 2130 | 0008 | 158 | 2.0 | 316 | | | | |
| 15 | | IWA ☐ OWA ☐ Room 936 at Entrance | 2.0 / 2.0 | 2131 | 0009 | 158 | 2.0 | 316 | | | | |
| FB-16 | | IWA ☐ OWA ☐ FB-16 | | | | | | | | | | |
| FB-17 | | IWA ☐ OWA ☐ FB-17 | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 0100 | TIME: 7/17 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE: 7/17/1 | TIME: 900 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 Hour TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH METHOD 7082

LOT # / FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

AIC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-17-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 9th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-17-02
**DATE RECEIVED:** 07-17-02
**DATE ANALYZED:** 07-17-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20434 | Room 927 at Entrance | <2.5 | 2.5 |
| 02 | 20434 | Room 931 at Entrance | <2.8 | 2.8 |
| 03 | 20434 | Room 935 at Entrance | <2.8 | 2.8 |
| 04 | 20434 | Room 913 at Entrance | <2.8 | 2.8 |
| 05 | 20434 | Room 925 at Entrance | <2.8 | 2.8 |
| 06 | 20434 | Room 927 at Entrance | <3.1 | 3.1 |
| 07 | 20434 | Room 931 at Entrance | <3.1 | 3.1 |
| 08 | 20434 | Room 935 at Entrance | <3.1 | 3.1 |
| 09 | 20434 | Room 913 at Entrance | <3.1 | 3.1 |
| 10 | 20434 | Room 925 at Entrance | <3.1 | 3.1 |
| 11 | 20434 | Room 939 at Entrance | <3.1 | 3.1 |
| 12 | 20434 | Room 938 at Entrance | <3.5 | 3.5 |
| 13 | 20434 | Room 940 at Entrance | <3.5 | 3.5 |
| 14 | 20434 | Room 926 at Entrance | <4.7 | 4.7 |
| 15 | 20434 | Room 936 at Entrance | <4.7 | 4.7 |
| 16 | 20434 | Field Blank | <1.5 µg | 1.5 µg |
| 17 | 20434 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD 20499 PAGE 1 OF 2

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERESA MICHALOVE | SCA NYC | STUYVESANT HS. 345 CHAMBERS ST. NY NY | 07.17.02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 07.17.02 | Hamid Savoi | 9th FLOOR | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG L-16 | M477-15217 LLW #29881 | CHRIS MC ELCUY | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 938 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 07.16 | 11.16 | 240 | 2.0 | 480 | | | | <3.1 |
| 02 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 940 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 07.16 | 11.16 | 240 | 2.0 | 480 | | | | <3.1 |
| 03 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 939 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 07.17 | 11.17 | 240 | 2.0 | 480 | | | | <3.1 |
| 04 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 935 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 07.18 | 11.18 | 240 | 2.0 | 480 | | | | <3.1 |
| 05 | | IWA ☐ OWA ☒ INSIDE CLASSROOM TO HALLWAY NEAR ENTRANCE TO HALLWAY 936 | 2.0 / 2.0 | 07.19 | 11.19 | 240 | 2.0 | 480 | | | | <3.1 |
| 06 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 931 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 07.20 | 11.20 | 240 | 2.0 | 480 | | | | <3.1 |
| 07 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 927 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 07.21 | 11.21 | 240 | 2.0 | 480 | | | | 8.7 |
| 08 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 911 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 09.25 | 13.25 | 240 | 2.0 | 480 | | | | <3.1 |
| 09 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 1010 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 09.27 | 13.27 | 240 | 2.0 | 480 | | | | <3.1 |
| 10 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 926 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 09.45 | 13.45 | 240 | 2.0 | 480 | | | | 4.2 |
| 11 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 938 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 11.15 | 15.15 | 240 | 2.0 | 480 | | | | 4.9 |
| 12 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 940 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 11.16 | 15.16 | 240 | 2.0 | 480 | | | | 5.4 |
| 13 | | IWA ☐ OWA ☒ INSIDE CLASSROOM 939 NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 11.16 | 15.16 | 240 | 2.0 | 480 | | | | 5.6 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Carlos A Velez | 7-17-02 | 1650 | Ce 07/17 6pm | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| Teresa Michalove | 07.17.02 | 1615 | | | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | 12 HOUR TURNAROUND NIOSH METOD 7402 | | |

CIRCLE: PCM TEM — BORO PRE DURING POST — OSHA — OTHER NIOSH METOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples

NYC-WTC_000107057

NYC 9/11 Public Portal Document

[redacted] PAGE [redacted] OF [redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

| | | | |
|---|---|---|---|
| TECHNICIAN: TERENCE MICHALCZUK | CLIENT: SCA NYC | SITE ADDRESS: STUYVESANT HS 345 CHAMBERS ST. NY, NY. | DATE SUBMITTED: 07.17.02 |
| DATE SAMPLED: 07.17.02 | CONTACT: Hanno Sarod | WORK AREA: 9th FLOOR | DATE LOGGED: |
| ROTOMETER NO.: TG6 L-16 | PROJECT NO.: M477-15217 LLW #29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ INSIDE CLASSROOM 936<br>OWA ☒ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 11.17 | 15.17 | 240 | 2.0 | 480 | | | | 3.7 |
| 15 | | IWA ☐ INSIDE CLASSROOM 902<br>OWA ☒ NEAR ENTRANCE TO HOLLWAY | 2.0 / 2.0 | 11.18 | 15.18 | 240 | 2.0 | 480 | | | | 4.3 |
| 16 | | IWA ☐ INSIDE CLASSROOM 911<br>OWA ☒ NEAR ENTRANCE TO HOLLWAY | 2.0 / 2.0 | 13.25 | 15.30 | 125 | 2.0 | 250 | | | | 15.5 |
| 17 | | IWA ☐ INSIDE CLASSROOM 1010<br>OWA ☒ NEAR ENTRANCE TO HOLLWAY | 2.0 / 2.0 | 13.27 | 15.20 | 113 | 2.0 | 226 | | | | 7.3 |
| 18 | | IWA ☐ INSIDE CLASSROOM 926<br>OWA ☒ NEAR ENTRANCE TO HOLLWAY | 2.0 / 2.0 | 13.45 | 15.25 | 100 | 2.0 | 200 | | | | 1.5 |
| 19 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 20 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 21 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Chris Lepet | DATE: 7-17-02 | TIME: 1650 | RECEIVED FROM TEG DROP BOX (SIGNATURE): ACho 07/17 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): Ted | DATE: 07.17.02 | TIME: 1615 | RECEIVED BY: (SIGNATURE): | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: 12 HOUR TURNAROUND NIOSH METHOD 7082 | | |

CYCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107058

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-18-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
345 Chambers St., 9th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-17-02
**DATE RECEIVED:** 07-17-02
**DATE ANALYZED:** 07-17-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20444 | Inside Classroom 938 Near Entrance to Hallway | <3.1 | 3.1 |
| 02 | 20444 | Inside Classroom 940 Near Entrance to Hallway | <3.1 | 3.1 |
| 03 | 20444 | Inside Classroom 939 Near Entrance to Hallway | <3.1 | 3.1 |
| 04 | 20444 | Inside Classroom 935 Near Entrance to Hallway | <3.1 | 3.1 |
| 05 | 20444 | Inside Classroom to Hallway Near Entrance to Hallway 936 | <3.1 | 3.1 |
| 06 | 20444 | Inside Classroom 931 Near Entrance to Hallway | <3.1 | 3.1 |
| 07 | 20444 | Inside Classroom 927 Near Entrance to Hallway | 8.7 | 3.1 |
| 08 | 20444 | Inside Classroom 911 Near Entrance to Hallway | <3.1 | 3.1 |
| 09 | 20444 | Inside Classroom 1010 Near Entrance to Hallway | <3.1 | 3.1 |
| 10 | 20444 | Inside Classroom 926 Near Entrance to Hallway | 4.2 | 3.1 |
| 11 | 20444 | Inside Classroom 938 Near Entrance to Hallway | 4.9 | 3.1 |
| 12 | 20444 | Inside Classroom 940 Near Entrance to Hallway | 5.4 | 3.1 |
| 13 | 20444 | Inside Classroom 939 Near Entrance ot Hallway | 5.6 | 3.1 |
| 14 | 20444 | Inside Classroom 936 Near Entrance to Hallway | 3.7 | 3.1 |
| 15 | 20444 | Inisidc Classroo 902 Near Entrance to Hallway | 4.3 | 3.1 |
| 16 | 20444 | Inside Classroom 911 Near Entrance to Hallway | 15.5 | 6.0 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 17 | 20444 | Inside Classroom 1010 Near Entrance to Hallway | 7.3 | 6.6 |
| 18 | 20444 | Inside Classroom 926 Near Entrance to Hallway | 11.5 | 7.5 |
| 19 | 20444 | Field Blank | <1.5 µg | 1.5 µg |
| 20 | 20444 | Field Blank | <1.5 µg | 1.5 µg |
| 21 | 20444 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

**ANALYSIS PERFORMED BY:** #04

**REPORT PREPARED BY:** [signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** [signature]

**LABORATORY DIRECTOR:** [signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879). (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#20163

PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/18/02 |
| DATE SAMPLED: 7/17/02 | CONTACT: Hamid Savoi | WORK AREA: 8th Floor | DATE LOGGED: |
| POTCUETER NO: 202 | PROJECT NO.: 14477-13217/29881 | PROJECT MANAGER: Chris McElyea | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☑ Room 829 at Entrance | 2.0/2.0 | 1600 | 2000 | 240 | 2.0 | 480 | | | | |
| 02 | | IWA ☐ OWA ☑ Room 833 at Entrance | 2.0/2.0 | 1601 | 2001 | 240 | 2.0 | 480 | | | | |
| 03 | | IWA ☐ OWA ☑ Room 835 at Entrance | 2.0/2.0 | 1602 | 2002 | 240 | 2.0 | 480 | | | | |
| 04 | | IWA ☐ OWA ☑ Room 837 at Entrance | 2.0/2.0 | 1603 | 2003 | 240 | 2.0 | 480 | | | | |
| 05 | | IWA ☐ OWA ☑ Room 839 at Entrance | 2.0/2.0 | 1604 | 2004 | 240 | 2.0 | 480 | | | | |
| 06 | | IWA ☐ OWA ☑ Room 840 at Entrance | 2.0/2.0 | 1605 | 2005 | 240 | 2.0 | 480 | | | | |
| 07 | | IWA ☐ OWA ☑ Room 829 at Entrance | 2.0/2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | |
| 08 | | IWA ☐ OWA ☑ Room 833 at Entrance | 2.0/2.0 | 2001 | 0001 | 240 | 2.0 | 480 | | | | |
| 09 | | IWA ☐ OWA ☑ Room 835 at Entrance | 2.0/2.0 | 2002 | 0002 | 240 | 2.0 | 480 | | | | |
| 10 | | IWA ☐ OWA ☑ Room 837 at Entrance | 2.0/2.0 | 2003 | 0003 | 240 | 2.0 | 480 | | | | |
| 11 | | IWA ☐ OWA ☑ Room 839 at Entrance | 2.0/2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | |
| 12 | | IWA ☐ OWA ☑ Room 840 at Entrance | 2.0/2.0 | 2005 | 0005 | 240 | 2.0 | 480 | | | | |
| 13 | | IWA ☐ OWA ☑ Room 838 at Entrance | 2.0/2.0 | 2006 | 0006 | 240 | 2.0 | 480 | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | DATE 7/18/02 | TIME 0830 | RECEIVED BY: (SIGNATURE) | DATE 7/19/7 | TIME |
| ATTEST: (SIGNATURE) | DATE | TIME | COMMENTS 90 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH Method 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107061

[redacted]

TAYLOR ENVIRONMENTAL GROUP **DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD** PAGE 2 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/18/02 |
| DATE SAMPLED: 7/17/02 | CONTACT: Hamin Sands | WORK AREA: 8th Floor | DATE LOGGED: |
| ROTOMETER NO.: 202 | PROJECT NO.: M477-1321/2988( | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: 2046 ] |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| FB-14 | | IWA ☐ OWA ☐ FB-14 | | | | | | | | | | |
| FB-15 | | IWA ☐ OWA ☐ FB-15 | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY (SIGNATURE) | DATE: 7/18/02 | TIME: 0025 | RECEIVED BY: (SIGNATURE) | DATE: 7/19/02 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 9a | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH METHOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| REPORT DATE: | 07-18-02 |
| CLIENT: | Taylor Environmental Group, Inc. |
| PROJECT NAME: | SCA/Stuyvesant HS<br>345 Chambers St., 8th Floor |
| SAMPLED BY: | Client |
| SAMPLE DATE | 07-17-02 |
| DATE RECEIVED: | 07-18-02 |
| DATE ANALYZED: | 07-18-02 |
| SAMPLE MEDIA: | Air Samples |
| ANALYSIS REQUIRED: | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20444 | Room 829 at Entrance | <3.1 | 3.1 |
| 02 | 20463 | Room 833 at Entrance | <3.1 | 3.1 |
| 03 | 20463 | Room 835 at Entrance | <3.1 | 3.1 |
| 04 | 20463 | Room 837 at Entrance | <3.1 | 3.1 |
| 05 | 20463 | Room 839 at Entrance | <3.1 | 3.1 |
| 06 | 20463 | Room 840 at Entrance | <3.1 | 3.1 |
| 07 | 20463 | Room 829 at Entrance | <3.1 | 3.1 |
| 08 | 20463 | Room 833 at Entrance | <3.1 | 3.1 |
| 09 | 20463 | Room 835 at Entrance | <3.1 | 3.1 |
| 10 | 20463 | Room 837 at Entrance | <3.1 | 3.1 |
| 11 | 20463 | Room 839 at Entrance | <3.1 | 3.1 |
| 12 | 20463 | Room 840 at Entrance | <3.1 | 3.1 |
| 13 | 20463 | Room 838 at Entrance | <1.5 µg | 1.5 µg |
| 14 | 20463 | Field Blank | <1.5 µg | 1.5 µg |
| 15 | 20463 | Field Blank | | |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg

NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.

NOTE 3:
Blank units are in µg

NYC-WTC_000107063

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted] [redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CH[redacted] OF [redacted]ST[redacted] RE[redacted]D

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvesterfrancois | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 7/18/02 |
| DATE SAMPLED: 7/18/02 | CONTACT: Hanis Sanos | WORK AREA: 8th floor | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477 - 15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☑ Inside room 815 near entrance to corridor | 2.0 / 2.0 | 1315 | 1530 | 135 | 2.0 | 270 | | | | < 5.5 |
| 15 | | IWA ☐ OWA ☐ Field Blank. | | | | | | | | | | < 1.5 |
| 16 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | < 1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos Ortiz | DATE: 7-18-02 | TIME: 1624 | RECEIVED FROM TEG DROP BOX (SIGNATURE): [redacted] 07/18 | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/18/02 | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR Turnaround NIOSH 7082 Method | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082 Method

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-19-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>345 Chambers St., 8th Floor |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-18-02 |
| **DATE RECEIVED:** | 07-18-02 |
| **DATE ANALYZED:** | 07-18-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20468 | Insdie Rm 829 Near Entrance to Corridor | <3.1 | 3.1 |
| 02 | 20468 | Insdie Rm 833 Near Entrance to Corridor | <3.1 | 3.1 |
| 03 | 20468 | Insdie Rm 835 Near Entrance to Corridor | <3.1 | 3.1 |
| 04 | 20468 | Insdie Rm 837 Near Entrance to Corridor | <3.1 | 3.1 |
| 05 | 20468 | Insdie Rm 840 Near Entrance to Corridor | <3.1 | 3.1 |
| 06 | 20468 | Insdie Rm 839 Near Entrance to Corridor | <3.1 | 3.1 |
| 07 | 20468 | Insdie Rm 838 Near Entrance to Corridor | <3.1 | 3.1 |
| 08 | 20468 | Insdie Rm 836 Near Entrance to Corridor | <3.1 | 3.1 |
| 09 | 20468 | Insdie Rm 840 Near Entrance to Corridor | <3.4 | 3.4 |
| 10 | 20468 | Insdie Rm 838 Near Entrance to Corridor | <3.4 | 3.4 |
| 11 | 20468 | Insdie Rm 836 Near Entrance to Corridor | <3.4 | 3.4 |
| 12 | 20468 | Insdie Rm 827 Near Entrance to Corridor | <3.4 | 3.4 |
| 13 | 20468 | Insdie Rm 804 Near Entrance to Corridor | <3.4 | 3.4 |
| 14 | 20468 | Insdie Rm 815 Near Entrance to Corridor | <5.5 | 5.5 |
| 15 | 20468 | Field Blank | <1.5 µg | 1.5 µg |
| 16 | 20468 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg

NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.

NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: #04

REPORT PREPARED BY:

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR:

LABORATORY DIRECTOR:

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-19-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
350 Chambers St., 8th Floor

**SAMPLED BY:** Client

**SAMPLE DATE** 07-18-02
**DATE RECEIVED:** 07-19-02
**DATE ANALYZED:** 07-19-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| LA-01 | 20486 | Rm 801 Inside Room 15' from Entrance 5' High | <1.3 | 1.3 |
| LA-02 | 20486 | Rm 804 Inside Rm 10' from Entrance 5' High | <1.3 | 1.3 |
| LA-03 | 20486 | Rm 811 Inside Rm 7' fro Entrance 5' High | <1.3 | 1.3 |
| LA-04 | 20486 | Rm 815 Inside Rm 10' from Entrance 5' High | <1.3 | 1.3 |
| LA-05 | 20486 | Rm 827 Inside Rm 10' from Entrance 5' High | <1.3 | 1.3 |
| LA-06 | 20486 | Rm 809 Inside Rm 15' from Entrance 5' High | <1.3 | 1.3 |
| LA-07 | 20486 | Rm 1017A Inside Rm by Entrance | <1.3 | 1.3 |
| LA-08 | 20486 | Rm 902 Inside Rm by Entrance | <1.3 | 1.3 |
| LA-09 | 20486 | Rm 801 Inside Rm by Entrance | <1.3 | 1.3 |
| LA-10 | 20486 | Rm 804 Inside Rm by Entrance | <1.3 | 1.3 |
| LA-11 | 20486 | Rm 811 Inside Rm by Entrance | <1.3 | 1.3 |
| LA-12 | 20486 | Rm 815 Inside Rm by Entrance | <1.3 | 1.3 |
| LA-13 | 20486 | Rm 827 Inside Rm by Entrance | <1.3 | 1.3 |
| LA-14 | 20486 | Rm 809 Inside Rm Next to Entrance | <1.3 | 1.3 |
| LA-15 | 20486 | Field Blank | <1.5 µg | 1.5 µg |
| LA-16 | 20486 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD — PAGE 1 OF [redacted]

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H. S. 345 Chambers | DATE SUBMITTED: 7/19/02 |
| DATE SAMPLED: 7/19/02 | CONTACT: Hamid Sadr | WORK AREA: 8th & 10th fl. | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477-15217 LL Wtr 29881 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☐ Inside room 807 near entrance to hallway | 2.0 / 2.0 | 720 | 1120 | 240 | 2.0 | 480 | | | | < 3.1 |
| 2 | | IWA ☐ OWA ☐ Inside room 1017A near entrance to hallway | 2.0 / 2.0 | 722 | 1122 | 240 | 2.0 | 480 | | | | < 3.1 |
| 3 | | IWA ☐ OWA ☐ Inside room 826 near entrance to hallway | 2.0 / 2.0 | 724 | 1124 | 240 | 2.0 | 480 | | | | < 3.1 |
| 4 | | IWA ☐ OWA ☐ Inside room 807 near entrance to hallway | 2.0 / 2.0 | 726 | 1126 | 240 | 2.0 | 480 | | | | < 3.1 |
| 5 | | IWA ☐ OWA ☐ Inside room 809 near entrance to hallway | 2.0 / 2.0 | 728 | 1128 | 240 | 2.0 | 480 | | | | < 3.1 |
| 6 | | IWA ☐ OWA ☐ Inside room 801 near entrance to hallway | 2.0 / 2.0 | 730 | 1130 | 240 | 2.0 | 480 | | | | < 3.1 |
| 7 | | IWA ☐ OWA ☐ Inside room 803 near entrance to hallway | 2.0 / 2.0 | 732 | 1132 | 240 | 2.0 | 480 | | | | < 3.1 |
| 8 | | IWA ☐ OWA ☐ Inside room 811 near entrance to hallway | 2.0 / 2.0 | 734 | 1134 | 240 | 2.0 | 480 | | | | < 3.1 |
| 9 | | IWA ☐ OWA ☐ Inside room 817 near entrance to hallway | 2.0 / 2.0 | 1120 PM | 320 PM | 240 | 2.0 | 480 | | | | < 3.1 |
| 10 | | IWA ☐ OWA ☐ Inside room 807 near entrance to hallway | 2.0 / 2.0 | 1126 PM | 326 PM | 240 | 2.0 | 480 | | | | 3.2 |
| 11 | | IWA ☐ OWA ☐ Inside room 809 near entrance to hallway | 2.0 / 2.0 | 1128 PM | 328 PM | 240 | 2.0 | 480 | | | | < 3.1 |
| 12 | | IWA ☐ OWA ☐ Inside room 891 near entrance to hallway | 2.0 / 2.0 | 1130 PM | 330 PM | 240 | 2.0 | 480 | | | | 4.9 |
| 13 | | IWA ☐ OWA ☐ Inside room 826 near entrance to hallway | 2.0 / 2.0 | 1124 PM | 324 PM | 240 | 2.0 | 480 | | | | < 3.1 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) 7/20/02 | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7-19-02 | TIME: 500Pm | RECEIVED BY (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR TURNAROUND NIOSH method 7082 | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA OTHER NIOSH 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107071

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD — PAGE [redacted] OF [redacted]

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers St. | DATE SUBMITTED: [redacted] |
| DATE SAMPLED: 7/19/02 | CONTACT: Hamid Sadr | WORK AREA: 8th & 10th Flrs. | DATE RECEIVED: 7/20/02 |
| ROTOMETER NO: | PROJECT NO: M497-15217 | PROJECT MANAGER: Chris McElyum | DATE APPROVED/SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☑ Inside room 810A near entrance to hallway | 2.0 / 2.0 | 1122 Am | 322 Pm | 240 | 2.0 | 480 | | | | <3.1 |
| 15 | | IWA ☐ OWA ☑ Inside room 811 near entrance to hallway | 2.0 / 2.0 | 1139 Am | 339 Pm | 240 | 2.0 | 480 | | | | <3.1 |
| 16 | | IWA ☐ OWA ☑ Inside room 803 near entrance to hallway | 2.0 / 2.0 | 1132 Am | 332 Pm | 240 | 2.0 | 480 | | | | <3.1 |
| 17 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 18 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) 7/19 07/19 | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE 7/19/02 | TIME 5:00pm | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR Turnaround NIOSH 7082 Method | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA NIOSH 7082 — OTHER — LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107072

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-22-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>350 Chambers Street<br>8th & 10th Floors |
| **PROJECT NUMBER:** | M477-15217-29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-19-02 |
| **DATE RECEIVED:** | 07-19-02 |
| **DATE ANALYZED:** | 07-19-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20504 | Inside room 817 near entrance to hallway | <3.1 | 3.1 |
| 02 | 20504 | Inside room 1017A near entrance to hallway | <3.1 | 3.1 |
| 03 | 20504 | Inside room 826 near entrance to hallway | <3.1 | 3.1 |
| 04 | 20504 | Inside room 807 near entrance to hallway | <3.1 | 3.1 |
| 05 | 20504 | Inside room 809 near entrance to hallway | <3.1 | 3.1 |
| 06 | 20504 | Inside room 801 near entrance to hallway | <3.1 | 3.1 |
| 07 | 20504 | Inside room 803 near entrance to hallway | <3.1 | 3.1 |
| 08 | 20504 | Inside room 811 near entrance to hallway | <3.1 | 3.1 |
| 09 | 20504 | Inside room 817 near entrance to hallway | <3.1 | 3.1 |
| 10 | 20504 | Inside room 807 near entrance to hallway | 3.2 | 3.1 |
| 11 | 20504 | Inside room 809 near entrance to hallway | <3.1 | 3.1 |
| 12 | 20504 | Inside room 801 near entrance to hallway | 4.9 | 3.1 |
| 13 | 20504 | Inside room 826 near entrance to hallway | <3.1 | 3.1 |
| 14 | 20504 | Inside room 1017A near entrance to hallway | <3.1 | 3.1 |
| 15 | 20504 | Inside room 811 near entrance to hallway | <3.1 | 3.1 |
| 16 | 20504 | Inside room 803 near entrance to hallway | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 17 | 20504 | Field Blank " | <1.5 µg | 1.5 µg |
| 18 | 20504 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m$^3$ and a permissible exposure level (PEL) of 50 µg/m$^3$ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229)

NYC 9/11 Public Portal Document

[redacted] [redacted] [redacted] [

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TERESA MICHALCZUK | CLIENT: SCA | SITE ADDRESS: STUYVESANT HS 345 CHAMBERS ST. NY NY | DATE SUBMITTED: 07/30/02 |
| DATE SAMPLED: 07.19.02 | CONTACT: HAMID SAVAJ | WORK AREA: FLOORS: 10,9,8,7 | DATE LOGGED: |
| ROTOMETER NO: TEG L-16 | PROJECT NO: M447-15217 LLH # 29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 705 NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.12 | 24.12 | 240 | 2.0 | 480 | | | | <3.1 |
| 15 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 707 NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.13 | 24.13 | 240 | 2.0 | 480 | | | | <3.1 |
| 16 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 715 NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.14 | 24.14 | 240 | 2.0 | 480 | | | | <3.1 |
| 17 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 717 NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.17 | 24.17 | 240 | 2.0 | 480 | | | | <3.1 |
| 18 | | IWA ☐ OWA ☑ INSIDE CLASSROOM 727 NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 22.00 | 24.18 | 138 | 2.0 | 276 | | | | <5.5 |
| 19 | | IWA ☐ OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 20 | | IWA ☐ OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 21 | | IWA ☐ OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Teresa Michalczuk | DATE 07.20 | TIME 7/20/02 | RECEIVED BY: (SIGNATURE) R. Armstrong | DATE 7.20.02 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR TURNAROUND NIOSH METOD 7082 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH METOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-22-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>350 Chambers Street<br>7th-10th Floors |
| **PROJECT NUMBER:** | M477-15217-29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-19-02 |
| **DATE RECEIVED:** | 07-20-02 |
| **DATE ANALYZED:** | 07-20-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20512 | Inside room 1017 near entrance to hallway | <3.1 | 3.1 |
| 02 | 20512 | Inside room 903A near entrance to hallway | <2.5 | 2.5 |
| 03 | 20512 | Inside room 803 near entrance to hallway | <2.5 | 2.5 |
| 04 | 20512 | Inside room 817 near entrance to hallway | <2.4 | 2.4 |
| 05 | 20512 | Inside room 709 near entrance to hallway | <3.1 | 3.1 |
| 06 | 20512 | Inside room 701 near entrance to hallway | <3.1 | 3.1 |
| 07 | 20512 | Inside room 703 near entrance to hallway | <3.1 | 3.1 |
| 08 | 20512 | Inside room 705 near entrance to hallway | <3.1 | 3.1 |
| 09 | 20512 | Inside room 707 near entrance to hallway | <3.1 | 3.1 |
| 10 | 20512 | Inside room 715 near entrance to hallway | <3.1 | 3.1 |
| 11 | 20512 | Inside room 709 near entrance to hallway | <3.1 | 3.1 |
| 12 | 20512 | Inside room 701 near entrance to hallway | <3.1 | 3.1 |
| 13 | 20512 | Inside room 703 near entrance to hallway | <3.1 | 3.1 |
| 14 | 20512 | Inside room 705 near entrance to hallway | <3.1 | 3.1 |
| 15 | 20512 | Inside room 707 near entrance to hallway | <3.1 | 3.1 |
| 16 | 20512 | Inside room 715 near entrance to hallway | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 17 | 20512 | Inside room 717 near entrance to hallway | <3.1 | 3.1 |
| 18 | 20512 | Inside room 727 near entrance to hallway | <5.5 | 5.5 |
| 19 | 20512 | Field Blank | <1.5 µg | 1.5 µg |
| 20 | 20512 | Field Blank | <1.5 µg | 1.5 µg |
| 21 | 20512 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples
NOTE 3.
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879). (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted]

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF [redacted]

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 7/20/02 |
| DATE SAMPLED: 7/20/02 | CONTACT: Mario Santos | WORK AREA: 7th floor | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477-152.17 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | ng/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ Inside room 701 at entrance to hallway | 2.0 / 2.0 | 720 | 1120 | 240 | 2.0 | 480 | | | | 3.3 |
| 2 | | IWA ☐ OWA ☑ Inside room 701A at entrance to hallway | 2.0 / 2.0 | 722 | 1122 | 240 | 2.0 | 480 | | | | < 3.1 |
| 3 | | IWA ☐ OWA ☑ Inside room 703 at entrance to hallway | 2.0 / 2.0 | 724 | 1124 | 240 | 2.0 | 480 | | | | < 3.1 |
| 4 | | IWA ☐ OWA ☑ Inside room 705 at entrance to hallway | 2.0 / 2.0 | 726 | 1126 | 240 | 2.0 | 480 | | | | < 3.1 |
| 5 | | IWA ☐ OWA ☑ Inside room 705 at entrance to hallway | 2.0 / 2.0 | 728 | 1128 | 240 | 2.0 | 480 | | | | < 3.1 |
| 6 | | IWA ☐ OWA ☑ Inside room 709 at entrance to hallway | 2.0 / 2.0 | 730 | 1130 | 240 | 2.0 | 480 | | | | < 3.1 |
| 7 | | IWA ☐ OWA ☑ Inside room 711 at entrance to hallway | 2.0 / 2.0 | 732 | 1132 | 240 | 2.0 | 480 | | | | < 3.1 |
| 8 | | IWA ☐ OWA ☑ Inside room 717 at entrance to hallway | 2.0 / 2.0 | 734 | 1134 | 240 | 2.0 | 480 | | | | < 3.1 |
| 9 | | IWA ☐ OWA ☑ Inside room 727 at entrance to hallway | 2.0 / 2.0 | 736 | 1136 | 240 | 2.0 | 480 | | | | < 3.1 |
| 10 | | IWA ☐ OWA ☑ Inside room 701 at entrance to hallway | 2.0 / | 1120 | V | 0 | I | D | | | | |
| 11 | | IWA ☐ OWA ☑ Inside 701A at entrance to Hallway | 2.0 / | 1122 | V | 0 | I | D | Power outage @ 1630 | | | |
| 12 | | IWA ☐ OWA ☑ Inside ~~room~~ room 703 at entrance to hallway | 2.0 / | 1124 | V | 0 | I | D | | | | |
| 13 | | IWA ☐ OWA ☑ Inside room 707 at entrance to hallway | 2.0 / | 1126 | V | 0 | I | D | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/20/02 | TIME: 430 PM | RECEIVED BY: (SIGNATURE) R. Arredina | DATE: 7.20.02 | TIME: 16.30 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR Turnaround NIOSH Method 7082. Because of power outage insufficient volume obtained for analysis | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH Method 7082

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107079

NYC 9/11 Public Portal Document

[redacted]

TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD — PAGE 2 OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 7/20/02 |
| DATE SAMPLED: 9/20/02 | CONTACT: Hamid Saadat | WORK AREA: 9th fl. | DATE LOGGED: |
| ROTOMETER NO: 16 | PROJECT NO: M477-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | ... mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☑ Inside room 705 | 2.0 | 1128 | V | 0 | I | D | | | | |
| 15 | | IWA ☐ OWA ☑ Inside room 708 at entrance to hallway | 2.0 | 1130 | V | 0 | I | D | Pump | | | |
| 16 | | IWA ☐ OWA ☑ Inside room 715 at entrance to hallway | 2.0 | 1132 | V | 0 | I | D | Pump | | | |
| 17 | | IWA ☐ OWA ☑ Inside room 717 at entrance to hallway | 2.0 | 1134 | V | 0 | I | D | Pump | | | |
| 18 | | IWA ☐ OWA ☑ Inside room 727 at entrance to hallway | 2.0 | 1136 | V | 0 | I | D | | | | |
| 19 | | IWA ☐ OWA ☐ Blank | | | | | | | | | | < 1.5 |
| 20 | | IWA ☐ OWA ☐ Blank | | | | | | | | | | < 1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME | CIRCLE: PCM TEM | |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/20/02 | TIME: 430 | RECEIVED BY (SIGNATURE): R. Diandra | DATE: 7.20.02 | TIME: 16.30 | BGRD PRE DURING POST | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: Because of power outage insufficient volume obtained | | | OSHA OTHER NIOSH Method 7082 | |
| | | | | | | LOT # / FILTER MANUFACTURER | |

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy Samples #10-18

NYC-WTC_000107080

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-22-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
350 Chambers Street
7th Floor

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE 07-20-02
DATE RECEIVED: 07-20-02
DATE ANALYZED: 07-20-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20517 | Inside Room 701 at Entrance to Hallway | 3.5 | 3.1 |
| 02 | 20517 | Inside Room 701A at Entrance to Hallway | <3.1 | 3.1 |
| 03 | 20517 | Inside Room 703 at Entrance to Hallway | <3.1 | 3.1 |
| 04 | 20517 | Inside Room 707 at Entrance to Hallway | <3.1 | 3.1 |
| 05 | 20517 | Inside Room 705 at Entrance to Hallway | <3.1 | 3.1 |
| 06 | 20517 | Inside Room 709 at Entrance to Hallway | <3.1 | 3.1 |
| 07 | 20517 | Inside Room 715 at Entrance to Hallway | <3.1 | 3.1 |
| 08 | 20517 | Inside Room 717 at Entrance to Hallway | <3.1 | 3.1 |
| 09 | 20517 | Inside Room 727 at Entrance to Hallway | <3.1 | 3.1 |
| 19 | 20517 | Field Blank | <1.5 µg | 1.5 µg |
| 20 | 20517 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3
Blank units are in µg

NYC-WTC_000107081

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879). (AIHA #100229)

NYC-WTC_000107082

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: NYRON WILLIAMS | CLIENT: SCA | SITE ADDRESS: STUYVESANT HIGH SCHOOL | DATE SUBMITTED: 07-21-02 |
| DATE SAMPLED: 07-21-02 | CONTACT: HAMIA SAVOI | WORK AREA: 7TH FLOOR | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477-15217 | PROJECT MANAGER: CHRIS MEELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | ~~F/CC~~ MG/M³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☑ INSIDE ROOM # 701A BY ENTRANCE | 2/2 | 07:10 | 11:10 | 240 | 2 | 480 | | | | <3.1 |
| 02 | | IWA ☐ OWA ☑ INSIDE ROOM # 701 BY ENTRANCE | 2/2 | 07:11 | 11:11 | 240 | 2 | 480 | | | | <3.1 |
| 03 | | IWA ☐ OWA ☑ INSIDE ROOM # 705 BY ENTRANCE | 2/2 | 07:12 | 11:12 | 240 | 2 | 480 | | | | <3.1 |
| 04 | | IWA ☐ OWA ☑ INSIDE ROOM # 707 BY ENTRANCE | 2/1.5 | 07:13 | 11:13 | 240 | 1.75 | 420 | | | | <3.6 |
| 05 | | IWA ☐ OWA ☑ INSIDE ROOM # 709 BY ENTRANCE | 2/2 | 07:14 | 11:14 | 240 | 2 | 480 | | | | <3.1 |
| 06 | | IWA ☐ OWA ☑ INSIDE ROOM # 715 BY ENTRANCE | 2/2 | 07:16 | 11:16 | 240 | 2 | 480 | | | | <3.1 |
| 07 | | IWA ☐ OWA ☑ INSIDE ROOM # 717 BY ENTRANCE | 2/2 | 07:17 | 11:17 | 240 | 2 | 480 | | | | <3.1 |
| 08 | | IWA ☐ OWA ☑ INSIDE ROOM # 727 BY ENTRANCE | 2/1.5 | 07:18 | 11:18 | 240 | 1.75 | 420 | | | | <3.6 |
| 09 | | IWA ☐ OWA ☑ INSIDE ROOM # 729 BY ENTRANCE | 2/2 | 07:19 | 11:19 | 240 | 2 | 480 | | | | <3.1 |
| 10 | | IWA ☐ OWA ☑ INSIDE ROOM # 704 BY ENTRANCE | 2/2 | 08:30 | 11:30 | 180 | 2 | 360 | | | | <4.2 |
| 11 | | IWA ☐ OWA ☑ INSIDE ROOM # 702 BY ENTRANCE | 2/2 | 09:21 | 11:31 | 140 | 2 | ~~280~~ | | | | <5.4 |
| 12 | | IWA ☐ OWA ☑ INSIDE ROOM # 736 BY ENTRANCE | 2/2 | 09:26 | 11:36 | 140 | 2 | 280 | | | | <5.4 |
| 13 | | IWA ☐ OWA ☑ INSIDE ROOM # 736 BY ENTRANCE | 2/2 | 09:30 | 11:40 | 140 | 2 | 280 | | | | <5.4 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7-21-02 | TIME: 1615 | RECEIVED BY: (SIGNATURE) R. ROLLERA | DATE: 7.21.02 | TIME: 16.15 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER AMBIENT

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107083

NYC 9/11 Public Portal Document

[redacted] T[redacted]OR [redacted]VIR[redacted]MEN[redacted]AL GR[redacted]UP [redacted] DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD [redacted] PAGE 2 OF 3

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| DYRON WILLIAMS | SCA | STUYVESANT HIGH SCHOOL | 07-21-02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 07-21-02 | HAMID SAVOJ | 7TH FLOOR | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG 16 | M477-15217/29881 | CHRIS MCELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC MG/M³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☒ INSIDE ROOM # 738 BY ENTRANCE | 2/2 | 09:22 | 11:42 | 140 | 2 | 280 | | | | <5.4 |
| 15 | | IWA ☐ OWA ☒ INSIDE ROOM # 701A BY ENTRANCE | 2/2 | 11:45 | 15:25 | 220 | 2 | 440 | | | | <3.4 |
| 16 | | IWA ☐ OWA ☒ INSIDE ROOM # 701 BY ENTRANCE | 2/2 | 11:46 | 15:26 | 220 | 2 | 440 | | | | <3.4 |
| 17 | | IWA ☐ OWA ☒ INSIDE ROOM # 705 BY ENTRANCE | 2/2 | 11:47 | 15:27 | 220 | 2 | 440 | | | | <3.4 |
| 18 | | IWA ☐ OWA ☒ INSIDE ROOM # 707 BY ENTRANCE | 2/2 | 11:48 | 15:28 | 220 | 2 | 440 | | | | <3.4 |
| 19 | | IWA ☐ OWA ☒ INSIDE ROOM # 709 BY ENTRANCE | 2/1.5 | 11:49 | 15:24 | 220 | 1.75 | 385 | | | | 3.9 |
| 20 | | IWA ☐ OWA ☒ INSIDE ROOM # 715 BY ENTRANCE | 2/2 | 11:50 | 15:30 | 220 | 2 | 440 | | | | <3.4 |
| 21 | | IWA ☐ OWA ☒ INSIDE ROOM # 717 BY ENTRANCE | 2/2 | 11:51 | 15:31 | 220 | 2 | 440 | | | | <3.4 |
| 22 | | IWA ☐ OWA ☒ INSIDE ROOM # 787 BY ENTRANCE | 2/2 | 11:53 | 15:33 | 220 | 2 | 440 | | | | <3.4 |
| 23 | | IWA ☐ OWA ☒ INSIDE ROOM # 789 BY ENTRANCE | 2/2 | 11:54 | 15:34 | 220 | 2 | 440 | | | | <3.4 |
| 24 | | IWA ☐ OWA ☒ INSIDE ROOM # 707 BY ENTRANCE | 2/2 | 11:56 | 15:36 | 220 | 2 | 440 | | | | <3.4 |
| 25 | | IWA ☐ OWA ☒ INSIDE ROOM # 709 BY ENTRANCE | 2/1.5 | 11:57 | 15:37 | 220 | 1.75 | 385 | | | | <3.9 |
| 26 | | IWA ☐ OWA ☒ INSIDE ROOM # 786 BY ENTRANCE | 2/0 | 11:59 | 15:39 | 220 | 2 | 440 | | | | <3.4 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | | | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| [signature] | 7-21-02 | 1615 | R. Stoudma | 7.21.02 | 16.15 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER AMBIENT

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

# [redacted] TAYLOR ENVIRONMENTAL GROUP [redacted] DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD [redacted] PAGE 3 OF 3

| | | | |
|---|---|---|---|
| TECHNICIAN: NYRON WILLIAMS | CLIENT: SCA | SITE ADDRESS: STUYVESANT HIGH SCHOOL | DATE SUBMITTED: 07-21-02 |
| DATE SAMPLED: 07-21-02 | CONTACT: HAMID SAUOJ | WORK AREA: 7TH FLOOR | DATE LOGGED: |
| ROTOMETER NO.: TEG 16 | PROJECT NO.: M477-15217 / 29861 | PROJECT MANAGER: CHRIS MCELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC n/g/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 27 | | IWA ☐ INSIDE ROOM #736<br>OWA ☑ BY ENTRANCE | 2 / 2 | 10:00 | 15:40 | 220 | 2 | 440 | | | | 4.3.4 |
| 26 | | IWA ☐ INSIDE ROOM #738<br>OWA ☑ BY ENTRANCE | 2 / 2 | 12:01 | 15:41 | 220 | 2 | 440 | | | | 4.3.4 |
| 29 | | IWA ☐ INSIDE ROOM #740<br>OWA ☑ BY ENTRANCE | 2 / 2 | 12:00 | 15:47 | 220 | 2 | 440 | | | | 4.3.4 |
| 30 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | 4.1.5 |
| 31 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | 4.1.5 |
| 32 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | 4.1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Carlos A. Lipp | DATE 7-21-02 | TIME 1615 | RECEIVED BY: (SIGNATURE) R. Ortuoma | DATE 7.21.02 | TIME 16.15 |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA OTHER AMBIENT

LOT #: FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TEREGA MICHALCZUK | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT HIGH SCHOOL | DATE SUBMITTED: 07.21.02 |
| DATE SAMPLED: 07.21.02 | CONTACT: HAMID SAVOY | WORK AREA: 7th FLOOR | DATE LOGGED: # 20524 |
| POTOVETER NO.: TEG-16 | PROJECT NO.: M477-15217 /29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE CLASSROOM 702<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.00 | 20.00 | 240 | 2.0 | 480 | | | | |
| 02 | | IWA ☐ INSIDE CLASSROOM 704<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.01 | 20.01 | 240 | 2.0 | 480 | | | | |
| 05 | | IWA ☐ INSIDE CLASSROOM 731<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 1.5 | 16.02 | 20.02 | 240 | 1.75 | 420 | | | | |
| 06 | | IWA ☐ INSIDE CLASSROOM 735<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.03 | 20.03 | 240 | 2.0 | 480 | | | | |
| 07 | | IWA ☐ INSIDE CLASSROOM 737<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.04 | 20.04 | 240 | 2.0 | 480 | | | | |
| 08 | | IWA ☐ INSIDE CLASSROOM 739<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.05 | 20.05 | 240 | 2.0 | 480 | | | | |
| 09 | | IWA ☐ INSIDE CLASSROOM 726<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.06 | 20.06 | 240 | 2.0 | 480 | | | | |
| 10 | | IWA ☐ INSIDE CLASSROOM 736<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 1.5 | 16.07 | 20.07 | 240 | 1.75 | 420 | | | | |
| 11 | | IWA ☐ INSIDE CLASSROOM 731<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.02 | 24.02 | 240 | 2.0 | 480 | | | | |
| 12 | | IWA ☐ INSIDE CLASSROOM 735<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.03 | 24.03 | 240 | 2.0 | 480 | | | | |
| 13 | | IWA ☐ INSIDE CLASSROOM 737<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 1.5 | 20.04 | 24.04 | 240 | 1.75 | 420 | | | | |
| 14 | | IWA ☐ INSIDE CLASSROOM 739<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.05 | 24.05 | 240 | 2.0 | 480 | | | | |
| 15 | | IWA ☐ INSIDE CLASSROOM 726<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.06 | 24.05 | 240 | 2.0 | 480 | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): | | | RECEIVED FROM TEG DROP BOX (SIGNATURE): | | |
| RELINQUISHED BY: (SIGNATURE): | DATE: 07.21.02 | TIME: 12:30 | RECEIVED BY: (SIGNATURE): | DATE: 7/22/02 | TIME: |
| ANALYST: (SIGNATURE): | DATE: | TIME: | COMMENTS: 12 HOUR TURNAROUND NIOSH METOD 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — DSHA — OTHER NIOSH METOD 7082

LOT #: FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

[redacted] #20529

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TERRY MICHAELS | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT HIGH SCHOOL | DATE SUBMITTED: 07.21.02 |
| DATE SAMPLED: 07.17.02 | CONTACT: HAMID SHAH | WORK AREA: 7TH FLOOR | DATE LOGGED: |
| ROTOMETER NO.: TEG-16 | PROJECT NO.: M477-15217/29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 16 | | IWA ☐ INSIDE CLASSROOM 736<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.07 | 24.07 | 240 | 2.0 | 480 | | | | |
| 17 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| 18 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) [signature] | DATE 07.21.02 | TIME 12:30 | RECEIVED BY: (SIGNATURE) [signature] | DATE 7/21/02 | TIME 8:00 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR TURNAROUND NIOSH METOD 7082 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSM METOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107087

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-22-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>350 Chambers Street<br>7th Floor |
| **PROJECT NUMBER:** | M477-15217-29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-21-02 |
| **DATE RECEIVED:** | 07-22-02 |
| **DATE ANALYZED:** | 07-22-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20524 | Inside classroom 702 near entrance to hallway | <3.1 | 3.1 |
| 02 | 20524 | Inside classroom 704 near entrance to hallway | <3.1 | 3.1 |
| 05 | 20524 | Inside classroom 731 near entrance to hallway | <3.1 | 3.1 |
| 06 | 20524 | Inside classroom 735 near entrance to hallway | <3.1 | 3.1 |
| 07 | 20524 | Inside classroom 737 near entrance to hallway | <3.1 | 3.1 |
| 08 | 20524 | Inside classroom 739 near entrance to hallway | <3.1 | 3.1 |
| 09 | 20524 | Inside classroom 726 near entrance to hallway | <3.1 | 3.1 |
| 10 | 20524 | Inside classroom 736 near entrance to hallway | <3.6 | 3.6 |
| 11 | 20524 | Inside classroom 731 near entrance to hallway | <3.1 | 3.1 |
| 12 | 20524 | Inside classroom 735 near entrance to hallway | <3.1 | 3.1 |
| 13 | 20524 | Inside classroom 737 near entrance to hallway | <3.6 | 3.6 |
| 14 | 20524 | Inside classroom 739 near entrance to hallway | <3.1 | 3.1 |
| 15 | 20524 | Inside classroom 726 near entrance to hallway | <3.1 | 3.1 |
| 16 | 20524 | Inside classroom 736 near entrance to hallway | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 17 | 20524 | Field Blank | <1.5 µg | 1.5 µg |
| 18 | 20524 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229)

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD — PAGE 1 OF 1

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| CORBETT MCFARLANE | NYC SCA | STUYVESANT H.S CHAMBERS ST NYNY. | 7/22/02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7/22/02 | Hamid Savoy | 6th Floor 20541 | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| L-18 | M477-1527/29881 | CHRIS MCELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1-804 | | IWA ☐ OWA ☒ Room 639 Inside Classroom near entrance to Corridor/Hallway | 2.0/2.0 | 08:05 | 12:05 | 240 | 2.0 | 480 | | | | <3.1 |
| 2-800 | | IWA ☐ OWA ☒ Room 640 Inside Classroom near entrance to Corridor. | 2.0/2.0 | 08:10 | 12:10 | 240 | 2.0 | 480 | | | | <3.1 |
| 3-801 | | IWA ☐ OWA ☒ Room 638 Inside Classroom near entrance to Corridor. | 2.0/2.0 | 08:12 | 12:12 | 240 | 2.0 | 480 | | | | <3.1 |
| 4- | | IWA ☐ OWA ☒ Room 615B Inside Classroom near entrance to Corridor | 2.0/2.0 | 0930 | 12:14 | 164 | 2.0 | 328 | | | | <4.6 |
| 5- | | IWA ☐ OWA ☒ Room 627 Inside Classroom near entrance to Corridor | 2.0/2.0 | 0932 | 12:16 | 164 | 2.0 | 328 | | | | <4.6 |
| 6- | | IWA ☐ OWA ☒ Room 629 Inside Classroom near entrance to Corridor | 2.0/2.0 | 0934 | 12:18 | 164 | 2.0 | 328 | | | | <4.6 |
| 7- | | IWA ☐ OWA ☒ Room 635 Inside Classroom near entrance to Corridor | 2.0/2.0 | 09:36 | 12:20 | 164 | 2.0 | 328 | | | | <4.6 |
| 8- | | IWA ☐ OWA ☒ Room 636 Inside Classroom near entrance to Corridor | 2.0/2.0 | 0938 | 1222 | 164 | 2.0 | 328 | | | | <4.6 |
| 9 | | IWA ☐ OWA ☒ Room 639 Inside Classroom near entrance to Corridor | 2.0/2 | 1205 | 1530 | 205 | 2 | 410 | | | | <3.7 |
| 10 | | IWA ☐ OWA ☒ Room 640 Inside Classroom near entrance to Corridor | 2.0/2 | 1210 | 1532 | 202 | 2 | 404 | | | | <3.7 |
| 11 | | IWA ☐ OWA ☒ Room 638 Inside Classroom near entrance to Corridor | 2.0/2 | 1212 | 1534 | 202 | 2 | 404 | | | | <3.7 |
| 12 | | IWA ☐ OWA ☒ Room 615B Inside Classroom near entrance to Corridor | 2.0/2 | 1214 | 1536 | 202 | 2 | 404 | | | | <3.7 |
| 13 | | IWA ☐ OWA ☒ Room 627 Inside Classroom near entrance to Corridor | 2.0/2 | 1216 | 1538 | 202 | 2 | 404 | | | | <3.7 |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| C. McFarlane | 7/22/02 | | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| | 7/22/02 | 4:30pm | 7/22 6pm | | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS NIOSH METHOD 7082 | | |
| | | | 12 HRS TURNAROUND. FAX results (212)406-2535 | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER AMBIENT.

LOT # 13782 FILTER MANUFACTURER Env. Esp.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

also (516) 358-1780

NYC-WTC_000107090

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



TECHNICIAN: Corbett McFarlane
DATE SAMPLED: 7/22/02
ROTOMETER NO.: L-18
CLIENT: SCA
CONTACT: Arnold Savory
PROJECT NO.: M477-15217
SITE ADDRESS: Stuyvesant H.S Chamber St NYNY
WORK AREA: 6th Floor
PROJECT MANAGER: Chris McElgun
20541
DATE SUBMITTED: 7/22/02
DATE LOGGED:
DATE APPROVED / SIGNATURE:

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ Room 629 inside Classroom OWA ~~☐~~ near entrance to Corridor | 2.0/2 | 1218 | 1540 | 202 | 2 | 404 | | | <3.7 | |
| 15 | | IWA ☐ Room 635 inside Classroom OWA ~~☐~~ near entrance to Corridor | 2.0/2 | 1220 | 1542 | 202 | 2 | 404 | | | <3.7 | |
| 16 | | IWA ☐ Room 636 inside Classroom OWA ~~☐~~ near entrance to Corridor | 2.0/2 | 1222 | 1544 | 202 | 2 | 404 | | | <3.7 | |
| 17 | | IWA ☐ Rm 615 inside Classroom OWA ~~☐~~ near entrance to Corridor | 2.0/2 | 1320 | 1546 | 146 | 2 | 292 | | | <3.7 | |
| 18 | | IWA ☐ OWA ☐ FBL | | | | | | | | | <1.5 | |
| 19 | | IWA ☐ OWA ☐ FBL | | | | | | | | | <1.5 | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

RELINQUISHED TO TEG DROP BOX (SIGNATURE): C. McFarlane — DATE: 7/22/02 — TIME:

RELINQUISHED BY: (SIGNATURE) — DATE: 7/22/02 — TIME: 4:30PM

ANALYST: (SIGNATURE) — DATE: — TIME:

RECEIVED FROM TEG DROP BOX (SIGNATURE): — DATE: — TIME:

RECEIVED BY: (SIGNATURE) AM 07/22 6 pm — DATE: — TIME:

COMMENTS: NIOSH Method 7082 12 Hr turnaround
Ps. Jax Umubb. (212) 406-7535 & (516) 358-1780

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER AMBIENT

LOT # 13782 FILTER MANUFACTURER Env. Exp.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-23-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
6th Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-22-02
**DATE RECEIVED:** 07-22-02
**DATE ANALYZED:** 07-22-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20541 | Rm 639 Inside Classroom Near Entrance to Corridor/Hallway | <3.1 | 3.1 |
| 02 | 20541 | Rm 640 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 03 | 20541 | Rm 638 Inside Classroom Near Entrance to Corridor | <3.1 | 3.1 |
| 04 | 20541 | Rm 615B Inside Classroom Near Entrance to Corridor | <4.6 | 4.6 |
| 05 | 20541 | Rm 627 Inside Classroom Neat Entrance to Corridor | <4.6 | 4.6 |
| 06 | 20541 | Rm 629 Inside Classroom Near Entrance to Corridor | <4.6 | 4.6 |
| 07 | 20541 | Rm 635 Inside Classroo Near Entrance to Corridor | <4.6 | 4.6 |
| 08 | 20541 | Rm 636 Inside Classroo Near Entrance to Corridor | <4.6 | 4.6 |
| 09 | 20541 | Rm 639 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 10 | 20541 | Rm 640 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 11 | 20541 | Rm 638 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 12 | 20541 | Rm 615B Inside Classroo Near Entrance to Corridor | <3.7 | 3.7 |
| 13 | 20541 | Rm 627 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 14 | 20541 | Rm 629 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 15 | 20541 | Rm 635 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 16 | 20541 | Rm 636 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 17 | 20541 | Rm 615 Inside Classroom Near Entrance to Corridor | <3.7 | 3.7 |
| 18 | 20541 | Field Blank | <1.5 µg | 1.5 µg |
| 19 | 20541 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

**CERTIFICATION AND SIGNATURES**

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

[redacted]

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TEREK MICHALCZUK | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT HS, CHAMBERS ST. NY, NY | DATE SUBMITTED: 07.22.02 |
| DATE SAMPLED: 07.22.02 | CONTACT: HAMID GHAWOY | WORK AREA: 6TH FLOOR | DATE LOGGED: |
| ROTOMETER NO.: TEG-L16 | PROJECT NO.: M477-15217/29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | E/GC mg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE CLASSROOM 629<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.00 | 18.04 | 124 | 2.0 | 248 | | | | <6.0 |
| 02 | | IWA ☐ INSIDE CLASSROOM 635<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.01 | 20.01 | 240 | 2.0 | 480 | | | | <3.1 |
| 03 | | IWA ☐ INSIDE CLASSROOM 636<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.02 | 20.02 | 240 | 2.0 | 480 | | | | <3.1 |
| 04 | | IWA ☐ INSIDE CLASSROOM 638<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.03 | 18.03 | 124 | 2.0 | 248 | | | | <6.0 |
| 05 | | IWA ☐ INSIDE CLASSROOM 627<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.04 | 20.04 | 240 | 2.0 | 480 | | | | <3.1 |
| 06 | | IWA ☐ INSIDE LIBRARY BY RM 615B<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.05 | 20.05 | 240 | 2.0 | 480 | | | | <3.1 |
| 07 | | IWA ☐ INSIDE LIBRARY BY RM 615C<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.06 | 20.06 | 240 | 2.0 | 480 | | | | <3.1 |
| 08 | | IWA ☐ INSIDE LIBRARY LEFT SIDE<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.07 | 20.07 | 240 | 2.0 | 480 | | | | <3.1 |
| 09 | | IWA ☐ INSIDE ROOM 615B<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 16.08 | 20.08 | 240 | 2.0 | 480 | | | | <3.1 |
| 10 | | IWA ☐ INSIDE CLASSROOM 635<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.01 | 24.01 | 240 | 2.0 | 480 | | | | <3.1 |
| 11 | | IWA ☐ INSIDE CLASSROOM 636<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.02 | 24.02 | 240 | 2.0 | 480 | | | | 5.6 |
| 12 | | IWA ☐ INSIDE CLASSROOM 627<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.04 | 24.04 | 240 | 2.0 | 480 | | | | <3.1 |
| 13 | | IWA ☐ INSIDE LIBRARY RIGHT SIDE<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.06 | 24.06 | 240 | 2.0 | 480 | | | | <3.1 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): [signature] | DATE: 7/22/02 | TIME: 0000 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): [signature] | DATE: 7.22.02 | TIME: 2430 | RECEIVED BY: (SIGNATURE): R. Rowdina | DATE: 7.23.02 | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH METHOD 7082<br>12 HRS. TURNAROUND | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER AMBIENT

LOT #: NIOSH METOD 7082 — FILTER MANUFACTURER

YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

EHV # 1212 / 106-2535

NYC-WTC_000107094

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TEREFA MICHALCZUK | NYC SCA | STUYVESANT HS. CHAMBERS ST. NY. NY | 07.22.02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 07.22.02 | HAMID SAHOY | 6th FLOOR | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG-6-16 | M477-15217/24881 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | FIBER f/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ INSIDE LIBRARY MIDDLE SIDE<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.07 | 24.07 | 240 | 2.0 | 480 | | | | <3.1 |
| 15 | | IWA ☐ INSIDE LIBRARY LEFT SIDE<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.08 | 24.08 | 240 | 2.0 | 480 | | | | <3.1 |
| 16 | | IWA ☐ INSIDE CLASSROOM 615 B<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.09 | 24.09 | 240 | 2.0 | 480 | | | | <3.1 |
| 17 | | IWA ☐ INSIDE CLASSROOM 629<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.10 | 24.10 | 240 | 2.0 | 480 | | | | <3.1 |
| 18 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 19 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | 2/22/02 | 0100 | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| | 07.22. | 24.30 | R. Broudina | 7.23.02 | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS NIOSHA METOD 7082<br>12 HRS. TURNAROUND | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER AMBIENT

LOT # / FILTER MANUFACTURER NIOSHA METOD 7082

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Corbett McFarlane | CLIENT: SCA | SITE ADDRESS: Stuyvesant HS. Chambers ST NY | DATE SUBMITTED: 7/23/02 |
| DATE SAMPLED: 7/23/02 | CONTACT: Hamid Sabet | WORK AREA: 6 Floor / 5 Floor | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477-15217 | PROJECT MANAGER: Chris McElgun. | SITE APPROVED / SIGNATURE: 20578 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON. | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ RM 615(SE) inside Library near entrance to Corridor | 2/2 | 0730 | 1200 | 270 | 2 | 540 | | | | < 2.8 |
| 2 | | IWA ☐ OWA ☐ RM 601 inside room near entrance to Corridor | 2/2 | 0750 | 1202 | 252 | 2 | 504 | | | | < 3.0 |
| 3 | | IWA ☐ OWA ☐ Rm 501B inside room near entrance. | 2/2 | 0830 | 1204 | 214 | 2 | 428 | | | | < 3.5 |
| 4 | | IWA ☐ OWA ☐ RM 501C inside room near entrance | 2/2 | 0832 | 1206 | 214 | 2 | 428 | | | | < 3.5 |
| 5 | | IWA ☐ OWA ☐ Rm 503 inside classroom near entrance to Corridor | 2/2 | 0834 | 1208 | 214 | 2 | 428 | | | | < 3.5 |
| 6 | | IWA ☐ OWA ☐ RM 907 inside Rm (Chem. Lab) near entrance to hallway | 2/2 | 0836 | 1210 | 214 | 2 | 428 | | | | < 3.5 |
| 7 | | IWA ☐ OWA ☐ RM 615(SE) inside Library near entrance to Corridor | 2/2 | 1200 | 1530 | 210 | 2 | 420 | | | | < 3.6 |
| 8 | | IWA ☐ OWA ☐ Rm 601 inside Rm near entrance to hallway | 2/2 | 1202 | 1532 | 210 | 2 | 420 | | | | < 3.6 |
| 9 | | IWA ☐ OWA ☐ Rm 503 inside classroom near entrance to Corridor | 2/2 | 1208 | 1538 | 210 | 2 | 420 | | | | < 3.6 |
| 10 | | IWA ☐ OWA ☐ Rm K531 inside classroom near entrance to Corridor | 2/2 | 1330 | 1540 | 130 | 2 | 260 | | | | < 5.8 |
| 11 | | IWA ☐ OWA ☐ Rm 525 inside classroom near entrance to Corridor | 2/2 | 1332 | 1542 | 130 | 2 | 260 | | | | < 5.8 |
| 12 | | IWA ☐ OWA ☐ FBL 1 | | | | | | | | | | < 1.5 |
| 13 | | IWA ☐ OWA ☐ FBL 2 | | | | | | | | | | < 1.5 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): C. McFarlane | DATE: 7/23/02 | TIME: 1900 | RECEIVED FROM TEG DROP BOX (SIGNATURE): AC 07/23 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH 7082 12 HRS TAT. Ps. FAX TO. (212) 406-2535 Cp To TEG. | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER AMBIENT

LOT # 13782 FILTER MANUFACTURER ENV EXP.

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-24-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>6th Floor/5th floor |
| **PROJECT NUMBER:** | M477-15217 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-23-02 |
| **DATE RECEIVED:** | 07-23-02 |
| **DATE ANALYZED:** | 07-23-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20578 | Rm 615 (SE) Inside Library Near Entrance to Corridor | <2.8 | 2.8 |
| 02 | 20578 | Rm 601 Inside Room Near Entrance to Corridor | <3.0 | 3.0 |
| 03 | 20578 | Rm 501B Inside Room Near Entrance | <3.5 | 3.5 |
| 04 | 20578 | Rm 501C Inside Room Near Entrance | <3.5 | 3.5 |
| 05 | 20578 | Rm 503 Inside Cclassroom Near Entrance to Corridor | <3.5 | 3.5 |
| 06 | 20578 | Rm 907 Inside Rm (Chem Lab) Near Entrance to Hallway | <3.5 | 3.5 |
| 07 | 20578 | Rm 615 (SE) Inside Library Near Entrance to Corridor | <3.6 | 3.6 |
| 08 | 20578 | Rm 601 Inside Rm Near Entrance to Hallway | <3.6 | 3.6 |
| 09 | 20578 | Rm 503 Inside Classroo mNear Entrance to Corridor | <3.6 | 3.6 |
| 10 | 20578 | Rm 531 Inside Classroom Near Entrance to Corridor | <5.8 | 5.8 |
| 11 | 20578 | Rm 525 Inside Classroom Near Entrance to Corridor | <5.8 | 5.8 |
| 12 | 20578 | Field Blank | <1.5 µg | 1.5 µg |
| 13 | 20578 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

**CERTIFICATION AND SIGNATURES**

**ANALYSIS PERFORMED BY:** _____

**REPORT PREPARED BY:** _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** _____

**LABORATORY DIRECTOR:** _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 2

| | | | |
|---|---|---|---|
| TECHNICIAN: TERESA MICHALCZYK | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT H.S 345 CHAMBERS ST. NY NY | DATE SUBMITTED: 07.24.02 |
| DATE SAMPLED: 07.23.02 | CONTACT: HAMID SAHOJ | WORK AREA: 5TH FLOOR | DATE LOGGED: |
| ROTOMETER NO.: TEG -16 | PROJECT NO.: 1477 - 15217 LLW # 29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 501C<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.00 | 20.00 | 240 | 2.0 | 480 | | | | |
| 02 | | IWA ☐ INSIDE ROOM 501B<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.01 | 20.01 | 240 | 2.0 | 480 | | | | |
| 03 | | IWA ☐ INSIDE ROOM 503<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.02 | 20.02 | 240 | 2.0 | 480 | | | | |
| 04 | | IWA ☐ INSIDE ROOM 505<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/1.5 | 16.03 | 20.03 | 240 | 1.75 | 420 | | | | |
| 05 | | IWA ☐ INSIDE ROOM 507<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.04 | 20.04 | 240 | 2.0 | 480 | | | | |
| 06 | | IWA ☐ INSIDE ROOM 511<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.05 | 20.05 | 240 | 2.0 | 480 | | | | |
| 07 | | IWA ☐ INSIDE ROOM 513<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.06 | 20.06 | 240 | 2.0 | 480 | | | | |
| 08 | | IWA ☐ INSIDE ROOM 525<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/1.5 | 16.07 | 20.07 | 240 | 1.75 | 420 | | | | |
| 09 | | IWA ☐ INSIDE ROOM 531C<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.08 | 20.08 | 240 | 2.0 | 480 | | | | |
| 10 | | IWA ☐ INSIDE ROOM 1021A<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 16.10 | 20.10 | 240 | 2.0 | 480 | | | | |
| 11 | | IWA ☐ INSIDE ROOM 501C<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.00 | 24.00 | 240 | 2.0 | 480 | | | | |
| 12 | | IWA ☐ INSIDE ROOM 501B<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.01 | 24.01 | 240 | 2.0 | 480 | | | | |
| 13 | | IWA ☐ INSIDE ROOM 503<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0/2.0 | 20.02 | 24.02 | 240 | 2.0 | 480 | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Teresa Michalczyk | DATE: 07.24.02 | TIME: 1.00 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): Teresa Michalczyk | DATE: 07.24.02 | TIME: | RECEIVED BY: (SIGNATURE): K. Fil | DATE: 07/24/02 | TIME: 9:00 AM |
| ANALYST: (SIGNATURE): | DATE: | TIME: | COMMENTS: NIOSH METOD 7082<br>12 HOURS TURNAROUND PS FAX (212) 406-2535 | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER AMBIENT

LOT # 13782 ENV. EXP. — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107099

NYC 9/11 Public Portal Document

[redacted]

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#20600



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERESA MICHALCZUK | NYC SCA | STUYVESANT HS 345 CHAMBERS ST. NYNY | 07.24.02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 07.23.02 | HAMID SAWOJ | 5TH FLOOR | |
| **ROTOMETER NO.** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TE6-16 | M477-15217 LLW # 29881 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ INSIDE ROOM 505<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.03 | 24.03 | 240 | 2.0 | 480 | | | | |
| 15 | | IWA ☐ INSIDE ROOM 507<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.04 | 24.04 | 240 | 2.0 | 480 | | | | |
| 16 | | IWA ☐ INSIDE ROOM 511<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.05 | 24.05 | 240 | 2.0 | 480 | | | | |
| 17 | | IWA ☐ INSIDE ROOM 513<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.06 | 24.06 | 240 | 2.0 | 480 | | | | |
| 18 | | IWA ☐ INSIDE ROOM 525<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.07 | 24.07 | 240 | 2.0 | 480 | | | | |
| 19 | | IWA ☐ INSIDE ROOM 531 K<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.08 | 24.08 | 240 | 2.0 | 480 | | | | |
| 20 | | IWA ☐ INSIDE ROOM 1024 D-<br>OWA ☐ FIELD BLANK NEAR ENTRANCE TO HALLWAY | 2.0 / 2.0 | 20.10 | 24.10 | 240 | 2.0 | 480 | | | | |
| 21 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| 22 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Teresa | 07.24.02 | 1.00 | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| | 07.24.02 | | Kim | 7/24/02 | 9:00am |
| **ANALYST (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** NIOSH METOD 7082<br>12 HOURS TURNAROUND FAX 212 406-2535 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER AMBIENT

LOT # 13482 ENV. EXP.
FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-24-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>5th Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-23-02 |
| **DATE RECEIVED:** | 07-24-02 |
| **DATE ANALYZED:** | 07-24-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20600 | Inside Rm 501C Near Entrance to Hallway | <3.1 | 3.1 |
| 02 | 20600 | Inside Rm 501B Near Entrance to Hallway | <3.1 | 3.1 |
| 03 | 20600 | Inside Rm 503 Near Entrance to Hallway | <3.1 | 3.1 |
| 04 | 20600 | Inside Rm 505 Near Entrance to Hallway | <3.6 | 3.6 |
| 05 | 20600 | Inside Rm 507 Near Entrance to Hallway | <3.1 | 3.1 |
| 06 | 20600 | Inside Rm 511 Near Entrance to Hallway | <3.1 | 3.1 |
| 07 | 20600 | Inside Rm 513 Near Entrance to Hallway | <3.1 | 3.1 |
| 08 | 20600 | Inside Rm 525 Near Entrance to Hallway | <3.6 | 3.6 |
| 09 | 20600 | Inside Rm 531K Near Entrance to Hallway | <3.1 | 3.1 |
| 10 | 20600 | Inside Rm 1024A Near Entrance to Hallway | <3.1 | 3.1 |
| 11 | 20600 | Inside Rm 501C Near Entrance to Hallway | <3.1 | 3.1 |
| 12 | 20600 | Inside Rm 501B Near Entrance to Hallway | <3.1 | 3.1 |
| 13 | 20600 | Inside Rm 503 Near Entrance to Hallway | <3.1 | 3.1 |
| 14 | 20600 | Inside Rm 505 Near Entrance to Hallway | <3.1 | 3.1 |
| 15 | 20600 | Inside Rm 507 Near Entrance to Hallway | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20600 | Inside Rm 511 Near Entrance to Hallway | <3.1 | 3.1 |
| 17 | 20600 | Inside Rm 513 Near Entrance to Hallway | <3.1 | 3.1 |
| 18 | 20600 | Inside Rm 525 Near Entrance to Hallway | <3.1 | 3.1 |
| 19 | 20600 | Inside Rm 531K Near Entrance to Hallway | <3.1 | 3.1 |
| 20 | 20600 | Inside Rm 1024A Entrance to Hallway | <3.1 | 3.1 |
| 21 | 20600 | Field Blank | <1.5 µg | 1.5 µg |
| 22 | 20600 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

**CERTIFICATION AND SIGNATURES**

**ANALYSIS PERFORMED BY:** IL

**REPORT PREPARED BY:** [signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** [signature]

**LABORATORY DIRECTOR:** [signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



TECHNICIAN: Corbett McFarlane
CLIENT: SCA
SITE ADDRESS: Stuyvesant H.S. Chambers ST NY.
DATE SUBMITTED: 7/24/02
DATE SAMPLED: 7/24/02
CONTACT: Hamid Savoj
WORK AREA: 5th floor
DATE LOGGED:
ROTOMETER NO: 135
PROJECT NO.: M477-15217
PROJECT MANAGER: Chris McElgum. 20616
DATE APPROVED / SIGNATURE:

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | FIELD |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ RM 507 inside Classroom OWA ☐ near entrance to Corridor | 2/2 | 0750 | 1200 | 250 | 2 | 500 | | | | < 3.0 |
| 2 | | IWA ☐ 501B inside Room By OWA ☐ entrance. | 2/2 | 0752 | 1202 | 250 | 2 | 500 | | | | 6.7 |
| 3 | | IWA ☐ RM 511 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 0754 | 1204 | 250 | 2 | 500 | | | | < 3.0 |
| 4 | | IWA ☐ RM 525 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 0756 | 1206 | 250 | 2 | 500 | | | | 4.7 |
| 5 | | IWA ☐ RM 531 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 0758 | 1208 | 250 | 2 | 500 | | | | 3.8 |
| 6 | | IWA ☐ RM 403 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 0830 | 1210 | 220 | 2 | 440 | | | | 3.2 |
| 7 | | IWA ☐ RM 405 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 0832 | 1212 | 220 | 2 | 446 | | | | 4.9 |
| 8 | | IWA ☐ RM 507 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 1200 | 1530 | 210 | 2 | 420 | | | | 4.0 |
| 9 | | IWA ☐ RM 531 inside Classroom OWA ☐ near entrance to corridor | 2/2 | 1208 | 1532 | 264 | 2 | 408 | | | | 11.2 |
| 10 | | IWA ☐ Rm 403 inside Clan-room OWA ☐ near entrance to corridor | 2/2 | 1210 | 1534 | 204 | 2 | 408 | | | | 16.7 |
| 11 | | IWA ☐ Rm 405 inside Classroom OWA ☐ near entrance to corridor. | 2/2 | 1212 | 1536 | 204 | 2 | 408 | | | | 8.4 |
| 12 | | IWA ☐ RM. 401 inside room near OWA ☐ entrance to hallway. | 2/2 | 1214 | 1538 | 204 | 2 | 408 | | | | 15.3 |
| 13 | | IWA ☐. FBL #1 | | | | | | | | | | < 1.5 |
| 14 | | OWA ☐ FBL #2 | | | | | | | | | | < 1.5 |

RELINQUISHED TO TEG DROP BOX (SIGNATURE): C. McFarlane. DATE 7/24/02 TIME
RELINQUISHED BY: (SIGNATURE) DATE 7/24/02 TIME 5:45pm
ANALYST: (SIGNATURE) DATE TIME

RECEIVED FROM TEG DROP BOX (SIGNATURE): DATE 07/24 TIME 6pm
RECEIVED BY: (SIGNATURE) DATE TIME

COMMENTS: NIOSH 7402 12 HRS TAT
FAX results (212) 406-2535 Also to Taylor Lab

ORDER: PCM TEM BGRD PRE DURING POST OSHA OTHER AMBIENT
LOT # 13782 FILTER MANUFACTURER ENV EXP.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107103

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-25-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>5th Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-24-02 |
| **DATE RECEIVED:** | 07-24-02 |
| **DATE ANALYZED:** | 07-24-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20616 | Rm 507 Inside Classroom Near Entrance to Corridor | <3.0 | 3.0 |
| 02 | 20616 | Rm 501B Inside Room by Entrance | 6.7 | 3.0 |
| 03 | 20616 | Rm 511 Inside Classroom Near Entrance to Corridor | <3.0 | 3.0 |
| 04 | 20616 | Rm 525 Inside Classroom Near Entrance to Corridor | 4.7 | 3.0 |
| 05 | 20616 | Rm 531Inside Classroom Near Entrance to Corridor | 3.8 | 3.0 |
| 06 | 20616 | Rm 403 Inside Classroom Near Entrance to Corridor | 3.2 | 3.4 |
| 07 | 20616 | Rm 405 Inside Classroom Near Entrance to Corridor | 4.9 | 3.4 |
| 08 | 20616 | Rm 507 Inside Classroom Near Entrance to Corridor | 4.0 | 3.6 |
| 09 | 20616 | Rm 531 Inside Classroom Near Entrance to Corridor | 11.2 | 3.7 |
| 10 | 20616 | Rm 403 Inside Classroom Near Entrance to Corridor | 16.7 | 3.7 |
| 11 | 20616 | Rm 405 Inside Classroom Near Entrance to Corridor | 8.4 | 3.7 |
| 12 | 20616 | Rm 401 Inside Room Near Entrance to Hallway | 15.3 | 3.7 |
| 13 | 20616 | Field Blank | <1.5 µg | 1.5 µg |
| 14 | 20616 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/25/02 |
| DATE SAMPLED: 7/24/02 | CONTACT: HAMID SAVOS | WORK AREA: 4th Floor | DATE LOGGED: |
| ROTOMETER NO: L-16 | PROJECT NO: M477-15217/29881 | PROJECT MANAGER: Chris McElwain | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC MG/M³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☐ Room 401 At Entrance | 2.0 / 2.0 | 1600 | 1930 | 210 | 2.0 | 420 | | | | <3.6 |
| 02 | | IWA ☐ OWA ☐ Room 403 At Entrance | 2.0 / 2.0 | 1602 | 1932 | 210 | 2.0 | 420 | | | | <3.6 |
| 03 | | IWA ☐ OWA ☐ Room 404 At Entrance | 2.0 / 2.0 | 1604 | 1934 | 210 | 2.0 | 420 | | | | <3.6 |
| 04 | | IWA ☐ OWA ☐ Room 405 At Entrance | 2.0 / 2.0 | 1606 | 1936 | 210 | 2.0 | 420 | | | | <3.6 |
| 05 | | IWA ☐ OWA ☐ Room 407 At Entrance | 2.0 / 2.0 | 1608 | 1938 | 210 | 2.0 | 420 | | | | <3.6 |
| 06 | | IWA ☐ OWA ☐ Room 411 At Entrance | 2.0 / 2.0 | 1610 | 1940 | 210 | 2.0 | 420 | | | | 5.2 |
| 07 | | IWA ☐ OWA ☐ Room 413 At Entrance | 2.0 / 2.0 | 1612 | 1942 | 210 | 2.0 | 420 | | | | <3.6 |
| 08 | | IWA ☐ OWA ☐ Room 911 At Entrance | 2.0 / 2.0 | 1614 | 1944 | 210 | 2.0 | 420 | | | | <3.6 |
| 09 | | IWA ☐ OWA ☐ Room 401 At Entrance | 2.0 / 2.0 | 2000 | 0000 | 240 | 2.0 | 480 | | | | <3.1 |
| 10 | | IWA ☐ OWA ☐ Room 403 At Entrance | 2.0 / 2.0 | 2002 | 2302 | 180 | 2.0 | 360 | | | | 6.1 |
| 11 | | IWA ☐ OWA ☐ Room 404 At Entrance | 2.0 / 2.0 | 2004 | 0004 | 240 | 2.0 | 480 | | | | 4.7 |
| 12 | | IWA ☐ OWA ☐ Room 405 At Entrance | 2.0 / 2.0 | 2006 | 2306 | 180 | 2.0 | 360 | | | | <4.2 |
| 13 | | IWA ☐ OWA ☐ Room 407 At Entrance | 2.0 / 2.0 | 2008 | 0008 | 240 | 2.0 | 480 | | | | <3.1 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | DATE 7/25/02 | TIME 0100 | RECEIVED BY: (SIGNATURE) R. Droudina | DATE 7.25.02 | TIME 01.00 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS (12 Hour TAT) FAX to TEG at 212-406-2535 and 516-368-1780 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH METHOD 7082

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107105

20635

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 2 OF 2

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| Gary McKenzie | NYC SCA | Stuyvesant H.S | 7/25/02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 7/24/02 | SCA | 4th Floor | |
| ROTAMETER NO | PROJECT NO | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| L-16 | M477-15217/29881 | Chris McElgun | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC (#/M³) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☐ Room 411 at Entrance | 2.0 / 2.0 | 2010 | 0010 | 240 | 2.0 | 480 | | | | <3.1 |
| 15 | | IWA ☐ OWA ☐ Room 413 at Entrance | 2.0 / 2.0 | 2012 | 0012 | 240 | 2.0 | 480 | | | | <3.1 |
| 16 | | IWA ☐ OWA ☐ Room ~~411~~ 427 At Entrance | 2.0 / 2.0 | 2014 | 0014 | 240 | 2.0 | 480 | | | | <3.1 |
| 17 | | IWA ☐ OWA ☐ Room 429 At Entrance | 2.0 / 2.0 | 2016 | 0016 | 240 | 2.0 | 480 | | | | <3.1 |
| 18 | | IWA ☐ OWA ☐ Room 431 At Entrance | 2.0 / 2.0 | 2018 | 0018 | 240 | 2.0 | 480 | | | | <3.1 |
| 19 | | IWA ☐ OWA ☐ Room 911 At Entrance | 2.0 / 2.0 | 2020 | 0320 | 180 | 2.0 | 360 | | | | <4.2 |
| FB-20 | | IWA ☐ OWA ☐ FB-20 | | | | | | | | | | <1.5 |
| FB-21 | | IWA ☐ OWA ☐ FB-21 | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED BY: (SIGNATURE) Gary McKenzie | 7/25/02 | 0100 | RECEIVED BY: (SIGNATURE) R. Arouidina | 7.25.02 | 01.00 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS (12 Hour TAT) FAX to TEG at 212-406-2535 + 516-358-[redacted]1780 | | |

CIRCLE: PCM TEM — BORO PRE DURING POST — OSHA OTHER NIOSH METHOD 7400

LOT # FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Sampler ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-25-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>4th Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE**<br>**DATE RECEIVED:**<br>**DATE ANALYZED:** | 07-25-02<br>07-25-02<br>07-25-02 |
| **SAMPLE MEDIA:**<br>**ANALYSIS REQUIRED:** | Air Samples<br>Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20635 | Rm 401 at Entrance | <3.6 | 3.6 |
| 02 | 20635 | Rm 403 at Entrance | <3.6 | 3.6 |
| 03 | 20635 | Rm 404 at Entrance | <3.6 | 3.6 |
| 04 | 20635 | Rm 405 at Entrance | <3.6 | 3.6 |
| 05 | 20635 | Rm 407 at Entrance | <3.6 | 3.6 |
| 06 | 20635 | Rm 411 at Entrance | 5.2 | 3.6 |
| 07 | 20635 | Rm 413 at Entrance | <3.6 | 3.6 |
| 08 | 20635 | Rm 911 at Entrance | <3.6 | 3.6 |
| 09 | 20635 | Rm 401 at Entrance | <3.1 | 3.1 |
| 10 | 20635 | Rm 403 at Entrance | 6.1 | 4.2 |
| 11 | 20635 | Rm 404 at Entrance | 4.7 | 3.1 |
| 12 | 20635 | Rm 405 at Entrance | <4.2 | 4.2 |
| 13 | 20635 | Rm 407 at Entrance | <3.1 | 3.1 |
| 14 | 20635 | Rm 411 at Entrance | <3.1 | 3.1 |
| 15 | 20635 | Rm 413 at Entrance | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20635 | Rm 427 at Entrance | <3.1 | 3.1 |
| 17 | 20635 | Rm 429 at Entrance | <3.1 | 3.1 |
| 18 | 20635 | Rm 431 at Entrance | <3.1 | 3.1 |
| 19 | 20635 | Rm 911 at Entrance | <4.2 | 4.2 |
| FB-20 | 20635 | Field Blank | <1.5 µg | 1.5 µg |
| FB-21 | 20635 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

**CERTIFICATION AND SIGNATURES**

**ANALYSIS PERFORMED BY:** RD

**REPORT PREPARED BY:** [signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** [signature]

**LABORATORY DIRECTOR:** [signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: AL. Ilizarov | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 20868 | DATE SUBMITTED: 7/25/02 |
| DATE SAMPLED: 7/25/02 | CONTACT: Hamid Savoj | WORK AREA: 4th Floor | DATE LOGGED: |
| ROTOMETER NO.: TEG-L16 | PROJECT NO: M488-15217/29881 | PROJECT MANAGER: Chris McEgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| AL-01 | | IWA ☐ OWA ☐ Room # 411 By Entrance | 2/2 | 07:30 | 11:30 | 240 | 2 | 480 | | | | <3.1 |
| AL-02 | | IWA ☐ OWA ☐ Room # 413 By Entrance | 2/2 | 07:32 | 11:32 | 240 | 2 | 480 | | | | <3.1 |
| AL-03 | | IWA ☐ OWA ☐ Room # 427 By Entrance | 2/2 | 07:34 | 11:34 | 240 | 2 | 480 | | | | <3.1 |
| AL-04 | | IWA ☐ OWA ☐ Room # 429 By Entrance | 2/2 | 07:36 | 11:36 | 240 | 2 | 480 | | | | <3.1 |
| AL-05 | | IWA ☐ OWA ☐ Room # 431 By Entrance | 2/2 | 07:38 | 11:38 | 240 | 2 | 480 | | | | <3.1 |
| AL-06 | | IWA ☐ OWA ☐ Room # 433 By Entrance | 2/2 | 07:40 | 11:40 | 240 | 2 | 480 | | | | <3.1 |
| AL-07 | | IWA ☐ OWA ☐ Room # 435 By Entrance | 2/2 | 07:42 | 11:42 | 240 | 2 | 480 | | | | <3.1 |
| AL-08 | | IWA ☐ OWA ☐ Room # 437 By Entrance | 2/2 | 07:44 | 11:44 | 240 | 2 | 480 | | | | <3.1 |
| AL-09 | | IWA ☐ OWA ☐ Room # 411 By Entrance | 2/2 | 11:31 | 15:01 | 210 | 2 | 420 | | | | 5.1 |
| AL-10 | | IWA ☐ OWA ☐ Room # 413 | 2/2 | 11:33 | 15:03 | 210 | 2 | 420 | | | | <3.6 |
| AL-11 | | IWA ☐ OWA ☐ Room # 427 | 2/2 | 11:35 | 15:05 | 210 | 2 | 420 | | | | 4.3 |
| AL-12 | | IWA ☐ OWA ☐ Room # 429 | 2/2 | 11:37 | 15:07 | 210 | 2 | 420 | | | | 3.6 |
| AL-13 | | IWA ☐ OWA ☐ Room # 431 | 2/2 | 11:39 | 15:09 | 210 | 2 | 420 | | | | 7.6 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos Ilizarov | DATE: 7-25-02 | TIME: 1702 | RECEIVED FROM TEG DROP BOX (SIGNATURE): A. Chin 07/25 | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/25/02 | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS | | |

CIRCLE: PCM / TEM — BGRD PRE DURING POST — OSHA — OTHER Ambient.

LOT # Nov94 7082 FILTER MANUFACTURER

WHITE: Office Copy YELLOW:

NYC-WTC_000107109

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: AL. Iacanello | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 20668 | DATE SUBMITTED: 7/25/02 |
| DATE SAMPLED: 7/25/02 | CONTACT: Hamid Sarof | WORK AREA: 4th floor | DATE LOGGED: |
| ROTOMETER NO: TEG-616 | PROJECT NO: M477-15217/29881 | PROJECT MANAGER: Chris McEGan | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| AL-14 | | IWA ☐ OWA ☐ Room # 433 64 entrance | 2/2 | 11:41 | 15:11 | 210 | 2 | 420 | | | | 6.6 |
| AL-15 | | IWA ☐ OWA ☐ Room # 435 | 2/2 | 11:43 | 15:13 | 210 | 2 | 420 | | | | 7.1 |
| AL-16 | | IWA ☐ OWA ☐ Room # 437 | 2/2 | 11:45 | 15:15 | 210 | 2 | 420 | | | | 8.8 |
| AL-17 | | IWA ☐ OWA ☐ E/13 | | | | | | | | | | <1.5 |
| A-18 | | IWA ☐ OWA ☐ F/B | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos | 7-25-02 | 1702 | RECEIVED FROM TEG DROP BOX (SIGNATURE): Mike 07/25 | | |
| RELINQUISHED BY: (SIGNATURE) | 7/25/02 | | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER Ambien

LOT # NIOSH .7082 FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-26-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
4th Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-25-02
**DATE RECEIVED:** 07-25-02
**DATE ANALYZED:** 07-25-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| AL-01 | 20668 | Rm 411 by Entrance | <3.1 | 3.1 |
| AL-02 | 20668 | Rm 413 by Entrance | <3.1 | 3.1 |
| AL-03 | 20668 | Rm 427 by Entrance | <3.1 | 3.1 |
| AL-04 | 20668 | Rm 429 by Entrance | <3.1 | 3.1 |
| AL-05 | 20668 | Rm 431 by Entrance | <3.1 | 3.1 |
| AL-06 | 20668 | Rm 433 by Entrance | <3.1 | 3.1 |
| AL-07 | 20668 | Rm 435 by Entrance | <3.1 | 3.1 |
| AL-08 | 20668 | Rm 437 by Entrance | <3.1 | 3.1 |
| AL-09 | 20668 | Rm 411 by Entrance | 5.1 | 3.6 |
| AL-10 | 20668 | Rm 413 by Entrance | <3.6 | 3.6 |
| AL-11 | 20668 | Rm 427 by Entrance | 4.3 | 3.6 |
| AL-12 | 20668 | Rm 429 by Entrance | 3.6 | 3.6 |
| AL-13 | 20668 | Rm 431 by Entrance | 7.6 | 3.6 |
| AL-14 | 20668 | Rm 433 by Entrance | 6.6 | 3.6 |
| AL-15 | 20668 | Rm 435 by Entrance | 7.1 | 3.6 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| AL-16 | 20668 | Rm 437 by Entrance | 8.8 | 3.6 |
| AL-17 | 20668 | Field Blank | <1.5 µg | 1.5 µg |
| AL-18 | 20668 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1.
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TERENCE MICHALCZUK | CLIENT: NYC SCH | SITE ADDRESS: STUYVESANT HS. 345 CHAMBERS ST. NY.NY | DATE SUBMITTED: 07.25.02 |
| DATE SAMPLED: 07.25.02 | CONTACT: HAMID SAWOJ | WORK AREA: 4TH FLOOR # 20672 | DATE LOGGED: |
| ROTOMETER NO: TEG-16 | PROJECT NO.: M477-15217/29881 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC (f/cm³) |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| AL-01 | | IWA ☐ INSIDE CLASSROOM 433<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.00 | 20.00 | 240 | 2 | 480 | | | | <3.1 |
| AL-02 | | IWA ☐ INSIDE CLASSROOM 435<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.01 | 20.01 | 240 | 2 | 480 | | | | 4.1 |
| AL-03 | | IWA ☐ INSIDE CLASSROOM 437<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.02 | 20.02 | 240 | 2 | 480 | | | | <3.1 |
| AL-04 | | IWA ☐ INSIDE CLASSROOM 439<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.03 | 20.03 | 240 | 2 | 480 | | | | <3.1 |
| AL-05 | | IWA ☐ INSIDE CLASSROOM 451<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.04 | 20.04 | 240 | 2 | 480 | | | | 2.6 |
| AL-06 | | IWA ☐ INSIDE CLASSROOM 450<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.05 | 20.05 | 240 | 2 | 480 | | | | 2.8 |
| AL-07 | | IWA ☐ INSIDE CLASSROOM 307<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.10 | 20.10 | 240 | 2 | 480 | | | | 3.8 |
| AL-08 | | IWA ☐ INSIDE CLASSROOM 315<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.11 | 20.11 | 240 | 2 | 480 | | | | 2.8 |
| AL-09 | | IWA ☐ INSIDE ROOM 433<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.00 | 23.00 | 180 | 2 | 360 | | | | 3.3 |
| AL-10 | | IWA ☐ INSIDE ROOM 435<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.01 | 24.01 | 240 | 2 | 480 | | | | <3.1 |
| AL-11 | | IWA ☐ INSIDE ROOM 434<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.02 | 24.02 | 240 | 2 | 480 | | | | <3.1 |
| AL-12 | | IWA ☐ INSIDE ROOM 439<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.03 | 24.03 | 240 | 2 | 480 | | | | <3.1 |
| AL-13 | | IWA ☐ INSIDE ROOM 451<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.04 | 22.14 | 134 | 2 | 248 | | | | <6.0 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): [signature] | DATE: 7-25-02 | TIME: 1AM | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): [signature] | DATE: 07.25.02 | TIME: 24.30 | RECEIVED BY: (SIGNATURE): [signature] | DATE: 7/26/2 | TIME: 8a |
| ANALYST: (SIGNATURE): | DATE: | TIME: | COMMENTS: NIOSH 7082 12 HRS TAT. FAX 212 406-2535 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER AMBIENT

LOT # FILTER MANUFACTURER: 13782 GVU EXP.

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: TERESA MICHALOVIC | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT HS. 345 CHAMBERS ST. NY, NY | DATE SUBMITTED: 07.25.02 |
| DATE SAMPLED: 07.25.02 | CONTACT: HAMID SAWOZ | WORK AREA: 4TH FLOOR #20672 | DATE LOGGED |
| ROTOMETER NO: TEG-16 | PROJECT NO.: M477-15217/29881 | PROJECT MANAGER: CHRIS MCEGGUN | DATE APPROVED / SIGNATURE |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC 5/m² |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| PE14 | | IWA ☐ INSIDE CLASSROOM 450<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2 / 2 | 20.05 | 23.35 | 210 | 2 | 420 | | | | <3.6 |
| PE15 | | IWA ☐ INSIDE ROOM 307<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2 / 2 | 20.10 | 24.10 | 240 | 2 | 480 | | | | <3.1 |
| PE-16 | | IWA ☐ INSIDE ROOM 315<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2 / 2 | 20.11 | 24.11 | 240 | 2 | 440 | | | | <3.1 |
| PE-17 | | IWA ☐ INSIDE ROOM 907<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2 / 2 | 20.15 | 24.15 | 240 | 2 | 480 | | | | <3.1 |
| 18 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 19 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) Teresa Michalovic | DATE 07.25.02 | TIME 24.30 | RECEIVED BY (SIGNATURE) | DATE 7/26/2 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS NIOSH 7082 12 HRS TAT. FAX TO 212 406-2535 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER AMBIENT

LOT # 13782 ENV. EXPRESS — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107114

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-26-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
4th Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-25-02
**DATE RECEIVED:** 07-25-02
**DATE ANALYZED:** 07-25-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| AL-01 | 20672 | Inside Classroom 433 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-02 | 20672 | Inside Classroom 435 Near Entrance to Hallway | 4.1 | 3.1 |
| AL-03 | 20672 | Inside Classroom 437 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-04 | 20672 | Inside Classroom 439 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-05 | 20672 | Inside Classroom 451 Near Entrance to Hallway | 2.6 | 3.1 |
| AL-06 | 20672 | Inside Classroom 450 Near Entrance to Hallway | 2.8 | 3.1 |
| AL-07 | 20672 | Inside Classroom 307 Near Entrance to Hallway | 3.8 | 3.1 |
| AL-08 | 20672 | Inside Classroom 315 Near Entrance to Hallway | 2.8 | 3.1 |
| AL-09 | 20672 | Inside Classroom 433 Near Entrance to Hallway | 3.3 | 4.2 |
| AL-10 | 20672 | Inside Classroom 435 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-11 | 20672 | Inside Classroom 437 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-12 | 20672 | Inside Classroom 439 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-13 | 20672 | Inside Classroom 451 Near Entrance to Hallway | <6.0 | 6.0 |
| AL-14 | 20672 | Inside Classroom 450 Near Entrance to Hallway | <3.6 | 3.6 |
| AL-15 | 20672 | Inside Classroom 307 Near Entrance to Hallway | <3.1 | 3.1 |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| AL-16 | 20672 | Inside Classroom 315 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-17 | 20672 | Inside Room 907 Near Entrance to Hallway | <3.1 | 3.1 |
| AL-18 | 20672 | Field Blank | <1.5 µg | 1.5 µg |
| AL-19 | 20672 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 µg/m³ and a permissible exposure level (PEL) of 50 µg/m³ for personal samples.
NOTE 3:
Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP **DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD** 2076 PAGE 1 OF 1

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERESA MICHALCZUK | NYC SCA | STUYVESANT HS 345 CHAMBERS ST NY NY | 27.07.02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 07.27.02 | HAMID SAWOZ | 3RD FLOOR | |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG L-16 | 14477-15217/29881 | CHRIS MCELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | ug/m³ <FIGC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 325<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.00 | 20.00 | 240 | 2 | 480 | | | | <3.1 |
| 02 | | IWA ☐ INSIDE ROOM 327<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.01 | 20.01 | 240 | 2 | 480 | | | | <3.1 |
| 03 | | IWA ☐ INSIDE ROOM 335<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.02 | 20.02 | 240 | 2 | 480 | | | | <3.1 |
| 04 | | IWA ☐ INSIDE ROOM 337<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.03 | 20.03 | 240 | 2 | 480 | | | | <3.1 |
| 05 | | IWA ☐ INSIDE ROOM 339<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.04 | 20.04 | 240 | 2 | 480 | | | | <3.1 |
| 06 | | IWA ☐ INSIDE ROOM 325<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.00 | 23.00 | 180 | 2 | 360 | | | | <4.2 |
| 07 | | IWA ☐ INSIDE ROOM 324<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.01 | 23.01 | 180 | 2 | 360 | | | | <4.2 |
| 08 | | IWA ☐ INSIDE ROOM 335<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.02 | 23.02 | 180 | 2 | 360 | | | | <4.2 |
| 09 | | IWA ☐ INSIDE ROOM 337<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.03 | 23.03 | 180 | 2 | 360 | | | | <4.2 |
| 10 | | IWA ☐ INSIDE ROOM 339<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.04 | 23.04 | 180 | 2 | 360 | | | | <4.2 |
| 11 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 12 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

20716

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | 07.27.02 | 24.30 | | | |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY (SIGNATURE) | DATE | TIME |
| | 07.28.02 | 1.00 | Mei Wang NYTL | 7/28/02 | 6 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: NIOSH 7082 12 HRS TAT. PS FAX 212 406-2535 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER AMBIENT

LOT # 13782 ENV. EXP. FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-29-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
3rd Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-27-02
**DATE RECEIVED:** 07-27-02
**DATE ANALYZED:** 07-27-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20716 | Inside Rm 325 Near Entrance to Hallway | <3.1 | 3.1 |
| 02 | 20716 | Inside Rm 327 Near Entrance to Hallway | <3.1 | 3.1 |
| 03 | 20716 | Inside Rm 335 Near Entrance to Hallway | <3.1 | 3.1 |
| 04 | 20716 | Inside Rm 337 Near Entrance to Hallway | <3.1 | 3.1 |
| 05 | 20716 | Inside Rm 339 Near Entrance to Hallway | <3.1 | 3.1 |
| 06 | 20716 | Inside Rm 325 Near Entrance to Hallway | <4.2 | 4.2 |
| 07 | 20716 | Inside Rm 327 Near Entrance to Hallway | <4.2 | 4.2 |
| 08 | 20716 | Inside Rm 335 Near Entrance to Hallway | <4.2 | 4.2 |
| 09 | 20716 | Inside Rm 337 Near Entrance to Hallway | <4.2 | 4.2 |
| 10 | 20716 | Inside Rm 339 Near Entrance to Hallway | <4.2 | 4.2 |
| 11 | 20716 | Field Blank | <1.5 µg | 1.5 µg |
| 12 | 20716 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**

NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.

NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

20722

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: NYRON WILLIAMS | CLIENT: SCA | SITE ADDRESS: STUYVESANT HIGH SCHOOL | DATE SUBMITTED: |
| DATE SAMPLED: 07-28-02 | CONTACT: HANNA SAVOJ | WORK AREA: 3RD FLOOR | DATE LOGGED: |
| ROTOMETER NO: T.E.G 16 | PROJECT NO.: M477-15819/29881 | PROJECT MANAGER: CHRIS MCELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | FIBC s/cc/m |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☑ INSIDE ROOM # 301A BY ENTRANCE | 2 / 2 | 08:02 | 11:52 | 230 | 2 | 440 | | | | 4.4 |
| 02 | | IWA ☐ OWA ☑ INSIDE ROOM # 303 BY ENTRANCE | 2 / 2 | 08:03 | 11:53 | 230 | 2 | 440 | | | | 5.9 |
| 03 | | IWA ☐ OWA ☑ INSIDE ROOM # 305 BY ENTRANCE | 2 / 2 | 08:04 | 11:54 | 230 | 2 | 440 | | | | 4.0 |
| 04 | | IWA ☐ OWA ☑ INSIDE ROOM # 305 BY ENTRANCE | 2 / 2 | 08:05 | 11:55 | 230 | 2 | 440 | | | | 5.4 |
| 05 | | IWA ☐ OWA ☑ INSIDE ROOM # 301A BY ENTRANCE | 2 / 2 | 12:00 | 15:30 | 210 | 2 | 420 | | | | 4.4 |
| 06 | | IWA ☐ OWA ☑ INSIDE ROOM # 303 BY ENTRANCE | 2 / 2 | 12:01 | 15:31 | 210 | 2 | 420 | | | | <3.6 |
| 07 | | IWA ☐ OWA ☑ INSIDE ROOM # 305 BY ENTRANCE | 2 / 2 | 12:02 | 15:32 | 210 | 2 | 420 | | | | <3.6 |
| 08 | | IWA ☐ OWA ☑ INSIDE ROOM # 305 BY ENTRANCE | 2 / 2 | 12:03 | 15:33 | 210 | 2 | 420 | | | | <3.6 |
| 09 | | IWA ☐ OWA ☐ FIELD BLANK | / | | | | | | | | | <1.5 |
| 10 | | IWA ☐ OWA ☐ FIELD BLANK | / | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Carlos G Lopez | DATE: 7-28-02 | TIME: 1610 | RECEIVED FROM TEG DROP BOX (SIGNATURE): | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE): Nyron Williams | DATE: 7-28-02 | TIME: | RECEIVED BY: (SIGNATURE): R. Arolfina | DATE: 7.28.02 | TIME: 16.15 |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS | | |

CIRCLE: PCM TEM

BORD PRE DURING POST

OSHA OTHER AMBIENT

LOT #

FILTER MANUFACTURER

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-29-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
3rd Floor

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-28-02
**DATE RECEIVED:** 07-28-02
**DATE ANALYZED:** 07-28-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20722 | Inside Rm 301A by Entrance | 4.4 | 3.4 |
| 02 | 20722 | Inside Rm 303 by Entrance | 5.9 | 3.4 |
| 03 | 20722 | Inside Rm 305 by Entrance | 4.0 | 3.4 |
| 04 | 20722 | Inside Rm 325 by Entrance | 5.4 | 3.4 |
| 05 | 20722 | Inside Rm 301A by Entrance | 4.4 | 3.6 |
| 06 | 20722 | Inside Rm 303 by Entrance | <3.6 | 3.6 |
| 07 | 20722 | Inside Rm 305 by Entrance | <3.6 | 3.6 |
| 08 | 20722 | Inside Rm 325 by Entrance | <3.6 | 3.6 |
| 09 | 20722 | Field Blank | <1.5 µg | 1.5 µg |
| 10 | 20722 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**

NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.

NOTE 3:
Blank units are in µg

NYC-WTC_000107120

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERESA MICHALCZUK | NYC SCA | STUYVESANT HS. CHAMBERS ST. NYNY | 07.28.02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 07.28.02 | HAMID SAWOJ | 3rd FLOOR | # 20726 |
| ROTOMETER NO. | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG L-16 | M477-15217/29881 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 313<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.00 | 20.00 | 240 | 2 | 480 | | | | |
| 02 | | IWA ☐ INSIDE ROOM 313<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.00 | 23.10 | 190 | 2 | 380 | | | | |
| 03 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| 04 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Teresa Lefkow | 07.28.02 | 24.30 | | | |
| RELINQUISHED BY (SIGNATURE) | DATE | TIME | RECEIVED BY (SIGNATURE) | DATE | TIME |
| Teresa Lefkow | 07.29.02 | 1.00 | TERESA MICHALCZUK | 7-29-02 | 7/29/02 8:00 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS NIOSH 7082 12 HRS TAT<br>FAX TO 212 406-2535 | | |

CIRCLE: PCM TEM
BGRD PRE DURING POST
OSHA OTHER AMMIENT

LOT # 13182 FILTER MANUFACTURER GNV EXP.

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 07-29-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>3rd Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 07-28-02 |
| **DATE RECEIVED:** | 07-29-02 |
| **DATE ANALYZED:** | 07-29-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20726 | Inside Room 313 Near Entrance to Hallway | <3.1 | 3.1 |
| 02 | 20726 | Inside Room 313 Near Entrance to Hallway | <3.9 | 3.9 |
| 03 | 20726 | Field Blank | <1.5 µg | 1.5 µg |
| 04 | 20726 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

**ANALYSIS PERFORMED BY:** TL

**REPORT PREPARED BY:** [signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

**QUALITY ASSURANCE COORDINATOR:** [signature]

**LABORATORY DIRECTOR:** [signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

20700

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers | DATE SUBMITTED: 7/26/02 |
| DATE SAMPLED: 7/26/02 | CONTACT: Hamid Saos | WORK AREA: 2ND & 8TH Floors | DATE LOGGED: |
| ROTOMETER NO: 16 | PROJECT NO: M477-15217 | PROJECT MANAGER: Chris McElwain | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | | µg/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ Inside room 315 at entrance to corridor | 2.0 / 2.0 | 938 am | 1130 am | 240 | 2.0 | 480 | | | | <3.1 |
| 2 | | IWA ☐ OWA ☑ Inside room 309 at entrance to corridor | 2.0 / 2.0 | 932 am | 1132 am | 240 | 2.0 | 480 | | | | <3.1 |
| 3 | | IWA ☐ OWA ☑ Inside room 907 at entrance to corridor. | 2.0 / 2.0 | 934 am | 1134 am | 240 | 2.0 | 480 | | | | <3.1 |
| 4 | | IWA ☐ OWA ☑ Inside room 802 at entrance to corridor | 2.0 / 2.0 | 936 am | 1136 am | 240 | 2.0 | 480 | | | | <3.1 |
| 5 | | IWA ☐ OWA ☑ Inside room 807, at entrance to corridor | 2.0 / 2.0 | 938 am | 1138 am | 240 | 2.0 | 480 | | | | <3.1 |
| 6 | | IWA ☐ OWA ☑ Inside room 819. at entrance to corridor | 2.0 / 2.0 | 940 am | 1140 am | 240 | 2.0 | 480 | | | | <3.1 |
| 7 | | IWA ☐ OWA ☑ Inside room 315 at entr. to corridor | 2.0 / 2.0 | 1130 am | 1318 | 108 | 2.0 | 216 | | | | <6.9 |
| 8 | | IWA ☐ OWA ☑ Inside room 309 at entr. to corridor | 2.0 / 2.0 | 1132 am | 1320 | 108 | 2.0 | 216 | | | | <6.9 |
| 9 | | IWA ☐ OWA ☑ Inside room 907 at entr to corridor | 2.0 / 2.0 | 1134 am | 334 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 10 | | IWA ☐ OWA ☑ Inside room 802 at entr. to corridor. | 2.0 / 2.0 | 1136 am | 336 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 11 | | IWA ☐ OWA ☑ Inside room 807 at entr. to corridor | 2.0 / 2.0 | 1138 am | 338 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 12 | | IWA ☐ OWA ☑ Inside room 817 at entr. to corridor | 2.0 / 2.0 | 1140 am | 340 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 13 | | IWA ☐ OWA ☐ Inside room 328 at entr. to corridor | 2.0 / 2.0 | 145 pm | 345 pm | 120 | 2.0 | 240 | | | | <6.3 |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | | | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY: (SIGNATURE) | 7/26/02 | 12:30 pm | RECEIVED BY: (SIGNATURE) R. Arruda | 7.27.02 | 09.30 |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR TURNAROUND NIOSH 7082 (212) 406-2535 method | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH 7082

LOT # FILTER MANUFACTURER

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

20160



| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 7/26/02 |
| DATE SAMPLED: 7/26/02 | CONTACT: Hamid Saadat | WORK AREA: 3RD & 8TH floors | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | f/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 14 | | IWA ☐ OWA ☐ Inside room 333 at entr. to corridor | 2.0 / 2.0 | 147 pm | 349 pm | 120 | 2.0 | 240 | | | | <6.3 |
| 15 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 16 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | <1.5 |
| 17 | | IWA ☐ OWA ☑ Inside room 802 at entr. to corridor | 2.0 / 2.0 | 408 pm | 808 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 18 | | IWA ☐ OWA ☑ Inside room 802 at entr. to corridor | 2.0 / 2.0 | 408 pm | 802 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 19 | | IWA ☐ OWA ☑ Inside room 819 at entr. to corridor | 2.0 / 2.0 | 409 pm | 809 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 20 | | IWA ☐ OWA ☑ Inside room 329 at entr. to corridor | 2.0 / 2.0 | 406 pm | 806 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 21 | | IWA ☐ OWA ☑ Inside room 333 at entr. to corridor | 2.0 / 2.0 | 408 pm | 808 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 22 | | IWA ☐ OWA ☑ Inside room 335 at entr. to corridor | 2.0 / 2.0 | 408 pm | 808 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 23 | | IWA ☐ OWA ☐ Inside room 327 at entr. to corridor | 2.0 / 2.0 | 412 pm | 812 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 24 | | IWA ☐ OWA ☐ Inside room 337 at entr. to corridor | 2.0 / 2.0 | 414 pm | 814 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 25 | | IWA ☐ OWA ☐ Inside room 339 at entr. to corridor | 2.0 / 2.0 | 416 pm | 816 pm | 240 | 2.0 | 480 | | | | <3.1 |
| 26 | | IWA ☐ OWA ☐ Inside room 911 at entr. to corridor | 2.0 / 2.0 | 418 pm | 818 pm | 240 | 2.0 | 480 | | | | <3.1 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/26/02 | TIME | RECEIVED BY (SIGNATURE): L. Ortiz | DATE: 7.27.02 | TIME: 00.30 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR Turnaround NIOSH Method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT #: FILTER MANUFACTURER:

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107124

20100

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 3 OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvesterfrancis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: 7/26/02 |
| DATE SAMPLED: 7/26/02 | CONTACT: Hamid Saos | WORK AREA: 3rd 8th & 9th Floors | DATE LOGGED: |
| POTOMETER NO: 16 | PROJECT NO.: M497-15217 | PROJECT MANAGER: ChrisMcElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | hug/m³ |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 27 | | IWA ☐ OWA ☑ Inside room 925 at entr. to corridor | 2.0 / 2.0 | 928a | 824p | 240 | 2.0 | 480 | | | | <3.1 |
| 28 | | IWA ☐ OWA ☑ Inside room 807 at entr. to corridor | 2.0 / 2.0 | 800a | 1130p | 210 | 2.0 | 420 | | | | <3.6 |
| 29 | | IWA ☐ OWA ☑ Inside room 807 at entr. to corridor | 2.0 / 2.0 | 802a | 1132p | 210 | 2.0 | 420 | | | | <3.6 |
| 30 | | IWA ☐ OWA ☑ Inside room 817 at entr. to corridor | 2.0 / 2.0 | 804a | 1134p | 210 | 2.0 | 420 | | | | <3.6 |
| 31 | | IWA ☐ OWA ☑ Inside room 329 at entr. to corridor | 2.0 / 2.0 | 806a | 1136p | 210 | 2.0 | 420 | | | | <3.6 |
| 32 | | IWA ☐ OWA ☑ Inside room 333 at entr. to corridor | 2.0 / 2.0 | 808a | 1138p | 210 | 2.0 | 420 | | | | <3.6 |
| 33 | | IWA ☐ OWA ☑ Inside room 335 at entr. to corridor | 2.0 / 2.0 | 810a | 1140p | 210 | 2.0 | 420 | | | | <3.6 |
| 34 | | IWA ☐ OWA ☑ Inside room 329 at entr. to corridor | 2.0 / 2.0 | 812a | 1142p | 210 | 2.0 | 420 | | | | <3.6 |
| 35 | | IWA ☐ OWA ☑ Inside room 339 at entr. to corridor | 2.0 / 2.0 | 814a | 1144p | 210 | 2.0 | 420 | | | | <3.6 |
| 36 | | IWA ☐ OWA ☑ Inside room 339 at entr. to corridor | 2.0 / 2.0 | 816a | 1146p | 210 | 2.0 | 420 | | | | <3.6 |
| 37 | | IWA ☐ OWA ☑ Inside room 911 at entr. to corridor | 2.0 / 2.0 | 818a | 1148p | 210 | 2.0 | 420 | | | | <3.6 |
| 38 | | IWA ☐ OWA ☐ Field Blank | / | | | | | | | | | <1.5 |
| 39 | | IWA ☐ OWA ☐ Field Blank | / | | | | | | | | | <1.5 |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/27/02 | TIME | RECEIVED BY: (SIGNATURE): R. Arruda | DATE: 7.27.02 | TIME: 00.30 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 HOUR TURNAROUND | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH 7082

LOT #:

FILTER MANUFACTURER

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-29-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-26-02
**DATE RECEIVED:** 07-27-02
**DATE ANALYZED:** 07-27-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20700 | Inside Rm 315 at Entrance to Corridor | <3.1 | 3.1 |
| 02 | 20700 | Inside Rm 307 at Entrance to Corridor | <3.1 | 3.1 |
| 03 | 20700 | Inside Rm 907 at Entrance to Corridor | <3.1 | 3.1 |
| 04 | 20700 | Inside Rm 802 at Entrance to Corridor | <3.1 | 3.1 |
| 05 | 20700 | Inside Rm 807 at Entrance to Corridor | <3.1 | 3.1 |
| 06 | 20700 | Inside Rm 817 at Entrance to Corridor | <3.1 | 3.1 |
| 07 | 20700 | Inside Rm 315 at Entrance to Corridor | <6.9 | 6.9 |
| 08 | 20700 | Inside Rm 307 at Entrance to Corridor | <6.9 | 6.9 |
| 09 | 20700 | Inside Rm 907 at Entrance to Corridor | <3.1 | 3.1 |
| 10 | 20700 | Inside Rm 802 at Entrance to Corridor | <3.1 | 3.1 |
| 11 | 20700 | Inside Rm 807 at Entrance to Corridor | <3.1 | 3.1 |
| 12 | 20700 | Inside Rm 817 at Entrance to Corridor | <3.1 | 3.1 |
| 13 | 20700 | Inside Rm 329 at Entrance to Corridor | <6.3 | 6.3 |
| 14 | 20700 | Inside Rm 333 at Entrance to Corridor | <6.3 | 6.3 |
| 15 | 20700 | Field Blank | <1.5 µg | 1.5 µg |

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | | | | |
|---|---|---|---|---|
| 16 | 20700 | Field Blank | <1.5 µg | 1.5 µg |
| 17 | 20700 | Inside Rm 802 at Entrance to Corridor | <3.1 | 3.1 |
| 18 | 20700 | Inside Rm 807 at Entrance to Corridor | <3.1 | 3.1 |
| 19 | 20700 | Inside Rm 817 at Entrance to Corridor | <3.1 | 3.1 |
| 20 | 20700 | Inside Rm 329 at Entrance to Corridor | <3.1 | 3.1 |
| 21 | 20700 | Inside Rm 333 at Entrance to Corridor | <3.1 | 3.1 |
| 22 | 20700 | Inside Rm 335 at Entrance to Corridor | <3.1 | 3.1 |
| 23 | 20700 | Inside Rm 327 at Entrance to Corridor | <3.1 | 3.1 |
| 24 | 20700 | Inside Rm 337 at Entrance to Corridor | <3.1 | 3.1 |
| 25 | 20700 | Inside Rm 339 at Entrance to Corridor | <3.1 | 3.1 |
| 26 | 20700 | Inside Rm 911 at Entrance to Corridor | <3.1 | 3.1 |
| 27 | 20700 | Inside Rm 925 at Entrance to Corridor | <3.1 | 3.1 |
| 28 | 20700 | Inside Rm 802 at Entrance to Corridor | <3.6 | 3.6 |
| 29 | 20700 | Inside Rm 807 at Entrance to Corridor | <3.6 | 3.6 |
| 30 | 20700 | Inside Rm 817 at Entrance to Corridor | <3.6 | 3.6 |
| 31 | 20700 | Inside Rm 329 at Entrance to Corridor | <3.6 | 3.6 |
| 32 | 20700 | Inside Rm 333 at Entrance to Corridor | <3.6 | 3.6 |
| 33 | 20700 | Inside Rm 335 at Entrance to Corridor | <3.6 | 3.6 |
| 34 | 20700 | Inside Rm 327 at Entrance to Corridor | <3.6 | 3.6 |
| 35 | 20700 | Inside Rm 337 at Entrance to Corridor | <3.6 | 3.6 |
| 36 | 20700 | Inside Rm 339 at Entrance to Corridor | <3.6 | 3.6 |
| 37 | 20700 | Inside Rm 911 at Entrance to Corridor | <3.6 | 3.6 |
| 38 | 20700 | Field Blank | <1.5 µg | 1.5 µg |
| 39 | 20700 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC-WTC_000107127

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary Mckenzie | CLIENT: NYC SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 7/27/02 |
| DATE SAMPLED: 7/27/02 | CONTACT: | WORK AREA: 3rd 8th & 9th | DATE LOGGED: |
| ROTOMETER NO: L-16 | PROJECT NO: M477-15217/29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: 7-28-02 |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | mp/m³ F/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☑ Room 802A At Entrance | 2/2 | 0730 | 1130 | 240 | 2 | 480 | | | | <3.1 |
| 02 | | IWA ☐ OWA ☑ Room 807 At Entrance | 2/2 | 0732 | 1132 | 240 | 2 | 480 | | | | |
| 03 | | IWA ☐ OWA ☑ Room 817 At Entrance | 2/2 | 0734 | 1134 | 240 | 2 | 480 | | | | |
| 04 | | IWA ☐ OWA ☑ Room 911 At Entrance | 2/2 | 0736 | 1136 | 240 | 2 | 480 | | | | |
| 05 | | IWA ☐ OWA ☑ Room 329 At Entrance | 2/2 | 0748 | 1140 | 240 | 2 | 480 | | | | |
| 06 | | IWA ☐ OWA ☐ Room 802A At Entrance | 2/2 | 1200 | 1430 | 150 | 2 | 300 | | | | <5.0 |
| 07 | | IWA ☐ OWA ☐ Room 817 At Entrance | 2/2 | 1202 | 1432 | 150 | 2 | 300 | | | | <5.0 |
| 08 | | IWA ☐ OWA ☐ Room 911 At Entrance | 2/2 | 1203 | 1500 | 177 | 2 | 354 | | | | <4.2 |
| 09 | | IWA ☐ OWA ☐ Room 329 At Entrance | 2/2 | 1206 | 1446 | 160 | 2 | 320 | | | | <4.7 |
| FB-10 | | IWA ☐ OWA ☐ FB-10 | | | | | | | | | | <1.5 |
| FB-11 | | IWA ☐ OWA ☐ FB-11 | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | | | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY: (SIGNATURE) Gary Mckenzie | DATE 7/27/02 | TIME | RECEIVED BY: (SIGNATURE) | DATE 7/28/2 | TIME 1100 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS 12 HOUR TAT | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER NIOSH 7400 7402

LOT # Ambient

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

**REPORT DATE:** 07-29-02

**CLIENT:** Taylor Environmental Group, Inc.

**PROJECT NAME:** SCA/Stuyvesant HS
3rd, 8th and 9th Floors

**PROJECT NUMBER:** M477-15217/29881

**SAMPLED BY:** Client

**SAMPLE DATE** 07-27-02
**DATE RECEIVED:** 07-27-02
**DATE ANALYZED:** 07-27-02

**SAMPLE MEDIA:** Air Samples
**ANALYSIS REQUIRED:** Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20704 | Rm 802A at Entrance | <3.1 | 3.1 |
| 02 | 20704 | Rm 807 at Entrance | <3.1 | 3.1 |
| 03 | 20704 | Rm 817 at Entrance | <3.1 | 3.1 |
| 04 | 20704 | Rm 911 at Entrance | <3.1 | 3.1 |
| 05 | 20704 | Rm 329 at Entrance | <3.1 | 3.1 |
| 06 | 20704 | Rm 802A at Entrance | <5.0 | 5.0 |
| 07 | 20704 | Rm 817 at Entrance | <5.0 | 5.0 |
| 08 | 20704 | Rm 911 at Entrance | <4.2 | 4.2 |
| 09 | 20704 | Rm 329 at Entrance | <4.7 | 4.7 |
| FB-10 | 20704 | Field Blank | <1.5 µg | 1.5 µg |
| FB-11 | 20704 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gary McKenzie | CLIENT: N.Y.C SCH | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 8/1/02 |
| DATE SAMPLED: 7/31/02 | CONTACT: Hamid Sayar | WORK AREA: 6th Floor | DATE LOGGED: |
| ROTOMETER NO.: L-16 | PROJECT NO.: 0477-15217 / 29881 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☐ In Library at doorway | Z/Z | 1603 | 1930 | 210 | 2 | 420 | | | | |
| 02 | | IWA ☐ OWA ☐ Room 615E at doorway | Z/Z | 1602 | 1932 | 210 | 2 | 420 | | | | |
| 03 | | IWA ☐ OWA ☐ In Library at doorway | Z/Z | 2000 | 2400 | 240 | 2 | 480 | | | | |
| 04 | | IWA ☐ OWA ☐ Room 615E at doorway | Z/Z | 2002 | 2402 | 240 | 2 | 480 | | | | |
| FB-5 | | IWA ☐ OWA ☐ FB-5 | | | | | | | | | | |
| FB-6 | | IWA ☐ OWA ☐ FB-6 | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): [signature] | DATE: 8/1/02 | TIME: 0100 | RECEIVED FROM TEG DROP BOX (SIGNATURE): [signature] | DATE: 08/01/02 | TIME: 9:00 am |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: ✓ | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA (NIOSH METHOD) — OTHER

LOT # 7082

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 08-01-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>6th Floor |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 08-01-02 |
| **DATE RECEIVED:** | 08-01-02 |
| **DATE ANALYZED:** | 08-01-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20824 | In Library at Doorway | <3.6 | 3.6 |
| 02 | 20824 | Rm 615E at Doorway | <3.6 | 3.6 |
| 03 | 20824 | In Library at Doorway | <3.1 | 3.1 |
| 04 | 20824 | Rm 615E at Doorway | <3.1 | 3.1 |
| FB-5 | 20824 | Field Blank | <1.5 µg | 1.5 µg |
| FB-6 | 20824 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers St. | DATE SUBMITTED: 7/31/02 |
| DATE SAMPLED: 7/31/02 | CONTACT: Hamid Saud | WORK AREA: 9TH + 6TH Floors | DATE LOGGED: |
| ROTOMETER NO.: 16 | PROJECT NO.: M477-152117 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ Inside room 9H at entrance to corridor | 2.0 / 2.0 | 720 AM | 1120 AM | 240 | 2.0 | 480 | | | | |
| 2 | | IWA ☐ OWA ☑ Inside room 6IS at entrance to corridor | 2.0 / 2.0 | 724 AM | 1124 AM | 240 | 2.0 | 480 | | | | |
| 3 | | IWA ☐ OWA ☑ Inside room 6ISE at entrance to corridor | 2.0 / 2.0 | 726 AM | 1126 AM | 240 | 2.0 | 480 | | | | |
| 4 | | IWA ☐ OWA ☑ Inside room 6OIA at entrance to corridor | 2.0 / 2.0 | 728 AM | 1128 AM | 240 | 2.0 | 480 | | | | |
| 5 | | IWA ☐ OWA ☑ Inside room 6IS at entrance to corridor | 2.0 / 2.0 | 1124 | 300 | 216 | 2.0 | 432 | | | | |
| 6 | | IWA ☐ OWA ☑ Inside room 6ISE at entrance to corridor | 2.0 / 2.0 | 1126 | 302 | 216 | 2.0 | 432 | | 02 JUL 31 PM 1:17 | | |
| 7 | | IWA ☐ OWA ☑ Inside room 6OIA at entrance to corridor | 2.0 / 2.0 | 1128 | 304 | 216 | 2.0 | 432 | | | | |
| 8 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | |
| 9 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

RECEIVED BY NYC HAZMAT

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 7/31/02 | TIME: 4:10PM | RECEIVED BY: (SIGNATURE) | DATE: 7/31/02 | TIME: 4:12 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: 12 Hour Turnaround NIOSH method 7082 | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA OTHER NIOSH 7082

LOT # / FILTER MANUFACTURER

WHITE: Office Copy | YELLOW: Lab Copy | PINK: Samples | ORANGE: Site Copy

Fax results to (212) 966-2535 and Taylor office

PAGE 01/01
EMSL ANALYTICAL INC
212-290-2538
08/01/2002 09:35
NYC-WTC_000107133

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

| | | | |
|---|---|---|---|
| Attn: | Taylor Environmental Group, Inc.<br>Floral Park Corporate Center<br>130 Jericho Tpke.<br>Floral Park, NY 11001 | Customer ID: | TAYL50 |
| | | Customer PO: | |
| | | Received: | 07/31/02 4:17 PM |
| Fax: | (516) 358-1780 Phone: 516-358-2955 | EMSL Order: | 030210369 |
| Project: | M477-15217/ SCA/ STUYVESANT H.S. 345 CHAMBERS ST. | EMSL Project ID: | |

## Lead in Air by Flame AAS (NIOSH 7082)

| | Client Sample Description | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 1 | INSIDE ROOM 9H AT ENTRANCE TO CORRIDOR | 0001 | | 480 L | <8.3 µg/m³ | |
| 2 | INSIDE ROOM 615 AT ENTRANCE TO CORRIDOR | 0002 | | 480 L | <8.3 µg/m³ | |
| 3 | INSIDE ROOM 615E AT ENTRANCE TO CORRIDOR | 0003 | | 480 L | <8.3 µg/m³ | |
| 4 | INSIDE ROOM 601A AT ENTRANCE TO CORRIDOR | 0004 | | 480 L | <8.3 µg/m³ | |
| 5 | INSIDE ROOM 615 AT ENTRANCE TO CORRIDOR | 0005 | | 432 L | <9.3 µg/m³ | |
| 6 | INSIDE ROOM 615E AT ENTRANCE TO CORRIDOR | 0006 | | 432 L | <9.3 µg/m³ | |
| 7 | INSIDE ROOM 601A AT ENTRANCE TO CORRIDOR | 0007 | | 432 L | <9.3 µg/m³ | |
| 8 | Field blank | 0008 | | n/a | <4.0 µg/filter | |
| 9 | Field blank | 0009 | | n/a | <4.0 µg/filter | |

Eric B. Lynch
Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581

PB w/o dust



NYC-WTC_000107134

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERESA MICHNIEWICZ | NYC SCA | STUYVESANT HS 345 CHAMBERS ST. | 08.05.02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 08.05.02 | HAMID SAWOJ | 3RD FLOOR | |
| **ROTOMETER NO** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG - 16 | M477 - 15217 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 351<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/3 | 16.00 | 20.00 | 240 | 3.5 | 840 | | | | <1.8 |
| 02 | | IWA ☐ INSIDE ROOM 373<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/4 | 16.02 | 20.02 | 240 | 4 | 960 | | | | <1.6 |
| 03 | | IWA ☐ INSIDE ROOM 351<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/4 | 20.00 | 23.15 | 195 | 4 | 780 | | | | <1.9 |
| 04 | | IWA ☐ INSIDE ROOM 373<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/3 | 20.02 | 23.17 | 195 | 3.5 | 683 | | | . | <2.2 |
| 05 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 06 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Teresa Michniewicz | 08.06.02 | 24.30 | | 8-6-2 | 9.00 AM |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| | 8/6/02 | | | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** | | |
| | | | NIOSH 7082 12 HRS TAT<br>FAX TO: 212 406-2535 & 516 358-1790 | | |

CIRCLE: PCM TEM — BORO PRE DURING POST — OSHA — OTHER AM NIGHT

LOT # FILTER MANUFACTURER 13782 ENV. EXP.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: TERRY MICHALCZUK | CLIENT: NYC SCA | SITE ADDRESS: STUYVESANT HS 345 CHAMBERS ST. | DATE SUBMITTED: 08.05.02 |
| DATE SAMPLED: 08.05.02 | CONTACT: HAMID SAWOJ | WORK AREA: 3RD FLOOR | DATE LOGGED: |
| ROTOMETER NO: TEG - 16 | PROJECT NO.: M477 - 15217 | PROJECT MANAGER: CHRIS MC ELGUN | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | FS/cc FCC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 351<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/3 | 16.00 | 20.00 | 240 | 3.5 | 840 | | | | <1.8 |
| 02 | | IWA ☐ INSIDE ROOM 373<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/4 | 16.02 | 20.02 | 240 | 4 | 960 | | | | <1.6 |
| 03 | | IWA ☐ INSIDE ROOM 351<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/4 | 20.00 | 23.15 | 195 | 4 | 1380 | | | | <1.9 |
| 04 | | IWA ☐ INSIDE ROOM 343<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/3 | 20.02 | 23.17 | 195 | 3.5 | 683 | | | | <2.2 |
| 05 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 06 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE): Terry Michalczuk | DATE: 08.06.02 | TIME: 24.30 | RECEIVED FROM TEG DROP BOX (SIGNATURE): KH | DATE: 8-6-2 | TIME: 9:00 am |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/6/02 | TIME: | RECEIVED BY: (SIGNATURE) | DATE: | TIME: |
| ANALYST (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH 7082 12 HRS TAT<br>FAX TO: 212 406-2535 & 516 338-1780 | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER AMBIENT

LOT # 13782 FILTER MANUFACTURER ENV. EXP.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107136

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers St. | DATE SUBMITTED: 8/5/02 |
| DATE SAMPLED: 8/5/02 | CONTACT: Hamid Saeed | WORK AREA: 3rd floor | DATE LOGGED: |
| PATOMETER NO: 16 | PROJECT NO: M477-15217 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² mg/m³ | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ Room 331 at entrance to corridor. | 2.0 / 2.0 | 1215 PM | 315 PM | 180 | 2.0 | 360 | | | < 4.2 | |
| 2 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | < 8.5 | |
| 3 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | < 1.5 | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/5/02 | TIME: 2330 | RECEIVED BY: (SIGNATURE): R. Proudma | DATE: 8.5.02 | TIME: 2330 |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

U80210516

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: Gregory Gordon | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: |
| DATE SAMPLED: 8/2/2 | CONTACT: Nawid Saleqi | WORK AREA: 4th and 9th floors | DATE LOGGED: |
| ROTOMETER NO.: TEG L-13 | PROJECT NO.: 4477-15217 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☑ OWA ☐ Room 402 entrance | 2/2 | 1605 | 2000 | 235 | 2.0 | 470 | | | | |
| 02 | | IWA ☑ OWA ☐ Room 459 east entrance | 2/2 | 1607 | 2001 | 234 | 2.0 | 468 | | | | |
| 03 | | IWA ☑ OWA ☐ Room 402 | 2/2 | 2000 | 2403 | 243 | 2.0 | 486 | | | | |
| 04 | | IWA ☑ OWA ☐ Room 450 east entrance | 2/2 | 2001 | 2404 | 243 | 2.0 | 486 | | | | |
| 05 | | IWA ☑ OWA ☐ Room 451 entrance | 2/2 | 2002 | 2405 | 243 | 2.0 | 486 | | | | |
| 06 | | IWA ☑ OWA ☐ Room 453 entrance | 2/2 | 0003 | 2406 | 243 | 2.0 | 486 | | | | |
| 07 | | IWA ☐ OWA ☐ F/B | | | | | | | | | | |
| 08 | | IWA ☐ OWA ☐ F/B | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 8/3/2 | TIME: 2400 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY (SIGNATURE) | DATE: 8/3/02 | TIME: 0050 | RECEIVED BY: (SIGNATURE) Javier Quispe@emsl. | DATE | TIME |
| ANALYST (SIGNATURE) | DATE | TIME | COMMENTS: 12 HR TAT | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER Lead

LOT # — FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

EMSL MANHATTAN RECEIVED 02 AUG -3 AM 12:59

08/03/2002 09:00 212-290-2538 EMSL ANALYTICAL INC PAGE 02/04

NYC-WTC_000107138

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2123900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217 / SCA / 4th and 9th Floors / Stuyvesant H.S.

Customer ID: TAYL50
Customer PO:
Received: 08/03/02 12:59 AM
EMSL Order: 030210516
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 01 | Room 402 entrance | 0001 | | 420 L | <9.5 µg/m³ | |
| 02 | Room 459 roof entrance | 0002 | | 468 L | <8.5 µg/m³ | |
| 03 | Room 402 | 0003 | | 486 L | <8.2 µg/m³ | |
| 04 | Room 450 entrance | 0004 | | 486 L | <8.2 µg/m³ | |
| 05 | Room 451 entrance | 0005 | | 486 L | <8.2 µg/m³ | |
| 06 | Room 453 entrance | 0006 | | 486 L | <8.2 µg/m³ | |
| 07 | Field blank | 0007 | | n/a | <4.0 µg/filter | |
| 08 | Field blank | 0008 | | n/a | <4.0 µg/filter | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102681

PB w/o QC



NYC-WTC_000107139

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

PAGE 02/02

| | | | |
|---|---|---|---|
| TECHNICIAN: Gregory Gordon | CLIENT: SCA | SITE ADDRESS: Silverstein Prop. 5 | DATE SUBMITTED: |
| DATE SAMPLED: 8-3-2 | CONTACT: Hamid Saadi | WORK AREA: 3rd, 4th, & 8th floors | DATE LOGGED: |
| ROTOMETER NO: TEG-L16 | PROJECT NO: 4477-15217 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☐ Room 301C entrance | 2.0/2.0 | 1430 | 1900 | 270 | 2.0 | 540 | | | | |
| 02 | | IWA ☐ OWA ☐ Room 453 entrance | 2.0/2.0 | 1502 | 1905 | 243 | 2.0 | 486 | | | | |
| 03 | | IWA ☐ OWA ☐ Room 371 entrance | 2.0/2.0 | 1700 | 2000 | 180 | 2.0 | 360 | | | | |
| 04 | | IWA ☐ OWA ☐ Room 301C entrance | 2.0/2.0 | 1901 | 2410 | 309 | 2.0 | 618 | | | | |
| 05 | | IWA ☐ OWA ☐ Room 453 entrance | 2.0/2.0 | 1905 | 2105 | 120 | 2.0 | 240 | | | | |
| 06 | | IWA ☐ OWA ☐ Room 371 | 2.0/2.0 | 2000 | 9415 | 255 | 2.0 | 470 | | | | |
| 07 | | IWA ☐ OWA ☐ F/B | / | | | | | | | | | |
| 08 | | IWA ☐ OWA ☐ F/B | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |
| | | IWA ☐ OWA ☐ | / | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 8/4/2 | TIME: 1:00 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS: NIOSH 7082 12 hrs TAT Fax 212 406-2555 & 516-3581780 | | |

CIRCLE: PCM TEM BORO PRE DURING POST OSHA OTHER Asbestos

LOT # 184782 FILTER MANUFACTURER Env. Sup.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

EMSL ANALYTICAL INC 212-290-2538 08/04/2002 13:12

RECEIVED AUG 7 2002 12:27 ENVIRONMENTAL HEALTH

NYC-WTC_000107140

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217 / SCA / Stuyvesant H.S. / 3rd, 4th, 8th Floors

Customer ID: TAYL50
Customer PO:
Received: 08/04/02 12:27 AM
EMSL Order: 030210571
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 01 | Room 301C entrance | 0001 | 8/4/02 | 540 L | <7.4 µg/m³ | |
| 02 | Room 453 entrance | 0002 | 8/4/02 | 486 L | <8.2 µg/m³ | |
| 03 | Room 371 entrance | 0003 | 8/4/02 | 360 L | <11.0 µg/m³ | |
| 04 | Room 301C entrance | 0004 | 8/4/02 | 618 L | <6.5 µg/m³ | |
| 05 | Room 453 entrance | 0005 | 8/4/02 | 240 L | <17.0 µg/m³ | |
| 06 | Room 371 entrance | 0006 | 8/4/02 | 470 L | <8.5 µg/m³ | |
| 07 | Field blank | 0007 | 8/4/02 | n/a | <4.0 µg/filter | |
| 08 | Field blank | 0008 | 8/4/02 | n/a | <4.0 µg/filter | |

Laboratory Manager
or other approved signatory

Reporting Limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581

P w/o QC



NYC-WTC_000107141

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD



| | | | |
|---|---|---|---|
| TECHNICIAN: Gregory Gordon | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. | DATE SUBMITTED: |
| DATE SAMPLED: 08-05-02 | CONTACT: Mamid Sawoj | WORK AREA: 4th & 9th floors | DATE LOGGED: 20845 |
| ROTOMETER NO.: IEG-L16 | PROJECT NO.: M477-15217 | PROJECT MANAGER: Chris McElgun | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | Asb/cm³ F/cc |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☐ Room 450 east entrance | 2.0/2.0 | 0730 | 1030 | 180 | 2.0 | 360 | | | | <4.2 |
| 02 | | IWA ☐ OWA ☐ Room 451 entrance | 2.0/2.0 | 0731 | 1231 | 300 | 2.0 | 600 | | | | <2.5 |
| 03 | | IWA ☐ OWA ☐ Room 453 entrance | 2.0/2.0 | 0732 | 1232 | 300 | 2.0 | 600 | | | | <2.5 |
| 04 | | IWA ☐ OWA ☐ Room 453 entrance | 2.0/2.0 | 1231 | 1501 | 150 | 2.0 | 300 | | | | <5.0 |
| 05 | | IWA ☐ OWA ☐ Room 453 entrance | 2.0/2.0 | 1232 | 1502 | 150 | 2.0 | 300 | | | | <5.0 |
| 06 | | IWA ☐ OWA ☐ FIG | | | | | | | | | | <1.5 |
| 07 | | IWA ☐ OWA ☐ FIG | | | | | | | | | | <1.5 |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE: 08-3-2 | TIME: | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE: | TIME: |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/3/02 | TIME: 1420 | RECEIVED BY: (SIGNATURE) | DATE: 8/5/2 | TIME: 16:20 |
| ANALYST: (SIGNATURE) | DATE: | TIME: | COMMENTS: NIOSH 7082 12hr TAT Fax 212 406-2535 & 516 358 1780 | | |

CIRCLE: PCM TEM — BORD PRE DURING POST — OSHA — OTHER Asbestos

LOT # / FILTER MANUFACTURER: 13492 Env. Exp.

WHITE: Office Copy YELLOW: Lab Copy PINK: Sampler Copy ORANGE: File Copy

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| **REPORT DATE:** | 08-05-02 |
| **CLIENT:** | Taylor Environmental Group, Inc. |
| **PROJECT NAME:** | SCA/Stuyvesant HS<br>4th, 8th Floors |
| **PROJECT NUMBER:** | M477-15217/29881 |
| **SAMPLED BY:** | Client |
| **SAMPLE DATE** | 08-03-02 |
| **DATE RECEIVED:** | 08-03-02 |
| **DATE ANALYZED:** | 08-03-02 |
| **SAMPLE MEDIA:** | Air Samples |
| **ANALYSIS REQUIRED:** | Method NIOSH 7082 |

ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20895 | Rm 450 East Entrance | <4.2 | 4.2 |
| 02 | 20895 | Rm 451 Entrance | <2.5 | 2.5 |
| 03 | 20895 | Rm 453 Entrance | <2.5 | 2.5 |
| 04 | 20895 | Rm 451 Entrance | <5.0 | 5.0 |
| 05 | 20895 | Rm 453 Entrance | <5.0 | 5.0 |
| 06 | 20895 | Field Blank | <1.5 µg | 1.5 µg |
| 07 | 20895 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
**THE REPORTING LIMIT (RL) IS 3.0 µg**

NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.

NOTE 3:
Blank units are in µg

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

0302105490

PAGE 1 OF 1

| | | | |
|---|---|---|---|
| TECHNICIAN: C. Gordon | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S | DATE SUBMITTED: 8-4-02 |
| DATE SAMPLED: 08-4-02 | CONTACT: Hamid Sawoq | WORK AREA: 3rd Floor | DATE LOGGED: |
| ROTOMETER NO.: TEG L-16 | PROJECT NO.: M477-15217 | PROJECT MANAGER: Chris McElyea | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ OWA ☐ Room 371E entrance | 2.0/2.0 | 7:15 | 11:30 | 255 | 2.0 | 510 | | | | |
| 02 | | IWA ☐ OWA ☐ Room 350 entrance | 2.0/2.0 | 8:10 | 12:10 | 240 | 2.0 | 480 | | | | |
| 03 | | IWA ☐ OWA ☐ Room 371E entrance | 2.0/2.0 | 11:30 | 13:20 | 110 | 2.0 | 220 | | | | |
| 04 | | IWA ☐ OWA ☐ Room 350 entrance | 2.0/2.0 | 12:10 | 15:20 | 190 | 2.0 | 380 | | | | |
| 05 | | IWA ☐ OWA ☐ F/B | | | | | | | | | | |
| 06 | | IWA ☐ OWA ☐ F/B | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | DATE | TIME | | DATE | TIME |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | 8-4-2 | 1615 | RECEIVED FROM TEG DROP BOX (SIGNATURE) | | |
| RELINQUISHED BY: (SIGNATURE) | | | RECEIVED BY: (SIGNATURE) | | |
| ANALYST (SIGNATURE) | | | COMMENTS: NIOSH 7082 12HRS TAT Fax # 12 40K-2535 | | |

576 358-1780

CIRCLE: PCM TEM — BORO PRE DURING POST — OSHA — OTHER Lead

LOT # 13782 Cav. ex.
FILTER MANUFACTURER

02 AUG -5 PM 4:04

EMSL ANALYTICAL INC RECEIVED

WHITE: Office Copy YELLOW: Lab Copy PINK: Sampler ORANGE: File

08/05/2002 09:01 212-290-2536 EMSL ANALYTICAL INC PAGE 04/06

NYC-WTC_000107145

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhsttanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: M477-15217 / SCA / Stuyvesant H.S. 3rd Floor

Customer ID: TAYL50
Customer PO:
Received: 08/04/02 4:04 PM
EMSL Order: 030210590
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 01 | Room 371E entrance | 0001 | | 510 L | 10.0 µg/m³ | |
| 02 | Room 350 entrance | 0002 | | 480 L | <8.3 µg/m³ | |
| 03 | Room 371E entrance | 0003 | | 220 L | <18.0 µg/m³ | |
| 04 | Room 350 entrance | 0004 | | 380 L | <11.0 µg/m³ | |
| 05 | Field blank | 0005 | | n/a | µg/g | |
| 06 | Field blank | 0006 | | n/a | µg/g | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL.
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581



NYC-WTC_000107146

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| TERESA MICHALCZUK | NYC SCA | STUYVESANT H.S., 345 CHAMBERS ST. | 08.05.02 |
| **DATE SAMPLED** | **CONTACT** | **WORK AREA** | **DATE LOGGED** |
| 08.04.02 | HAMID SAWOJ | 3rd FLOOR | |
| **ROTOMETER NO.** | **PROJECT NO.** | **PROJECT MANAGER** | **DATE APPROVED / SIGNATURE** |
| TEG L-18 | M477-15217 /29881 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 350<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 16.00 | 20.00 | 240 | 2 | 480 | | | | |
| 02 | | IWA ☐ INSIDE ROOM 350<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 2/2 | 20.00 | 23.00 | 180 | 2 | 360 | | | | |
| 03 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| 04 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| Teresa Michalczuk | 08.04.02 | 21.30 | | | |
| **RELINQUISHED BY: (SIGNATURE)** | **DATE** | **TIME** | **RECEIVED BY: (SIGNATURE)** | **DATE** | **TIME** |
| Teresa Michalczuk | 08.05.02 | 00.30 | ~~TERESA MICHALCZUK~~ | | |
| **ANALYST: (SIGNATURE)** | **DATE** | **TIME** | **COMMENTS** NIOSH 7082 12 HRS TAT, FAX TO 212 406-2535 & SIG 358-1780 | | |

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER AMBIENT

LOT # 13782 FILTER MANUFACTURER ENV. EXP.

EMSL-MANHATTAN RECEIVED 02 AUG -5 AM 12:30

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

PAGE 02/02 EMSL ANALYTICAL INC 212-290-2538 08/05/2002 09:48

NYC-WTC_000107147

NYC 9/11 Public Portal Document



**EMSL Analytical, Inc.**
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: NYV SCA/M477-15217-129881/Stuyvesant H.S. 345 Chambers St./3rd Floor

Customer ID: TAYL50
Customer PO:
Received: 08/05/02 9:47 AM
EMSL Order: 030210616
EMSL Project ID:

## Lead in Air by Flame AAS (NIOSH 7082)

| Client Sample Description | | Lab ID | Analyzed | Volume | Lead Concentration | Notes |
|---|---|---|---|---|---|---|
| 01 | Inside Room 350 Near Entrance to Hallway | 0001 | | 480 L | <8.3 µg/m³ | |
| 02 | Inside Room 350 Near Entrance to Hallway | 0002 | | 360 L | 13.0 µg/m³ | |
| 03 | Field blank | 0003 | | n/a | <4.0 µg/filter | |
| 04 | Field blank | 0004 | | n/a | <4.0 µg/filter | |

Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL
ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581



NYC-WTC_000107148

NYC 9/11 Public Portal Document

TAYLOR ENVIRONMENTAL GROUP

# DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

#2031

PAGE 1 OF 1

| TECHNICIAN | CLIENT | SITE ADDRESS | DATE SUBMITTED |
|---|---|---|---|
| JEREMY MICHALCZUK | NYC SCA | STUYVESANT HS 345 CHAMBERS ST. | 08.05.02 |
| DATE SAMPLED | CONTACT | WORK AREA | DATE LOGGED |
| 08.05.02 | HAMID SAWOJ | 3RD FLOOR | |
| ROTOMETER NO | PROJECT NO. | PROJECT MANAGER | DATE APPROVED / SIGNATURE |
| TEG - 16 | M477 - 15217 | CHRIS MC ELGUN | |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² | NIOSH 7400 F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 01 | | IWA ☐ INSIDE ROOM 351<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/3 | 16.00 | 20.00 | 240 | 3.5 | 840 | | | | <1.8 |
| 02 | | IWA ☐ INSIDE ROOM 373<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/4 | 16.02 | 20.02 | 240 | 4 | 960 | | | | <1.6 |
| 03 | | IWA ☐ INSIDE ROOM 351<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/4 | 20.00 | 23.15 | 195 | 4 | 780 | | | | <1.9 |
| 04 | | IWA ☐ INSIDE ROOM 343<br>OWA ☐ NEAR ENTRANCE TO HALLWAY | 4/3 | 20.02 | 23.17 | 195 | 3.5 | 683 | | | . | <2.2 |
| 05 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| 06 | | IWA ☐<br>OWA ☐ FIELD BLANK | | | | | | | | | | <1.5 |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |
| | | IWA ☐<br>OWA ☐ | | | | | | | | | | |

| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
|---|---|---|---|---|---|
| | 08.06.02 | 24.30 | | 8-6-2 | 9:00am |
| RELINQUISHED BY: (SIGNATURE) | DATE | TIME | RECEIVED BY: (SIGNATURE) | DATE | TIME |
| | 8/6/02 | | | | |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |
| | | | NIOSH 7082 12 HRS TAT<br>FAX TO: 212 406-2535 & 516 358-1780 | | |

CIRCLE: PCM TEM BORD PRE DURING POST OSHA OTHER AMBIENT

LOT # FILTER MANUFACTURER 13782 ENV. EXP.

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

NYC-WTC_000107149

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-07-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
7th Floor & 202,260

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE 08-06-02
DATE RECEIVED: 08-07-02
DATE ANALYZED: 08-07-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20983 | F.Calle SS# PII (Room 207) | <3.6 | 3.6 |
| 02 | 20983 | T.Bunay SS# PII (Room 260) | <3.6 | 3.6 |
| 03 | 20983 | F.Calle SS# PII (Room 207) | <3.1 | 3.1 |
| 04 | 20983 | T.Bunay SS# PII (Room 260) | <3.1 | 3.1 |
| FB-05 | 20983 | Field Blank | <1.5 µg | 1.5 µg |
| FB-06 | 20983 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3:
Blank units are in µg

## CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

NYC 9/11 Public Portal Document

# TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF ____

| | | | |
|---|---|---|---|
| TECHNICIAN: Sylvester Francis | CLIENT: SCA | SITE ADDRESS: Stuyvesant H.S. 345 Chambers St. | DATE SUBMITTED: 8/6/02 |
| DATE SAMPLED: 8/6/02 | CONTACT: HAMID SAADAT | WORK AREA: 3rd flour | DATE LOGGED: |
| ROTOMETER NO: 16 | PROJECT NO: M477-1521.7 | PROJECT MANAGER: Chris McElgunn | DATE APPROVED / SIGNATURE: |

| SAMPLE & PUMP # | LABORATORY NO. | SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE | FLOW ON/OFF | TIME ON | TIME OFF | DURATION MINUTES | FLOW (AVERAGE) | LITERS | FIELDS | FIBERS | F/MM² mg/in³ | F/CC |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | IWA ☐ OWA ☑ Room 351 at entrance to corridor. | 2.0 / 2.0 | 12:15 PM | 3:15 PM | 180 | 2.0 | 360 | | | <4.2 | |
| 2 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | <1.5 | |
| 3 | | IWA ☐ OWA ☐ Field Blank | | | | | | | | | <1.5 | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |
| | | IWA ☐ OWA ☐ | | | | | | | | | | |

| | | | | | |
|---|---|---|---|---|---|
| RELINQUISHED TO TEG DROP BOX (SIGNATURE) | DATE | TIME | RECEIVED FROM TEG DROP BOX (SIGNATURE) | DATE | TIME |
| RELINQUISHED BY: (SIGNATURE) | DATE: 8/6/02 | TIME | RECEIVED BY: (SIGNATURE) R. Rondina | DATE: 8.6.02 | TIME |
| ANALYST: (SIGNATURE) | DATE | TIME | COMMENTS | | |

CIRCLE: PCM TEM — BGRD PRE DURING POST — OSHA — OTHER NIOSH 7082

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

Fax results to Condition 2575

NYC-WTC_000107151

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

| | |
|---|---|
| REPORT DATE: | 08-07-02 |
| CLIENT: | Taylor Environmental Group, Inc. |
| PROJECT NAME: | SCA/Stuyvesant HS<br>3rd Floor |
| PROJECT NUMBER: | M477-15217/29881 |
| SAMPLED BY: | Client |
| SAMPLE DATE<br>DATE RECEIVED:<br>DATE ANALYZED: | 08-06-02<br>08-06-02<br>08-06-02 |
| SAMPLE MEDIA:<br>ANALYSIS REQUIRED: | Air Samples<br>Method NIOSH 7082 |

## ANALYSIS RESULTS

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION | LEAD CONCENTRATION ($\mu g/m^3$) | DETECTION LIMIT ($\mu g/m^3$) |
|---|---|---|---|---|
| 01 | 20945 | Room 351 at Entrance to Corridor | <4.2 | 4.2 |
| 02 | 20945 | Field Blank | <1.5 µg | 1.5 µg |
| 03 | 20945 | Field Blank | <1.5 µg | 1.5 µg |

NOTE 1:
THE REPORTING LIMIT (RL) IS 3.0 µg
NOTE 2:
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu g/m^3$ and a permissible exposure level (PEL) of 50 $\mu g/m^3$ for personal samples.
NOTE 3.
Blank units are in µg

## CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).