

22:46 No. 003 P.03

TITLE:



ATHENCA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 704-7400

Fax. (718) 704-4005

CLIENT: Warren & Paez Engineers, P. C.

LABORATORY ID #: T02-07-028

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.003643

PROJECT: 125 Cedar Street

DATE OF REPORT: 07/27/02

DATE OF ANALYSIS: 07/27/02

EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (m)	G.O.'s ANAL. V2ED	AREA ANALY ZED (mm ²)	ANALYT. SENSITIV. (micrograms)	TOTAL ASBESTOS AIR CONC. (micrograms)	TOTAL ASBESTOS FILTER CONC. (micrograms)	AIR CONC. FOR STRICT. 0.55-5.0um	AIR CONC. FOR STRICT. 5-10um	ASBEST. TYPE CRYST.	AMPHIB. ASBEST. TYPE SPECIFY
DE01	T02-07-028-1084	By down	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA
DE02	T02-07-028-1085	TWA right side of work area	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA
DE03	T02-07-028-1086	TWA middle of work area	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA
DE04	T02-07-028-1087	TWA left side of work area	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA
DE05	T02-07-028-1088	Exit to roof of PDNY	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA

ANALYST
E. Sioukri

LABORATORY DIRECTOR
Spiro Donganis

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenca Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling activities will be noted for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc. did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to areas tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenca Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

07/27/2002 11:41 FAX 718 784 4055

001

228 East 43rd Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-8530

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

LABORATORY: TEM

PROJECT: 125 Cedar St

ANALYSIS METHOD: PCM TEM

circle one

SAFETY EPA LEVEL II

LOCATION: facade

TECHNICIAN: DPO ELEMO

CONTACT: MICHAEL MOLAN

702-07-028

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (ppb/cc)
DE01	by Deco	3		03 03	0715 1715	600	1800	
DE02	W&P Rightside of W&P	3		03 03	0716 1716	600	1800	
DE03	middle	3		03 03	0717 1717	600	1800	
DE04	left side	3		03 03	0718 1718	600	1800	
DE05	Exit to roof at (ferry)	3		03 03	0720 1720	600	1800	
DE06	field (Blank)	1		03 03	0720 1720	600	1800	
DE07	Sealed Blank	1		03 03	0720 1720	600	1800	
DE08	Sealed Blank	1		03 03	0720 1720	600	1800	

COMMENTS:

SAMPLE BY: DPO ELEMO	DATE: 7/26/02
SIGNATURE: DPO	
RELEASED BY: DPO ELEMO	DATE: 7/26/02
SIGNATURE: DPO	
RECEIVED BY: G. Sioufen	DATE: 7/27/02
SIGNATURE: G	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background


ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490

Fax. (718) 784-4005

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

CLIENT: Warren & Panzer Engineers, P. C.

LABORATORY ID #: T02-07-025

ANALYT. METHODOLOGY: AHERA.

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.008643

PROJECT: 125 Cedar St. NYC

DATE OF REPORT: 07/26/02

DATE OF ANALYSIS: 07/26/02

 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O. % ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (microg/cm ³)	TOTAL ASBESTOS AIR CONC. (microg/cm ³)	TOTAL ASBESTOS FILTER CONC. (microg/cm ²)	AIR CONC. FOR STRUCT. 0.55-5.0um	AIR CONC. FOR STRUCT. ≥5.0um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
DE 1	T02-07-025-	Ry Decon	1800	5	0.0432	0.0049	0.0099	46.28	0.0049	0.0049	Chrys.	NA
DE 2	T02-07-025-	IWA Right side of WA	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA
DE 3	T02-07-025-	IWA Middle side of WA	1800	5	0.0432	0.0049	0.0049	23.14	0.0049	<0.0049	Chrys.	NA
DE 4	T02-07-025-	IWA Left side of WA	1800	5	0.0432	0.0049	<0.0049	<23.14	NA	NA	NA	NA
DE 5	T02-07-025-	Exit to Roof of (FDNY)	1800	5	0.0432	0.0049	0.0148	69.42	<0.0049	0.0148	Chrys.	NA

 ANALYST
E. Dimitrakas

 LABORATORY DIRECTOR
Spiro Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athena Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate ⁺ /a
1	100	100	100	100	100
2	100	100	100	100	100
3	100	100	100	100	100
4	100	100	100	100	100
5	100	100	100	100	100
6	100	100	100	100	100
7	100	100	100	100	100
8	100	100	100	100	100
9	100	100	100	100	100
10	100	100	100	100	100
11	100	100	100	100	100
12	100	100	100	100	100
13	100	100	100	100	100
14	100	100	100	100	100
15	100	100	100	100	100
16	100	100	100	100	100
17	100	100	100	100	100
18	100	100	100	100	100
19	100	100	100	100	100
20	100	100	100	100	100
21	100	100	100	100	100
22	100	100	100	100	100
23	100	100	100	100	100
24	100	100	100	100	100
25	100	100	100	100	100
26	100	100	100	100	100
27	100	100	100	100	100
28	100	100	100	100	100
29	100	100	100	100	100
30	100	100	100	100	100
31	100	100	100	100	100
32	100	100	100	100	100
33	100	100	100	100	100
34	100	100	100	100	100
35	100	100	100	100	100
36	100	100	100	100	100
37	100	100	100	100	100
38	100	100	100	100	100
39	100	100	100	100	100
40	100	100	100	100	100
41	100	100	100	100	100
42	100	100	100	100	100
43	100	100	100	100	100
44	100	100	100	100	100
45	100	100	100	100	100
46	100	100	100	100	100
47	100	100	100	100	100
48	100	100	100	100	100
49	100	100	100	100	100
50	100	100	100	100	100
51	100	100	100	100	100
52	100	100	100	100	100
53	100	100	100	100	100
54	100	100	100	100	100
55	100	100	100	100	100
56	100	100	100	100	100
57	100	100	100	100	100
58	100	100	100	100	100
59	100	100	100	100	100
60	100	100	100	100	100
61	100	100	100	100	100
62	100	100	100	100	100
63	100	100	100	100	100
64	100	100	100	100	100
65	100	100	100	100	100
66	100	100	100	100	100
67	100	100	100	1	

W&P FILE #: 079-01-02

CONTACT: MICHEN

LABORATORY:

ANALYSIS METHOD: PCM TEM TEM
circle one AHERA EPA LEVEL II

TECHNICIAN: DIPO EL ENO

CLIENT: NYC DEP
PROJECT: 125 Cedar st NYC
LOCATION: facade

[illegible]

COMMENTS:

DATE: 7/25/02

7/25/02

DATE: 1/23/06

7/25/02

DATE: 7/26/02

SAMPLE BY: Dipo Elena DATE: 7/25/12

SIGNATURE: James 7/25/02

RELEASED BY: Dyo E Lemo DATE: 1/23/02

SIGNATURE: Diya E 7/25/02

RECEIVED BY: E. Sienty DATE: 7/26/02

SAMPLE TYPE CODES

f - Blank

2 - Pre-Abatement

3 - During Abatement

4 - During Glove Bag Removal

S - Final Clearance (inside)

6 - Final Clearance (outside)

7. Personal

8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION


ATHENICA

ENVIRONMENTAL SERVICES INC.

TEL (718) 784-7490

Fax: (718) 784-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-07-020

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.008643

PROJECT: NYC DEP, 125 Cedar Street

DATE OF REPORT: 07/25/02

DATE OF ANALYSIS: 07/25/02

 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (m)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (struc/cm ²)	TOTAL ASBESTOS AIR CONC. (struc/cm ²)	TOTAL ASBESTOS FILTER CONC. (pg./mm ²)	AIR CONC. POR STRUCT. 0.55<5µm	AIR CONC. FOR STRUCT. 8<25.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
DE01	T02-07-020-1044	Decon	1485	6	0.0519	0.0050	<0.0050	<19.28	NA	NA	NA	NA
DE02	T02-07-020-1045	IWA right side of work area	1485	6	0.0519	0.0050	<0.0050	<19.28	NA	NA	NA	NA
DE03	T02-07-020-1046	IWA middle of work area	1485	6	0.0519	0.0050	0.0050	39.28	<0.0050	0.0050	Chrys.	NA
DE04	T02-07-020-1047	IWA left side of work area	1485	6	0.0519	0.0050	<0.0050	<19.28	NA	NA	NA	NA
DE05	T02-07-020-1048	Exit to roof FDNY	1485	6	0.0519	0.0050	<0.0050	<19.28	<0.0050	0.0050	Chrys.	NA

 ANALYST
E. Dimadick

 LABORATORY DIRECTOR
Spice Dengata

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0830**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a P.O.

W&P FILE #: 1079-01-02

LABORATORY:

ANALYSIS METHOD:	PCM	TEAM	TEAM

circle one.

TECHNICIAN: 1100 1150

CONTACT: MICHAEL NOLAN

#A7T

SCA JOB#:

W&P FILE #: 1079-01-02

LABORATORY:

ANALYSIS METHOD:	PCM	TEAM	TEAM

circle one.

TECHNICIAN: 1100 1150

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRA- (lb./cc.)
DE01	By Decan	3		03	03	1000	1815	495	1485	
DE02	WHA Rightside of WHA	3		03	03	1001	1816	495	1485	
DE03	✓ middle	3		03	03	1002	1817	495	1485	
DE04	✓ left side	3		03	03	1003	1818	495	1485	
DE05	Exit to roof of (FDNY)	3		03	03	1005	1820	495	1485	
DE06	field Blank	1		—	—	—	0	0	0	
DE07	✓	1		—	—	—	0	0	0	
DE08	Sealed Blank	1		—	—	—	0	0	0	

COMMENTS:

To 2-07-020

SAMPLE BY: WIPD 6-15-74 DATE: 7/24/02

SIGNATURE: *[Signature]*

RELEASED BY: Dapo Clement DATE: 7/24/03

SIGNATURE: _____

RECEIVED BY: E. Spitzer DATE: 7/24/02

SIGNATURE: _____

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

07/27/2002 11:41 AM 784 4085

001

20 East 40th Street
New York, NY 10017
(212) 922-0077
(212) 922-0030

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

LABORATORY:

CONTACT: MICHAEL MOLAN

PROJECT: 25 Cedar St

ANALYSIS METHOD: PCM

TEM (AHERRA)

EPALVELLII

LOCATION: facade

circle one

7400

T02-07-028

TECHNICIAN: DIPO ELEMO

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (mg./cc.)
DE01	by DeCaro	3		03	03	0715	1715	600	1800	
DE02	Right side of WA	3		03	03	0716	1716	600	1800	
DE03	middle	3		03	03	0717	1717	600	1800	
DE04	Left side	3		03	03	0718	1718	600	1800	
DE05	Exit to roof at (entry)	3		03	03	0720	1720	600	1800	
DE06	field Blank	1								
DE07		1								
DE08	Sealed Blank	1								

COMMENTS:

SA MPLE BY:	DIPO ELEMO	DATE:	7/26/02
SIC NATURE:	DIPPE		
RE EASED BY:	DIPO ELEMO	DATE:	7/26/02
SIC NATURE:	DIPPE		
RE CEIVED BY:	E. Sioufen	DATE:	7/27/02
SIC NATURE:			

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background


ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490

Fax. (718) 784-4065

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-07-016

ANALYT. METHODOLOGY: AIHRA

FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.008643

PROJECT: NYC DEP, 125 Cedar St.

DATE OF REPORT: 07/24/02

DATE OF ANALYSIS: 07/24/02

 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'S ANAL YZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (ftr/cm ²)	TOTAL ASBESTOS AIR CONC. (ftr/cm ²)	TOTAL ASBESTOS FILTER CONC. (ftr/cm ²)	AIR CONC. FOR STRUCT. 0.5-5µm	AIR CONC. FOR STRUCT. 5-10µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
DE01	T02-07-016-1024	By Decon	1425	7	0.0605	0.0045	<0.0045	<16.53	NA	NA	NA	NA
DE02	T02-07-016-1025	TWA right side of WA	1425	7	0.0605	0.0045	<0.0045	<16.53	NA	NA	NA	NA
DE03	T02-07-016-1026	TWA middle side of WA	1425	7	0.0605	0.0045	<0.0045	<16.53	NA	NA	NA	NA
DE04	T02-07-016-1027	TWA Left side	1425	7	0.0605	0.0045	<0.0045	<16.53	NA	NA	NA	NA
DE05	T02-07-016-1028	Exit to roof of FDNY	1425	7	0.0605	0.0045	<0.0045	<16.53	NA	NA	NA	NA

ANALYST

E. Dimitrakas

 LABORATORY DIRECTOR
Spiro Dongaris

LABORATORY CREDIT/TEST INFORMATION

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- All sampling activities will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a

12 hr⁺/a 6 hr⁺/a 3 hr⁺/h Immediate ⁺/a

PAGE 1 OF 1

P.O.

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

LABORATORY:

PROJECT: 125 Cedar St

LOCATION: facade

ANALYSIS METHOD: PCM

TECHNICIAN: Dipo

TECHNICAL NOLAN

702-07-016

Also Sample

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (mg/m ³)
DE01	By Decm	3	1	05	05	1315	1800	285	1425	16.53
DE02	11MT right side of WA	3	1	05	05	1316	1801	285	1425	16.53
DE03	— middle —	3	1	05	05	1317	1802	285	1425	16.53
DE04	— left side —	3	1	05	05	1318	1803	285	1425	16.53
DE05	EXIT to roof off (any)	3	1	05	05	1320	1805	285	1425	16.53
DE06	field Blank	1	1	—	—	—	—	—	—	—
DE07	—	1	1	—	—	—	—	—	—	—
DE08	Sealed Blank	1	1	—	—	—	—	—	—	—

COMMENTS:

SAMPLE BY: Dipo	DATE: 7/23/02
SIGNATURE: Dipo	
RELEASED BY: Dipo	DATE: 7/23/02
SIGNATURE: Dipo	
RECEIVED BY: E. Sigler	DATE: 7/23/02
SIGNATURE: E. Sigler	22:00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background


ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel: (718) 704-7480

Fax: (718) 704-1085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-07-013

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: MCE

 AVERAGE G.O. AREA (mm²): 0.008643

PROJECT: NYC DEP, 125 Cedar Street

DATE OF REPORT: 07/25/02

DATE OF ANALYSIS: 07/24/02

 EFFECTIVE FILTER AREA (mm²): 385

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (lit)	G.O. ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITV. (airuct/cm ³)	TOTAL ASBESTOS AIR CONC. (airuct/cm ³)	TOTAL ASBESTOS FILTER CONC. (airuct/cm ³)	AIR CONC. FOR STRUCT. 0.5<S<5µm	AIR CONC. FOR STRUCT. S>5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST TYPE SPECIFY
DE01	T02-07-013-1009	By Decon	1575	6	0.0519	0.0047	0.0094	38.57	0.0094	<0.0047	Chrys.	NA
DE02	T02-07-013-1010	TWA right side of work area	1575	6	0.0519	0.0047	<0.0047	<19.28	NA	NA	NA	NA
DE03	T02-07-013-1011	IWA middle of work area	1575	6	0.0519	0.0047	0.0047	19.28	0.0047	<0.0047	Chrys.	NA
DE04	T02-07-013-1012	IWA left side of work area	1575	6	0.0519	0.0047	0.0047	19.28	<0.0047	0.0047	Chrys.	NA
DE05	T02-07-013-1013	Exit to roof of FDNY	1575	4	0.0346	0.0071	0.0354	114.63	0.0212	0.0141	Chrys.	NA

ANALYST

F. Dimitrakas

LABORATORY DIRECTOR

Spiro Dougaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

