

***** -IND. XMT JOURNAL- ***** DATE OCT-24-2002 ***** TIME 14:24 *****

DATE/TIME = OCT-24-2002 14:20
 JOURNAL No. = 31
 COMM.RESULT = OK
 PAGE(S) = 013
 DURATION = 00:03'58
 FILE No. =
 MODE = TRANSMISSION
 DESTINATION = 912126373105
 RECEIVED ID = NYCRRO / 9 1212 637 3105
 RESOLUTION = STD

-NYCDEP BANHM ASB/LEAD TRU-

***** -

- ***** - 718 595 3648- *****

UL1-15-2002 16:22

NYCDEP BANHM ASB/LEAD TRU

718 595 3648 P.07

48

8 samples > 0.0009 → 6 units/spaces

9 samples = 0.0009 → 10 units/spaces

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

Received: 10/9/02

1:00:00 PM

ATC Group #: 8950

Analysis Date: 10/13/02

Suggest Analytical
Sensitivity of 0.0004
or
0.0005add columns
Asbestos Concentration
25µ
S/mm³ S/cc

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.3µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Asbestos Concentration (S/cc)	Notes
X A 5S 03 8950 -1	3600.00	0.1236	71	CHRYSTILE	0	0.0009	24.26	0.0026	Cellulose - 3 Structures, Gypsum - 58 Structures
X A 5S 04 8950 -2	3600.00	0.1236	48	CHRYSTILE	0	0.0009	16.18	0.0017	Cellulose - 1 Structures, Gypsum - 47 Structures
A 5S 05 8950 -3	3600.00	0.1236	83	CHRYSTILE	(8)	0.0009	64.70	0.0069	Cellulose - 1 Structures, Gypsum - 81 Structures, Glass - 1 Structures
X A 5S 06 8950 -4	3600.00	0.1236	70	CHRYSTILE	(2)	0.0009	32.35	0.0035	Cellulose - 1 Structures, Gypsum - 69 Structures
A 5S 07 8950 -5	3600.00	0.1236	12	CHRYSTILE	(2)	0.0009	16.18	0.0017	Gypsum - 12 Structures
X A 5N 08 8950 -6	3600.00	0.1236	21	CHRYSTILE	0	0.0009	16.18	0.0017	Gypsum - 21 Structures
(A 5N 09 8950 -7)	3600.00	0.1236	21	CHRYSTILE	0	0.0009	8.09	0.0009	Gypsum - 21 Structures

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Sunday, October 13, 2002

Page 1 of 6

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street
New York NY 10010

Received: 10/9/02 1:00:00 PM
ATC Group #: 8950
Analysis Date: 10/13/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	* Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
A 5N 10 8950 -8	3600.00	0.1236	19	CHRYSTOLE	① 1	0.0009	16.18	0.0017	Gypsum - 19 Structures
A 5N 11 8950 -9	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09	<0.0009	Cellulose - 1 Structures
A 5N 12 8950 -10	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09	<0.0009	Cellulose - 1 Structure, Gypsum - 1 Structures
A 5 13 8950 -11	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09	<0.0009	Cellulose - 2 Structures
A 5 14 8950 -12	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09	<0.0009	Gypsum - 2 Structures
A 4S 15 8950 -13	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09	<0.0009	Gypsum - 1 Structures
A 4S 16 8950 -14	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09	<0.0009	Gypsum - 1 Structures
A 4S 17 8950 -15	3600.00	0.1236	0	None Detected	0 0	0.0009	<8.09	<0.0009	
A 4S 18 8950 -16	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09	<0.0009	Cellulose - 1 Structures, Gypsum - 1 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP P1MTEM #101187-0, NY State ELAP #10879

Sunday, October 13, 2002

Page 2 of 6

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/9/02 1:00:00 PM
 ATC Group #: 8950
 Analysis Date: 10/13/02

Fax: (212) 353-3599 Phone: (212) 353-8250


Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes	
A 4S 19 8950 -17	3600.00	0.1236	0	None Detected	0	0	0.0009	<8.09	<0.0009	
A 4N 20 8950 -18	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009	Cellulose - 1 Structures
A 4N 21 8950 -19	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009	Cellulose - 1 Structures
A 4N 22 8950 -20	3600.00	0.1236	3	None Detected	0	0	0.0009	<8.09	<0.0009	Gypsum - 3 Structures
A 4N 23 8950 -21	3600.00	0.1236	0	None Detected	0	0	0.0009	<8.09	<0.0009	
A 4N 24 8950 -22	3600.00	0.1236	10	None Detected	0	0	0.0009	<8.09	<0.0009	Cellulose - 2 Structures, Gypsum - 8 Structures
A 4 25 8950 -23	3600.00	0.1236	0	None Detected	0	0	0.0005	<8.09	<0.0009	
A 4 26 8950 -24	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009	Cellulose - 1 Structures
A 3S 27 8950 -25	3600.00	0.1236	2	None Detected	0	0	0.0009	<8.09	<0.0009	Gypsum - 2 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Sunday, October 13, 2002

Page 3 of 6

OCT-15-2002 10:22

NYCDEP BHHM HSB/LEAD TRU

718 595 3648 P.10

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street
New York NY 10010

Received: 10/9/02 1:00:00 PM
ATC Group #: 8950
Analysis Date: 10/13/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Net Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
A 3S 28 8950 -26	3600.00	0.1236	1	CHRYSTILE	① 0	0.0009	8.09	Gypsum - 1 Structures
A 3S 29 8950 -27	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09	Gypsum - 1 Structures
A 3S 30 8950 -28	3600.00	0.1236	3	None Detected	0 0	0.0009	<8.09	Gypsum - 3 Structures
A 3S 31 8950 -29	3600.00	0.1236	4	CHRYSTILE	① 0	0.0009	8.09	Cellulose - 1 Structures, Gypsum - 3 Structures
A 3N 32 8950 -30	3600.00	0.1236	4	CHRYSTILE	① 2	0.0009	24.26	Cellulose - 1 Structures, Gypsum - 3 Structures
A 3N 33 8950 -31	3600.00	0.1236	0	None Detected	0 0	0.0009	<8.09	<0.0009
A 3N 34 8950 -32	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09	Cellulose - 2 Structures
A 3N 35 8950 -33	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09	Gypsum - 1 Structures, Glass - 1 Structures
A 3N 36 8950 -34	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09	Cellulose - 1 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Sunday, October 13, 2002

Page 4 of 6

OCT-15-2002 16:23

NYCDEP BANHM ASB/LEAD TRU

718 595 3648 P.11

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street
New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

Received: 10/9/02 1:00:00 PM
ATC Group #: 8950
Analysis Date: 10/13/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
A 3 37 8950 -35	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009 Gypsum - 1 Structures
A 3 38 8950 -36	3600.00	0.1236	7	None Detected	0	0	0.0009	<8.09	<0.0009 Cellulose - 2 Structures, Gypsum - 1 Structures, Glass - 4 Structures
A 2S 39 8950 -37	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009 Gypsum - 1 Structures
A 2S 40 8950 -38	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009 Gypsum - 1 Structures
A 2S 41 8950 -39	3600.00	0.1236	2	None Detected	0	0	0.0009	<8.09	<0.0009 Cellulose - 1 Structures, Gypsum - 1 Structures
A 2S 42 8950 -40	3600.00	0.1236	6	None Detected	0	0	0.0009	<8.09	<0.0009 Gypsum - 6 Structures
A 2S 43 8950 -41	3600.00	0.1236	2	None Detected	0	0	0.0009	<8.09	<0.0009 Cellulose - 1 Structures, Gypsum - 1 Structures
A 2N 44 8950 -42	3600.00	0.1236	1	None Detected	0	0	0.0009	<8.09	<0.0009 Cellulose - 1 Structures, Gypsum - 2 Structures
A 2N 45 8950 -43	3600.00	0.1236	4	None Detected	0	0	0.0009	<8.09	<0.0009 Cellulose - 2 Structures, Gypsum - 2 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GCRYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-J, NY State ELAP #10879

Sunday, October 13, 2002

Page 5 of 6

UL1-15-2002 16:23

NYC/DEP BAHNM ASB/LEAD TRU

718 595 3648 P.12

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/9/02 1:00:00 PM
 ATC Group #: 8950
 Analysis Date: 10/13/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
A 2N 46 8950 -44	3600.00	0.1236	2	None Detected	0 0	0.0009	<8.09 <0.0009	Gypsum - 1 Structures Glass - 1 Structures
A 2N 47 8950 -45	3600.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 1 Structures, Gypsum - 2 Structures
A 2N 48 8950 -46	3600.00	0.1236	9	CHRYSTOLITE	(2) 0	0.0009	16.18 0.0017	Cellulose - 6 Structures, Gypsum - 3 Structures
A 2 49 8950 -47	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09 <0.0009	Gypsum - 1 Structures
A 1 50 8950 -48	3600.00	0.1236	1	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 1 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Sunday, October 13, 2002

Page 6 of 6

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 10/8/02

11:10:00 AM

ATC Group #: 8943

Analysis Date: 10/9/02

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
PH-01 8943 -1	3850.00	0.1236	3	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
PH-02 8943 -2	3840.00	0.1236	4	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 4 Structures
PH-03 8943 -3	3830.00	0.1236	3	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
PH-04 8943 -4	3820.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
PH-05 8943 -5	3810.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-06 8943 -6	3820.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-07 8943 -7	3810.00	0.1236	0	None Detected	0 0	0.0008	<8.09	<0.0008

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

10/10/2002 07:45 FAX 212 353 8306

ATC

003

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
12N-08 8943 -8	3800.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-09 8943 -9	3790.00	0.1236	5	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 5 Structures
12N-10 8943 -10	3780.00	0.1236	0	None Detected	0	0	0.0008	<8.09	<0.0008
12SW-11	3760.00	0.1236	3	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures

10/11/2002 16:37 FAX 212 353 8308

ATC

002

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 10/8/02

11:10:00 AM

ATC Group #: 8943

Analysis Date: 10/9/02

Project: DEP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
PH-01 8943 -1	3850.00	0.1236	3	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
PH-02 8943 -2	3840.00	0.1236	4	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 4 Structures
PH-03 8943 -3	3830.00	0.1236	3	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
PH-04 8943 -4	3820.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
PH-05 8943 -5	3810.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-06 8943 -6	3820.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-07 8943 -7	3810.00	0.1236	0	None Detected	0	0	0.0008	<8.09	<0.0008

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited to: NVLAP PLM/TEM #101187-0, NY State ELAP #10879

10/11/2002 16:38 FAX 212 353 8306

ATC

003

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures As-5 S-5	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
12N-08 8943 -8	3800.00	0.1236	1	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 1 Structures
12N-09 8943 -9	3790.00	0.1236	5	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 5 Structures
12N-10 8943 -10	3780.00	0.1236	0	None Detected	0 0	0.0008	<8.09 <0.0008	
12SW-11 8943 -11	3760.00	0.1236	3	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 3 Structures
12SW-12 8943 -12	3750.00	0.1236	1	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 1 Structures
12SW-13 8943 -13	3740.00	0.1236	1	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 1 Structures
12SE-14 8943 -14	3730.00	0.1236	5	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 4 Structures, Gypsum - 1 Structure
12SE-15 8943 -15	3720.00	0.1236	1	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 3 Structures
12SE-16 8943 -16	3710.00	0.1236	0	None Detected	0 0	0.0008	<8.09 <0.0008	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PUMTEM #01187-0, NY State ELAP #10679

10/11/2002 16:38 FAX 212 353 8306

ATC

004

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AIERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
12SE-17 8943-17	3700.00	0.1236	4	None Detected	0 0	0.0008	<8.09	Cellulose - 4 Structures
12SE-18 8943-18	3690.00	0.1236	1	None Detected	0 0	0.0008	<8.09	Cellulose - 1 Structures
11N-19 8943-19	3660.00	0.1236	0	None Detected	0 0	0.0009	<8.09	Cellulose - 0 Structures
11N-20 8943-20	3650.00	0.1236	2	None Detected	0 0	0.0009	<8.09	Cellulose - 1 Structures
11N-21 8943-21	3640.00	0.1236	3	None Detected	0 0	0.0009	<8.09	Cellulose - 3 Structures
11N-22 8943-22	3630.00	0.1236	1	None Detected	0 0	0.0009	<8.09	Cellulose - 1 Structures
11N-23 8943-23	3620.00	0.1236	5	None Detected	0 0	0.0009	<8.09	Cellulose - 3 Structures, Gypsum - 2 Structure
11S-24 8943-24	3630.00	0.1236	0	None Detected	0 0	0.0009	<8.09	Cellulose - 0 Structures
11S-25 8943-25	3620.00	0.1236	2	None Detected	0 0	0.0009	<8.09	Cellulose - 2 Structures

MARK PRYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

10/11/2002 16:39 FAX 212 353 8306

ATC

005

ATTN: Benjamin Sallami
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3598 Phone: (212) 353-8280
 Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
11S-26 8943 -26	3610.00	0.1236	1	None Detected	0 0	0.0009	<8.09 <0.0009	Gypsum - 1 Structure
11S-27 8943 -27	3600.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 2 Structures, Gypsum - 1 Structure
11S-28 8943 -28	3600.00	0.1236	4	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 4 Structures
10N-29 8943 -29	3670.00	0.1236	0	None Detected	0 0	0.0008	<8.09 <0.0008	
10N-30 8943 -30	3660.00	0.1236	2	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 1 Structures, Gypsum - 1 Structure
10N-31 8943 -31	3650.00	0.1236	2	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 2 Structure
10N-32 8943 -32	3640.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 2 Structures, Glass - 1 Structure
10N-33 8943 -33	3630.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 3 Structures
10S-34 8943 -34	3690.00	0.1236	0	None Detected	0 0	0.0008	<8.09 <0.0008	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NYLAP PL WTEM #101187-0, NY State ELAP #10879

10/11/2002 16:39 FAX 212 353 8306

ATC

006

Attn: Benjamin Sallami
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02


Fax: (212) 353-9599 Phone: (212) 353-8280
 Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.3µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
10S-35 8943-35	3680.00	0.1236	3	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures, Gypsum - 7 Structures
10S-36 8943-36	3670.00	0.1236	3	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
10S-37 8943-37	3660.00	0.1236	0	None Detected	0 0	0.0009	<8.09	<0.0009
10S-38 8943-38	3650.00	0.1236	0	None Detected	0 0	0.0009	<8.09	<0.0009
A-39 8943-39	3680.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
A-40 8943-40	3660.00	0.1236	0	None Detected	0 0	0.0009	<8.09	<0.0009
A-41 8943-41	3650.00	0.1236	2	CHRYSTOLE (1)	0 0	0.0009	8.09	0.0009 Cellulose - 2 Structures
A-42 8943-42	3640.00	0.1236	3	None Detected	0 0	0.0009	<8.09	<0.0009 Cellulose - 3 Structures
A-43 8943-43	3660.00	0.1236	2	None Detected	0 0	0.0009	<8.09	<0.0009 Cellulose - 2 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NPLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NPLAP PLM/TEM #1011187.0, NY State ELAP #10870

10/11/2002 16:40 FAX 212 353 6306

ATC

007

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 8.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
A-44 8943 -44	3610.00	0.1236	3	None Detected	0	0.0009	<8.09	Cellulose - 3 Structures
A-45 8943 -45	3620.00	0.1236	4	None Detected	0	0.0009	<8.09	Cellulose - 1 Structures, Gypsum - 3 Structure
A-46 8943 -46	3640.00	0.1236	10	None Detected	0	0.0009	<8.09	Cellulose - 10 Structures
A-47 8943 -47	3630.00	0.1236	0	None Detected	0	0.0009	<8.09	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

Page 6 of 6

10/11/2002 16:31 FAX 212 353 8306

ATC

002

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/9/02 8:00:00 AM
 ATC Group #: 8946
 Analysis Date: 10/11/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
A-9N-01 8946 -1	3870.00	0.1236	36	CHRYSTILE	① 2	0.0008	24.26 0.0024	Cellulose - 20 Structures, Gypsum - 16 Structures
A-9N-02 8946 -2	3860.00	0.1236	16	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 4 Structures, Gypsum - 12 Structures
A-9N-03 8946 -3	3850.00	0.1236	34	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 2 Structures, Gypsum - 29 Structures
A-9N-04 8946 -4	3840.00	0.1236	19	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 3 Structures, Gypsum - 15 Structures
A-9N-05 8946 -5	3830.00	0.1236	10	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 2 Structures, Gypsum - 8 Structures
A-9S-06 8946 -6	3910.00	0.1236	11	CHRYSTILE	① 0	0.0008	8.09 0.0008	Cellulose - 2 Structures, Gypsum - 9 Structures
A-9S-07 8946 -7	3900.00	0.1236	22	None Detected	0 0	0.0008	<8.09 <0.0008	Cellulose - 1 Structure, Gypsum - 21 Structures

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Friday, October 11, 2002

Page 1 of 6

10/11/2002 16:32 FAX 212 353 8308

ATC

004

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street
New York NY 10010

Received: 10/9/02 8:00:00 AM
ATC Group #: 8946
Analysis Date: 10/11/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)		Notes
A-8S-17 8946 -17	3840.00	0.1236	24	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 7 Structures, Gypsum - 14 Structures
A-8S-18 8946 -18	3830.00	0.1236	33	CHRYSTILE	1	1	0.0008	16.18	0.0016	Cellulose - 3 Structures, Gypsum - 30 Structures
A-8S-19 8946 -19	3820.00	0.1236	28	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 7 Structures, Glass - 21 Structure
A-8S-20 8946 -20	3810.00	0.1236	17	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 2 Structures, Gypsum - 15 Structures
A-7N-21 8946 -21	3820.00	0.1236	21	CHRYSTILE	0	1	0.0008	8.09	0.0008	Cellulose - 5 Structures, Gypsum - 16 Structures
A-7N-22 8946 -22	3810.00	0.1236	14	CHRYSTILE	1	0	0.0008	8.09	0.0008	Cellulose - 4 Structures, Gypsum - 8 Structures, Glass - 2 Structure
A-7N-23 8946 -23	3800.00	0.1236	18	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 2 Structures, Gypsum - 16 Structures
A-7N-24 8946 -24	3790.00	0.1236	19	CHRYSTILE	0	1	0.0008	8.09	0.0008	Cellulose - 1 Structures, Gypsum - 18 Structures
A-7N-25 8946 -25	3780.00	0.1236	9	CHRYSTILE	0	1	0.0008	8.09	0.0008	Cellulose - 1 Structures, Gypsum - 9 Structures

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State EJP #10879

Friday, October 11, 2002

Page 3 of 6

10/11/2002 16:33 FAX 212 353 8308

ATC

005

Attn: Benjamin Salleri
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/9/02 8:00:00 AM
 ATC Group #: 8946
 Analysis Date: 10/11/02

Fax: (212) 353-3599 Phone: (212) 353-8280


Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
A-7S-26 8946 -26	3740.00	0.1236	10	CHRYSTILE	① 0	0.0008	8.09	0.0008	Cellulose - 4 Structures, Gypsum - 5 Structures
A-7S-27 8946 -27	3730.00	0.1236	10	CHRYSTILE	③ 0	0.0008	24.26	0.0025	Cellulose - 1 Structures, Gypsum - 9 Structures
A-7S-28 8946 -28	3720.00	0.1236	8	CHRYSTILE	0 1	0.0008	8.09	0.0008	Cellulose - 3 Structures, Gypsum - 5 Structure
A-7S-29 8946 -29	3710.00	0.1236	23	CHRYSTILE	0 1	0.0008	8.09	0.0008	Cellulose - 1 Structures, Gypsum - 22 Structures
A-7S-30 8946 -30	3700.00	0.1236	4	None Detected	0 0	0.0008	<8.09	<0.0008	Cellulose - 2 Structures, Gypsum - 2 Structure
A-6N-31 8946 -31	3790.00	0.1236	30	None Detected	0 0	0.0008	<8.09	<0.0008	Cellulose - 6 Structures Gypsum - 24 Structure
A-6N-32 8946 -32	3780.00	0.1236	28	None Detected	0 0	0.0008	<8.09	<0.0008	Cellulose - 1 Structures, Gypsum - 27 Structures
A-6N-33 8946 -33	3770.00	0.1236	16	None Detected	0 0	0.0008	<8.09	<0.0008	Cellulose - 2 Structures, Gypsum - 14 Structures
A-6N-34 8946 -34	3870.00	0.1236	16	None Detected	0 0	0.0008	<8.09	<0.0008	Cellulose - 7 Structures, Gypsum - 9 Structure

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval of ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

Friday, October 11, 2002

Page 4 of 6

10/11/2002 16:34 FAX 212 353 8308

ATC

0006

Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/9/02 8:00:00 AM
 ATC Group #: 8946
 Analysis Date: 10/11/02

Fax: (212) 353-3599 Phone: (212) 353-8280


Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
A-6N-35 8946 -35	3760.00	0.1236	4	None Detected	0	0	0.0008	<8.09	<0.0008 Glass - 4 Structure
A-6S-36 8946 -36	3850.00	0.1236	22	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 7 Structures, Gypsum - 15 Structures
A-6S-37 8946 -37	3840.00	0.1236	10	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures, Glass - 7 Structure
A-6S-38 8946 -38	3830.00	0.1236	10	None Detected	0	0	0.0008	<8.09	<0.0008 Gypsum - 10 Structures
A-6S-39 8946 -39	3820.00	0.1236	11	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structure, Gypsum - 10 Structures
A-6S-40 8946 -40	3810.00	0.1236	28	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 7 Structures, Gypsum - 26 Structures
A-41 8946 -41	3800.00	0.1236	35	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures, Gypsum - 34 Structures
A-42 8946 -42	3790.00	0.1236	24	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures, Gypsum - 21 Structures
A-43 8946 -43	3800.00	0.1236	19	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 2 Structures, Gypsum - 17 Structure

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Friday, October 11, 2002

Page 5 of 6

10/11/2002 16:34 FAX 212 353 8308

ATC

007

Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 10/9/02

8:00:00 AM

ATC Group #: 8946

Analysis Date: 10/11/02

Project: DEP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Asbestos Concentration (S/cc)	Notes
A-44 8946 -44	3800.00	0.1236	23	CHRYSTILE	0	3	0.0008	24.26	0.0025 Cellulose - 8 Structures, Gypsum - 15 Structures
A-45 8946 -45	3800.00	0.1236	29	CHRYSTILE	2	1	0.0008	24.26	0.0025 Cellulose - 1 Structures, Gypsum - 28 Structures
A-46 8946 -46	3790.00	0.1236	41	CHRYSTILE	1	0	0.0008	8.09	0.0008 Cellulose - 4 Structures, Gypsum - 37 Structures
A-47 8946 -47	3800.00	0.1236	33	CHRYSTILE	0	2	0.0008	16.18	0.0016 Cellulose - 2 Structures, Gypsum - 31 Structures
A-48 8946 -48	3800.00	0.1236	22	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures, Gypsum - 19 Structures

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory end analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

Friday, October 11, 2002

Page 6 of 6