



ASSOCIATES INC.

104 EAST 25TH STREET
 NEW YORK, NEW YORK 10010-2917
 (TEL.) 212-353-8280 (FAX) 212-353-8306

F A X T R A N S M I T T A L

DATE: October 16, 2002
TO: Penny Theodorells
COMPANY: NYCDEP
ADDRESS: 59-17 Junction Blvd.
PHONE NUMBER: 718-595-3657
FAX NUMBER: 718-595-3744
FROM: Benjamin M. Sallemi
PHONE NUMBER: 212.353.8280 ext. 295
SUBJECT: 125 Cedar Street – Asbestos Clearance Results

NUMBER OF PAGES TO FOLLOW COVER: 2

Message:

Penny,

Clearance results for the 5th floor South apartment, which originally failed under the PCMe criterion.

If you have any questions, please feel free to contact me at the telephone number above.

Thanks.

Ben Sallemi

FW		Date	10/17	# of pages	3
Post-it® Fax Note 7671		To	Bob Fitzpatrick		
		From	Penny Theodorells		
		Co./Dept	NYC DEP		
		Phone #	(212) 637-3117		
		Fax #	(212) 637-3115		
		Phone #	(718) 595-3657		
		Fax #	(718) 595-3744		

CONFIDENTIALITY NOTICE:

The documents accompanying this transmittal contain confidential and privileged information intended for the exclusive use of the individual named above. If the reader of this message is not the intended recipient, or the employee or agent responsible for delivering it to the intended recipient, you are hereby notified that any dissemination, distribution or copying of the documents accompanying this transmittal is strictly prohibited. If you have received this transmittal in error, please immediately notify us by telephone (at 1.800.725.3282) to arrange for its return. Thank you.

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

Received: 10/17/02

10:05:00 PM

ATC Group #: 8995

Analysis Date: 10/17/02

EPA PCMe Method Via Transmission Electron Microscopy

Sample	Volume	Non Asbestos Fibers	PCM F/cc	Asbestos Type(s)	Asbestos Fibers	Asbestos % of total	EPA PCMe (TEM) F/cc	Notes
03 8995 -1	3650.00	2	0.001	None Detected	0	0	<0.0002	Cellulose - 1 Structures, Gypsum - 4 Structures
04 8995 -2	3650.00	2	0.001	None Detected	0	0	<0.0002	Cellulose - 2 Structures
05 8995 -3	3650.00	1	0.001	None Detected	0	0	<0.0002	Cellulose - 1 Structures
06 8995 -4	3650.00	3	0.001	None Detected	0	0	<0.0002	Cellulose - 3 Structures
07 8995 -5	3650.00	1	0.001	None Detected	0	0	<0.0002	Cellulose - 1 Structures

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D

Approved by:

ATC is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by ATC Associates Inc.

Analysis performed by ATC Associates Inc. (NY ELAP #10879).

Forty Grid Openings from each of the samples were examined for structures greater than 5µm length and having a length-to-width ratio greater than 3:1.

Thursday, October 17, 2002

Page 1 of 1

***** -IND. XMT JOURNAL- ***** DATE OCT-17-2002 ***** TIME 15:47 *****

DATE/TIME = OCT-17-2002 15:45
 JOURNAL No. = 28
 COMM.RESULT = OK
 PAGE(S) = 003/003
 DURATION = 00:01'05
 FILE No. = 076
 MODE = MEMORY TRANSMISSION
 DESTINATION = 912126373115
 RECEIVED ID = / 1 212 637 3115
 RESOLUTION = STD

-NYCDEP BANHM ASB/LEAD TRU-

***** -

- ***** -

718 595 3648- *****