

101091903

[illegible]

Page 1 of 2

Phase Control Microscopy (PCM) Fiber Results

59 Maiden Lane, New York City (Ambient)

Soil Job # 204991903
Client Name: GLOMAR CORP.

Soil Job Sample #	Client Sample # / Location	Time Collected	Flow Rate (Micrograms)	Durability (min.)	Air Filtration (Hours)	Fiber Count (Fibers/cm²)	Plan Density (Fibers/cm²)	Fiber Count (Fibers/cm²)	TWA
01	00130 10th Floor Balcony - Corridor North	9/15/01	0	0	1000	100	2.55	<0.001	
02	00229 10th Floor Balcony Corridor South	9/15/01	0	0	1000	100	2.55	<0.001	
03	00229 2nd Floor Corridor North	9/15/01	0	0	1000	100	2.55	<0.001	
04	004 2nd Floor Corridor South Corridor	9/15/01	0	0	1000	100	2.55	<0.001	
05	005 6th Floor Corridor East	9/15/01	0	0	1000	100	2.55	<0.001	
06	006 6th Floor Corridor West	9/15/01	0	0	1000	100	2.55	<0.001	
07	007 10th Floor Corridor East	9/15/01	0	0	1000	100	2.55	<0.001	
08	008 7th Floor Corridor West	9/15/01	0	0	1000	100	2.55	<0.001	
09	009 8th Floor Corridor North	9/15/01	0	0	1000	100	2.55	<0.001	
10	010 8th Floor Corridor South	9/15/01	0	0	1000	100	2.55	<0.001	
11	011 9th Floor Corridor North	9/15/01	0	0	1000	100	2.55	<0.001	
12	012 9th Floor Corridor South	9/15/01	0	0	1000	100	2.55	<0.001	
13	013 10th Floor Corridor East	9/15/01	0	0	1000	100	2.55	<0.001	
14	014 10th Floor Corridor West	9/15/01	0	0	1000	100	2.55	<0.001	
15	015 11th Floor Corridor North	9/15/01	0	0	1000	100	2.55	<0.001	

2126792114 TO 1010321191434821 P.02/05

SoLab Job #: 201001905
Client Name: GLORIAN CORP.

Phase Contract Inventory (PCMI) Filter Results

30 Madison Avenue, New York City (Arbitral)

SoLab Sample #	Client Sample # / Location	Date Collected	PC In Drum (Sample #)	Air Filtered (Sample #)	Fields	Fibers	Fiber Density (Fibers/cm ²)	Fiber Conc. (Fibers/cm ²)	TWA
36	0016 11th Floor Corridor South	9/15/01	1	1000	100	2	2.83	<0.004	
37	0017 12th Floor Corridor East	9/15/01	1	1000	100	2	2.95	<0.004	
38	0018 12th Floor Corridor	9/15/01	1	1000	100	3	3.02	<0.004	
39	0019 13th Floor Corridor North	9/15/01	1	1000	100	2	2.55	<0.001	
20	0020 13th Floor Corridor South	9/15/01	1	1000	100	3	3.02	<0.001	

Responsible Signer: V. G. New York, New York

SoLab is an asbestos laboratory. All asbestos samples are analyzed by SoLab using a Phase Contrast Microscopy (PCM) method. The results are reported in terms of fibers per cubic centimeter (f/cc) and are based on a minimum of 1000 fibers counted. The results are reported in terms of fibers per cubic centimeter (f/cc) and are based on a minimum of 1000 fibers counted.

718 403 4199 P.21
718 403 4199 P.21

GLORIAN CORP

DEPT OF FINANCE

1-914-345-2170

SEP-26-2001 09:51
SEP-18/2001 12:49

DEP-EBC

Fax: 212-361-1577