



CONSULTING & TESTING SERVICES, INC.

ASBESTOS INVESTIGATION


AT

**NEW YORK UNIVERSITY
200 WATER STREET, ENTIRE
NEW YORK, NY**

September 2001
Project # NY-388-01

Prepared for:

NEW YORK UNIVERSITY
Environmental Services
14 Waverly Place, 2nd Floor
New York, NY 10003
Attn.: Ms. Stephanie Kung





September 14, 2001

Ms. Stephanie Kung
Senior Environmental Specialist
NEW YORK UNIVERSITY
Environmental Services
14 Waverly Place 2nd Floor
New York, NY 10003

**RE: ASBESTOS INVESTIGATION PERFORMED AT: 200 WATER STREET, LOBBY,
NEW YORK, NEW YORK
PROJECT # NY-388-01**

Dear Ms. Kung:

On September 13th, 2001, CTSI performed an asbestos investigation at the above referenced premises. New York City and State licensed inspector conducted the investigation.

The purpose of the investigation was to identify suspect dust that may contain asbestos. An independent licensed laboratory (EMSL) using Polarized Light Microscopy (PLM) method analyzed all samples collected.

Two (2) bulk samples were collected from suspect dust above mailboxes located within the lobby. Based on sample analysis all bulk samples are non-ACM.

Also, enclosed please find Bulk Sample Analysis and PLM bulk sample certificate of analysis.

If you have any questions or need further information, please do not hesitate to contact our office.

Sincerely,

CONSULTING & TESTING SERVICES, INC.

Farhood Salami
Project Executive
NYC Asbestos License # 84243

Encl.

2001:report\asb\m\knyu\200waterst.ny-388-01

PLM **BULK SAMPLE ANALYSIS**

Client: NYU **CTSI Project #:** NY-388-01 **Location:** 200 Water Street
Date: September 13th, 2001

SAMPLE ID#	LOCATION	SAMPLE TYPE	PLM ANALYZED
001	Lobby Mailboxes	Wipe samples	N/D
002	Lobby Mailboxes	Wipe samples	N/D

N/D =Non detected PLM = Polarized Light Microscopy

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: Frank Azizov
 CTSI-Consulting & Testing Services, Inc.
 622 Georges Rd.
 North Brunswick, NJ 08902

Fax: (732) 729-1803

Phone: 732-729-1800

Project: NYU

Customer ID: CTSI50

Customer PO:

Received: 09/13/01 1:52 PM

EMSL Order: 030104187

EMSL Project ID:

Analysis Date: 9/13/2001

Asbestos Analysis of Bulk Materials by PLM via the NY State ELAP 198.1 Method

Sample	Location	Appearance	Treatment	Non-Asbestos		Asbestos	
				% Fibrous	% Non-Fibrous	% Type	
01 030104187-0001	Lobby Mailboxes wipe samples	Brown Fibrous Heterogeneous	Crushed Dissolved	5.00% Synthetic 10.00% Cellulose	25.00% Non-fibrous (other) 60.00% Matrix	None Detected	
02 030104187-0002	Lobby Mailboxes wipe samples	Brown Fibrous Heterogeneous	Crushed Dissolved	18.00% Cellulose	20.00% Non-fibrous (other) 62.00% Matrix	None Detected	

RECEIVED
9-28-01

Gulam Machhiwala

Analyst

Laboratory Manager
or other approved signatory

has been known to miss asbestos in a small percentage of samples which contain asbestos. Negative PLM results cannot be guaranteed. Samples reported as <1% or none should be tested with TEM. The above test report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government.

Analysis performed by EMSL Manhattan (NVLAP #101048-9), NY ELAP 11506

PLM Point Count: 1

1



September 28, 2001

Ms. Stephanie Kung
Senior Environmental Specialist
NEW YORK UNIVERSITY
Environmental Services
14 Waverly Place 2nd Floor
New York, NY 10003

**RE: ASBESTOS INVESTIGATION PERFORMED AT: 200 WATER STREET, NEW YORK, NEW YORK
PROJECT # NY-388-01**

Dear Ms. Kung:

On September 13th and September 15th, 2001, CTSI performed an asbestos investigation at the above referenced premises. New York City and State licensed inspectors conducted the investigation.

The purpose of the investigation was to identify suspect dust and debris that may contain asbestos. An independent licensed laboratory (EMSL) using Polarized Light Microscopy (PLM) method analyzed all samples collected.

A total of three hundreds and seven (307) bulk and wipe samples were collected. Based on sample analysis the following conclusions were derived:

- Asbestos was detected within:

Apartment
Apartment
Apartment
Apartment
Apartment
Apartment
Apartment
Penthouse

PII

Apartment
Apartment
Apartment
Apartment
Apartment
Apartment
Apartment
Penthouse

PII

Apartment
Apartment
Apartment
Apartment
Apartment
Apartment

PII

- All other qualitative wipe and bulk samples were negative for detection of asbestos.

Note: The investigation and sample collection also was performed by EMA. All open windows were closed.

Page 1 of 2

Also, enclosed please find Bulk Sample Analysis and PLM bulk sample certificate of analysis.

If you have any questions or need further information, please do not hesitate to contact our office.

Sincerely,

CONSULTING & TESTING SERVICES, INC.



Farhood Salami
Project Executive
NYC Asbestos License # 84243



Yuriy Shamilov
NYC Asbestos License # 75357

Encl.,

2001:report\ash\un\eyu\200waterst.bulk

