



ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

Received: 7/9/02

4:20:00 PM

ATC Group #: 8425

Analysis Date: 7/9/02

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP. W&P# 1079.01.02
30 W Broadway

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8425 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8425 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8425 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8425 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8425 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 85% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

5



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

Fax #: (212) 922-0630

Date: Tuesday, July 09, 2002

Time: 10:11:18 PM

Comments:

From: MARK PEYSAKHOV

ATC Group #: 8425

Client Project: NYC DEP. W&P# 1079.01.02
30 W. Broadway

Number of Pages: 3
(including cover page)

4