

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 7/10/02 3:00:00 PM
ATC Group #: 8437
Analysis Date: 7/10/02

Fax: (212) 922-0630 Phone: (212) 922-0077
Project: NYC DEP, W&P# 1079.01.02
30 West Broadway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8437 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8437 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8437 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8437 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8437 -5	1800.00	0.0450	0	CHRYSTOLE	0	1	0.0048	22.24	0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-8877
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1079.01.02

CLIENT: NYC DEP

PROJECT: 30 W BROAD

LOCATION: ROOF 4 S (1st FL and)

LABORATORY: ATC

ANALYSIS METHOD: PCMC TEM
circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: R. TRASHINSKY

CONTACT:

8437

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
01	DECON	3		5.0	5.0	0802	1402	760	1800	
02	INTERNAL (A)	3		5.0	5.0	0804	1404	760	1800	
03	EXTERNAL	3		5.0	5.0	0806	1406	760	1800	
04	INT WEST SIDE	3		5.0	5.0	0810	1410	760	1800	
05	INT SOUTH SIDE	3		5.0	5.0	0812	1412	760	1800	
06	FD	1					1412			
07	FD	1					1412			

COMMENTS:

SAMPLE BY: A. TRASHINSKY	DATE: 7-10-02
SIGNATURE:	
RELEASED BY:	DATE: 7/10/02
SIGNATURE:	
RECEIVED BY:	DATE: 7/10/02
SIGNATURE:	15 PM

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8437

Date: Wednesday, July 10, 2002

Client Project: NYC DEP. W&P# 1079.01.02
30 West Broadway

Time: 10:40:06 PM

Number of Pages: 3

(including cover page)

Comments:

7