

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/12/02 4:15:00 PM
 ATC Group #: 8462
 Analysis Date: 7/13/88

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
 30 West Broadway, Roof #3

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
01 8462 -1	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
02 8462 -2	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
03 8462 -3	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
04 8462 -4	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048
05 8462 -5	1800.00	0.0450	0	None Detected	0	0.0048	<22.24	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101167-0, NY State ELAP #10879

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

	24 hr ⁺ /a	12 hr ⁺ /a	6 hr ⁺ /a	3 hr ⁺ /a	Immediate +/a	P.O.
--	-----------------------	-----------------------	----------------------	----------------------	---------------	------

W&P FILE # 1079-01. 02

LABORATORY: ATC

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	ANERA	EPA LEV

TECHNICIAN: R. FORMANDEZ

CONTACT:

LABORATORY: ATC

ANALYSIS METHOD:	PCM	TEM	TEM
circle one	7400	ANERA	EPA LEV

TECHNICIAN: R. FORMANDEZ

[illegible]

COMMENTS:

SAMPLE BY: R. T. Adams DATE: 7-11-64
SIGNATURE: _____
RELEASED BY: _____ DATE: _____
SIGNATURE: _____
RECEIVED BY: ATC DATE: 7/12/62
SIGNATURE: JP 16:15

#8462

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street

New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Padone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8462

Date: Wednesday, July 13, 1988

Client Project: NYC DEP. W&P# 1079.01.02
30 West Broadway, Roof #3

Time: 1:49:12 PM

Comments:

Number of Pages:

3
(including cover page)