

Jul-17-02 12:57P

212 949 1273

P.03

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 7/16/02 3:20:00 PM
ATC Group #: 8516
Analysis Date: 7/17/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
30 West Broadway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 8516 -1	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	
02 8516 -2	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	
03 8516 -3	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	
04 8516 -4	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	
05 8516 -5	1800.00	0.0450	0	None Detected	0	0.0048	<22.24 <0.0048	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10679

JUL-17-02 12:58P

212 949 1273

P.04

228 East 43rd Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C. AIR-MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a P.O.

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

LABORATORY: ATC

CONTACT:

PROJECT: 30 W BROADY (WEST)
LOCATION: ROOF + 3 (WEST)

ANALYSIS METHOD: PCM TEM
circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: R. F. RANDEL

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc.)
01	DECK (PERSONAL)	3		5.0	5.0	0710	1310	360	1800	
02	SWIRLWELL (A)	3		5.0	5.0	0711	1311			
03	ENTRANCE TO ROOF	3		5.0	5.0	0713	1313			
04	INVA (NORTH)	3		5.0	5.0	0717	1317			
05	INVA (WEST)	3		5.0	5.0	0719	1319	360	1800	
06	FB	1					NA			
07	FB	1					NA			

COMMENTS:

SAMPLE BY: R. F. RANDEL	DATE: 7-16-02
SIGNATURE:	
RELEASED BY:	DATE:
SIGNATURE:	
RECEIVED BY: ATC	DATE: 7/16/02
SIGNATURE:	15:20

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

Jul-17-02 12:57P

212 949 1273

P.02



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

ATC Group #: 8316

Fax #: (212) 922-0630

Client Project: NYC DEP, W&P# 1079.01.02

Date: Wednesday, July 17, 2002

30 West Broadway

Time: 11:12:14 AM

Number of Pages:

3

(including cover page)

Comments: