

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 07

P.O. _____

CLIENT: NYC DEP
PROJECT: Side Facades
LOCATION: 30 W Broadway

W&P FILE #: 1079:01:02
LABORATORY: ATC
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II
TECHNICIAN: Celestine Nnamkang

CONTACT: Mr Mike

[illegible]

COMMENTS:

SAMPLE BY: Celestine Nmonye	DATE: 07/24/02
SIGNATURE: [Signature]	
RELEASED BY: Celestine Nmonye	DATE: 07/25/02
SIGNATURE: [Signature]	
RECEIVED BY: M. Berdyan	DATE: 7/26
SIGNATURE: [Signature]	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

07/30/02 16:19 FAX 914 941 4154

TESTWELL LABORATORIES, INC.
ENVIRONMENTAL DIVISION

ASBESTOS LABORATORY

PAGE 1 OF 1
DATE: 7/30/02

TEM AIR SUMMARY SHEET

CLIENT: Warren & Panzer
PROJECT: NYC Dept/ Side Facades
METHOD: AHERA

CLIENT NUMBER	LAB #	VOLUME COLLECTED (L)	CHD OPENINGS ANALYZED	CHD AREA ANALYZED (mm ²)	COUNTABLE ASBESTOS STRUCTURES PER SAMPLE	CONCENTRATION (structures/mm ²)	CONCENTRATION (structures/cc)
001	5228	1440.0	5	0.061	0	< 16.53	< 0.004
002	5229	1440.0	5	0.061	0	< 16.53	< 0.004
003	5230	1440.0	5	0.061	0	< 16.53	< 0.004
004	5231	1440.0	5	0.061	0	< 16.53	< 0.004
005	5232	1440.0	5	0.061	0	< 16.53	< 0.004

TOTAL AVERAGE CONCENTRATIONS		Structures/mm ²	Structures/cc
		< 16.53	< 0.004

NOTE: When no asbestos structures are counted, the Analytical Sensitivity Detection Limit is reported.

COMMENTS:

ANALYST'S SIGNATURE: 