

**228 East 45th Street
New York, NY 10017
(212) 922-4077
Fax (212) 922-0680**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

Fax (212) 922-0680

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate +/a

உ

CLIENT: **WY-123**

W&P FILE #: 1574.01.02

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM TEM

circle one . 7400, AHERA/ EPA LEVEL II

TECHNICIAN:

TEM TEM

EPA LEVEL II

CONTACT:

T: Mike Nolan

PAGE 1 OF 1

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (mg/cc)
001A	Entrance by door	3		4	4	07:20	15:00	1800		
002A	Entrance to balcony	3		4	4	07:31	15:01	1800		
003A	N/W area on balcony	3		4	4	07:32	15:02	1800		
004A	N/W area on ground level	3		4	4	07:33	15:03	1800		
005A	N/W area on ground level	3		4	4	07:34	15:04	1800		
006	Field	1								
007	Field	1								
008	Shaded	1								

COMMENTS:

SAMPLE BY: _____	DATE: 8/15
SIGNATURE: _____	
RELEASED BY: _____	DATE: 8/16
SIGNATURE: _____	
RECEIVED BY: _____	DATE: 8/16/02
SIGNATURE: _____	

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

TESTWELL LABORATORIES, INC.
ENVIRONMENTAL DIVISION

PAGE 1 OF 1

DATE: 8/23/02

ASBESTOS LABORATORY

TEM AIR SUMMARY SHEET

CLIENT: Warren and Panzer Engineers, P.C.PROJECT: NYC-DEP / Cleaning / 30 W. BroadwayMETHOD: ASHERAAVERAGE GRID OPENING AREA = 0.0121 mm²

CLIENT NUMBER	LAB # 01 TEM -	VOLUME COLLECTED (L)	GRID OPENINGS ANALYZED	GRID AREA ANALYZED (mm ²)	COUNTABLE ASBESTOS STRUCTURES PER SAMPLE	CONCENTRATION (Structures/mm ²)	CONCENTRATION (Structures/cc)
001A	6685	1800.0	4	0.048	0	< 20.66	< 0.004
002A	6686	1800.0	4	0.048	0	< 20.66	< 0.004
003A	6687	1800.0	4	0.048	0	< 20.66	< 0.004
004A	6688	1800.0	4	0.048	0	< 20.66	< 0.004
005A	6689	1800.0	4	0.048	0	< 20.66	< 0.004

	Structures/mm ²	Structures/cc
TOTAL AVERAGE CONCENTRATIONS	< 20.66	< 0.004

NOTE: When no asbestos structures are counted, the Analytical Sensitivity (Detection Limit) is reported.

COMMENTS :

ANALYST'S SIGNATURE: 