

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NCDP

PROJECT: Cleaning

LOCATION: 30 W. 34th St

W&P FILE #: 10794102

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM

TECHNICIAN: N. Wells circle one AHERA EPA LEVEL II

CONTACT: Nike Nolan

P.O.

PAGE 1 OF 1

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (lb./cc)
001A	Adj to security booth	3		5	5	07:30	12:10	270	1350	
002A	By Entrance to bldg South	3		5	5	07:31	12:01	270	1350	
003A	By Entrance to bldg West	3		5	5	07:32	12:02	270	1350	
004A	Center area adj to slabs	3		5	5	07:33	12:03	270	1350	
005A	N/W area by slabs	3		5	5	07:34	12:04	270	1350	
col	field	1								
out	field	1								
wr	sealed	1								

SAMPLE BY:	<u>N. Wells</u>	DATE:	<u>8/27</u>
SIGNATURE:	<u>N. Wells</u>	DATE:	<u>8/27</u>
RELEASED BY:	<u>N. Wells</u>	DATE:	<u>8/27</u>
SIGNATURE:	<u>N. Wells</u>	DATE:	<u>8/27</u>
RECEIVED BY:	<u>A. C. T. / G. L.</u>	DATE:	<u>8/28/02</u>
SIGNATURE:	<u>Ag. in</u>		

T02-08-147

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATHENICA

ENVIRONMENTAL SERVICES INC.

Tel. (718) 704-7460

Fax. (718) 704-4005

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-08-147

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.E.

AVERAGE G.O. AREA (mm²): 0.012422

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

PROJECT: NYC DEP, 30 West Broadway

DATE OF REPORT: 08/28/02

DATE OF ANALYSIS: 08/28/02

EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID	LOCATION	VOLUME (ft ³)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (struct./cm ²)	TOTAL ASBESTOS AIR CONC. (fibers/cm ³)	TOTAL ASBESTOS FILTER CONC. (fibers/2mm ²)	AIR CONC. FOR STRUCT. 0.558-5.1um	AIR CONC. FOR STRUCT. 8.25-9um	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
001 A	T02-08-147-1974	Adjacent to security door	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
002 A	T02-08-147-1975	By entrance to building (south)	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
003 A	T02-08-147-1976	By entrance to building (west)	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
004 A	T02-08-147-1977	Center area adjacent to steps	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA
005 A	T02-08-147-1978	North west area by slabs	1350	5	0.0621	0.0046	<0.0046	<16.10	NA	NA	NA	NA

E. Diminikakis

ANALYST
E. Diminikakis

Emilio P. A. Jr.

LABORATORY DIRECTOR
Spiro Dougaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report reflects only to firms tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.