

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

30 W Broadway BMCC

Received: 6/28/02

5:00:00 PM

ATC Group #: 8323

Analysis Date: 6/29/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
01 8323 -1	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
02 8323 -2	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
03 8323 -3	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
04 8323 -4	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	
05 8323 -5	1680.00	0.0562	0	None Detected	0	0	0.0041 <17.79 <0.0041	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

23

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF

8323

P.O.

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: NYC DEP

W&P FILE #: 1079-01-02

CONTACT:

PROJECT: 30 W 50th DMCC

LABORATORY: ATC

LOCATION: ROOF # 2 15th FLR

ANALYSIS METHOD: PCM TEM

circle one 7400 AHEDA EPA LEVEL II

TECHNICIAN: R. FERNANDEZ

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		FLOWRATE STOP	ON	TIME OFF		TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
				START	STOP			ON	OFF			
01	DECON (PERSONAL)	3		7.0	7.0	7.0	0650	0650	1050	240	1680	
02	ENTRANCE TO ROOF (SOUTH SIDE)	3		7.0	7.0	7.0	0652	0652	1052	240	1680	
03	STAIRWELL / ROOF DECK	3		7.0	7.0	7.0	0654	0654	1054	240	1680	
04	INP EAST	3		7.0	7.0	7.0	0656	0656	1056	240	1680	
05	INP WEST	3		7.0	7.0	7.0	0658	0658	1058	240	1680	
06	FB	1										
07	FB	1										

COMMENTS:

SAMPLE BY: R. FERNANDEZ	DATE: 6-28-07
SIGNATURE: 	
RELEASED BY:	DATE:
SIGNATURE:	
RECEIVED BY: H. Lopez	DATE: 06/28/07
SIGNATURE:	

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)		
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement	7 - Personal		
4 - During Glove Bag Removal	8 - Background		

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8323

Date: Saturday, June 29, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
30 W Broadway BMCC

Time: 12:52:47 PM

Comments:

Number of Pages: 3
(including cover page)

22