

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0650

Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02

30 West Broadway

Received: 7/1/02

3:00:00 PM

ATC Group #: 8368

Analysis Date: 7/1/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8368 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8368 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8368 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8368 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8368 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

228 East 45th Street
New York, NY 10017
(212) 922-8077
Fax (212) 922-8630

8368

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

W&P FILE #: 1019-01-02

CONTACT:

LABORATORY: ATC

ANALYSIS METHOD: PCM TEM

circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: R. TELANDEL

CLIENT: NYC DEP

PROJECT: 30 W BRUNY

LOCATION: ROOF # 2 (EAST)

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (µg/cc)
01	ENTRANCE TO ROOF	3		5.0	5.0	0720	1020	360	1800	
02	DECK	3		5.0	5.0	0722	1322			
03	STAIRWELL (A)	3		5.0	5.0	0724	1324			
04	TWA EAST SIDE ROOF	3		5.0	5.0	0726	1326			
05	TWA WEST "	3		5.0	5.0	0730	1330	360	1800	
06	FB	1				NA				
07	FB	1				NA				

COMMENTS:

SAMPLE BY: R. TELANDEL	DATE: 7-1-02
SIGNATURE: [Signature]	DATE:
RELEASED BY: [Signature]	DATE:
SIGNATURE: [Signature]	DATE: 7/1/02
RECEIVED BY: ATC	DATE: 7/1/02
SIGNATURE: [Signature]	DATE: 7/1/02

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: ROMAN PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 8368

Date: Monday, July 01, 2002

Client Project: NYC-DEP W & P File #: 1079.01.02
30 West Broadway

Time: 11:19:18 PM

Number of Pages: 3

(including cover page)

Comments:

7