

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/5/02

1:00:00 PM

ATC Group #: 8400

Analysis Date: 7/5/02

Project: NYC-DEP W & P File # 1079.01.02

30 West Broadway, Roof #2

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
01 8400 -1	1600.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
02 8400 -2	1600.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
03 8400 -3	1600.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
04 8400 -4	1600.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
05 8400 -5	1600.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

2



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

ATC Group #: 3400

Fax #: (212) 922-0630

Client Project: NYC-DEP W & P File # 1079.01.02
30 West Broadway, Roof #2

Date: Friday, July 05, 2002

Time: 4:07:51 PM

Comments:

Number of Pages: 3
(including cover page)

Leonard / Krisn

10 Pages

1