



ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
30 W Broadway

Received: 7/9/02

4:20:00 PM

ATC Group #: 8425

Analysis Date: 7/9/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8425 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8425 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8425 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8425 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8425 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

8623

WARREN & PANZER ENGINEERS, P.C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

P.O.

CLIENT: NYC DEP

PROJECT: 30 W BRDNY

LOCATION: ROOF # 1

W&P FILE #: 1079-01-02

TURN AROUND: 24 HRS

TECHNICIAN: R. FERNANDEZ

Analysis Method: PCM-7400

(circle one) TEM - AHERA

TEM - EPA LEVEL II

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE		TIME		TOTAL TIME	VOLUME CONCENTR	
				START	STOP	ON	OFF		(liters)	(lb./ft.)
01	ENTRANCE TO ROOF	3		5.0	5.0	0701	1301	360	1800	
02	STAIRWELL (A)	3		5.0	5.0	0702	1302			
03	DECK	3		5.0	5.0	0705	1305			
04	IN/A (SOUTH)	3		5.0	5.0	0708	1308			
05	IN/A (NORTH)	3		5.0	5.0	0711	1311	360	1800	
06	FB	1								
07	FB	1								

SAMPLED BY: A. FERNANDEZ DATE: 07-09-02

SIGNATURE: 

RELEASED BY: DATE:

SIGNATURE: DATE: 7/9

RECEIVED BY: DATE: 10:20

SIGNATURE: 

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION



ATC Associates Inc.

104 East 25 Street
New York, NY 10010

TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.

From: MARK PEYSAKHOV

Fax #: (212) 922-0630

ATC Group #: 842S

Date: Tuesday, July 09, 2002

Client Project: NYC DEP. W&P# 1079.01.02
30 W. Broadway

Time: 10:11:18 PM

Number of Pages: 3

(including cover page)

Comments:

4