

10/04/2002 16:12 FAX

0008



ATHENICA
ENVIRONMENTAL SERVICES INC.
Tel. (718) 784-7490
Fax. (718) 784-4065

CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-10-014
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.F.
AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYCDER, 62 Williams St.
DATE OF REPORT: 10/03/02
DATE OF ANALYSIS: 10/03/02
EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAB. ID	LOCATION	VOLUME (ft ³)	G.O.'s ANAL. VZFD	AREA ANALY. ZED (mm ²)	ANALYT. SENSITV. (direct/cm ³)	TOTAL ASBESTOS AIR CONC. (direct/cm ³)	TOTAL ASBESTO S FILTER CONC. (air/mm ²)	AIR CONC. FOR STRUCT. 0.55-5µm	AIR CONC. FOR STRUCT. 5-250µm	ASBEST. TYPE CHNVS.	AMPHIB. ASBEST TYPE SPECIFY
ID01	T02-10-014-2750	IWA 1 st side of W/A	1500	4	0.0046	0.0046	<0.0046	<18.07	NA	NA	NA	NA
ID02	T02-10-014-2751	IWA 2 nd side of W/A	1500	4	0.0046	0.0046	<0.0046	<18.07	NA	NA	NA	NA
ID03	T02-10-014-2752	IWA 3 rd side of W/A	1500	4	0.0046	0.0046	<0.0046	<18.07	NA	NA	NA	NA
ID04	T02-10-014-2753	IWA 4 th side of W/A	1500	4	0.0046	0.0046	<0.0046	<18.07	NA	NA	NA	NA
ID05	T02-10-014-2754	Exit to the roof	1500	4	0.0046	0.0046	0.0046	18.07	0.0046	<0.0046	Chrys.	NA

ANALYST
E. Siobaki

E. Siobaki

LABORATORY DIRECTOR
Spino Douglas

Spino Douglas

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be stated for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported asbestos concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

10/04/2002 16:13 FAX

0000

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0030

WARREN & PANZER ENGINEERS, P.C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

CLIENT: NYC DEP
PROJECT: 62 WILLIAMS ST.
LOCATION: ROOF

W&P FILE #: 1079-01-02
LABORATORY: W & P
ANALYSIS METHOD: PCM TEM TEM
7400 AHERA EPA LEVEL II
TECHNICIAN: IDRIS IDOWU

CONTACT: MICHAEL NELSON

P.O. _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (lb./cc.)
ID01	1st SIDE OF WH	03		05	05	1000	1500	300	1500	
ID02	2nd SIDE OF WH	03		05	05	1001	1501	300	1500	
ID03	3rd SIDE OF WH	03		05	05	1002	1502	300	1500	
ID04	4th SIDE OF WH	03		05	05	1003	1503	300	1500	
ID05	EXIT TO THE ROOF	03		05	05	1004	1504	300	1500	
ID06	FIELD BLANK	01				N/A				
ID07	FIELD BLANK	01				N/A				
ID08	SEALED BLANK	01				N/A				

COMMENTS:

702-10-014

SAMPLE BY: IDRIS IDOWU DATE: 10-02-02
SIGNATURE: [Signature]
RELEASED BY: IDRIS IDOWU DATE: 10-02-02
SIGNATURE: [Signature]
RECEIVED BY: A. CAGLIA DATE: 10/3/02
SIGNATURE: [Signature]

SAMPLE TYPE CODES			
1 - Blank	5 - Final Clearance (inside)	7 - Personal	8 - Background
2 - Pre-Abatement	6 - Final Clearance (outside)		
3 - During Abatement			
4 - During Glove Bag Removal			

SEE REVERSE SIDE FOR ANALYSIS INFORMATION