

10/23/2002 15:18 FAX

010

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 704-7490
Fax. (718) 704-0885**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY**

CLIENT: **Watten & Panzer Engineers, P.C.**
 PROJECT: **NYC DEP, 123 Williams Street**
 LABORATORY ID #: **T02-10-115**
 DATE OF REPORT: **10/19/02**
 ANALYT. METHODOLOGY: **AHERA**
 DATE OF ANALYSIS: **10/19/02**
 FILTER TYPE: **M.C.B.**
 EFFECTIVE FILTER AREA (mm²): **385**
 AVERAGE G.O. AREA (mm²): **0.013838**

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (M)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIVITY (STRUCT./CM ²)	TOTAL ASBESTOS AIR CONC. (STRUCT./CM ²)	TOTAL ASBESTOS FILTER CONC. (AIR/CM ²)	AIR CONC. FOR STRUCT. 0.55<S<5µm	AIR CONC. FOR STRUCT. S>5µm	ASBEST. TYPE CHRYS.	ASBEST. TYPE SPECIFY
01	T02-10-115-3262	Decon penthouse	1500	4	0.0554	0.0046	0.0046	18.07	<0.0046	0.0046	Chrys.	NA
02	T02-10-115-3263	North east side adjacent stairway	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA
03	T02-10-115-3264	North east side of roof	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA
04	T02-10-115-3265	North east side of roof	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA
05	T02-10-115-3266	North east side of roof	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA

ANALYST
E. Sioulis
LABORATORY DIRECTOR
Spiro Donganis

LABORATORY CERTIFICATION NUMBERS: NY LAB 104750, 104751, 104752

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- This report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

