

10/15/2002 17:37 FAX

013

**ATHENICA**
 ENVIRONMENTAL SERVICES INC.
 TEL (718) 784-7480
 FAX (718) 784-0885

AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY

 CLIENT: Warren & Paret Engineers, P.C.
 LABORATORY ID #: T02-10-085

 ANALYT. METHODOLOGY: AHERA
 FILTER TYPE: M.C.E.

 AVERAGE G.O. AREA (mm²): 0.013838

 PROJECT: NYC DEP, 123 Williams Street
 DATE OF REPORT: 10/14/02
 DATE OF ANALYSIS: 10/14/02
 EFFECTIVE FILTER AREA (mm²): 385

LABORATORY RESULTS

CLIENT #	LAE ID #	LOCATION	VOLUME (L)	G.O.'s ANAL. YZED	AREA ANALY ZED (mm ²)	ANALYT. SENSITV. (structural)	TOTAL ASBESTOS AIR CONC. (structural)	TOTAL ASBESTOS FILTER CONC. (structural)	AIR CONC. FOR STRUCT. 0.55-4um	AIR CONC. FOR STRUCT. 0.55-4um	ASBEST. TYPE CHRTS.	ALPHAB. ASBEST TYPE SPECIFY
01	T02-10-085-3111	East side stairway (B) roof entry	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
02	T02-10-085-3112	East side / south side	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
03	T02-10-085-3113	South side by east	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
04	T02-10-085-3114	East by south east	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA
05	T02-10-085-3115	East by south east	1680	4	0.0554	0.0041	<0.0041	<18.07	NA	NA	NA	NA

ANALYST

E. Dumitracas

LABORATORY DIRECTOR

Sprio Douglas

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling certificates will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

