

10/21/2002 08:45 FAX

007

**ATHENICA**

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490
Fax. (718) 784-4085

CLIENT: Warren & Panzer Engineers, P.C.

LABORATORY ID #: T02-10-108

ANALYT. METHODOLOGY: AHERA

FILTER TYPE: M.C.R.

AVERAGE G.O. AREA (mm²): 0.013838

PROJECT: NYC DEP, 123 Williams Street

DATE OF REPORT: 10/18/02

DATE OF ANALYSIS: 10/18/02

EFFECTIVE FILTER AREA (mm²): 385**AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY****LABORATORY RESULTS**

CLIENT #	LAB. ID #	LOCATION	VOLUME (l)	G.O.'s ANALYZED	AREA ANALYZED (mm ²)	ANALYT. SENSITIV. (structure/mm ²)	TOTAL ASBESTOS AIR CONC. (structure/mm ²)	TOTAL ASBESTOS FILTER CONC. (structure/mm ²)	AIR CONC. FOR STRUCT. 0.5-5.0µm	AIR CONC. FOR STRUCT. ≥5.0µm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
01	T02-10-108-3226	Roof-penthouse deck	1470	4	0.0554	0.0047	<0.0047	<18.07	NA	NA	NA	NA
02	T02-10-108-3227	Roof east side	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA
03	T02-10-108-3228	Roof east side	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA
04	T02-10-108-3229	11 th fl. east back	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA
05	T02-10-108-3230	11 th fl. east back	1500	4	0.0554	0.0046	<0.0046	<18.07	NA	NA	NA	NA

ANALYST
E. Dimitrakos

LABORATORY DIRECTOR
Spiro Donganis**LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955**

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

006

**2228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

(24 hr⁺/a) 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate⁺/a P.O. _____

CONTACT: Mr. Adonis

W&P FILE #: 1075-0102

LABORATORY:

ANALYSIS METHOD: PCM
circle one

TECHNICIAN: J. S. G. 855-

TEMA ANHERA
TEMA EPA LEVI

[illegible]

SAMPLE BY: <i>[Signature]</i>	DATE: 11-17-02
SIGNATURE: <i>[Signature]</i>	
RELEASED BY: <i>[Signature]</i>	DATE: 10-17-02
SIGNATURE: <i>[Signature]</i>	
RECEIVED BY: <i>[Signature]</i>	DATE: 10-18-02
SIGNATURE: <i>[Signature]</i>	

702-10-108

SAMPLE TYPE CODES

	5 - Final Clearance (inside)	6 - Final Clearance (outside)	7 - Personal	8 - Background
1 - Blank				
2 - Pre-Abatement				
3 - During Abatement				
4 - During Glove Bag Removal				

SEE REVERSE SIDE FOR ANALYSIS INFORMATION