




AIRBORNE ASBESTOS ANALYSIS BY TRANSMISSION ELECTRON MICROSCOPY


CLIENT: Warren & Panzer Engineers, P.C.
LABORATORY ID #: T02-11-031
ANALYT. METHODOLOGY: AHERA
FILTER TYPE: M.C.E.
AVERAGE G.O. AREA (μm^2): 0.013433

PROJECT: NYC DEP, 130 William Street
DATE OF REPORT: 11/06/02
DATE OF ANALYSIS: 11/06/02
EFFECTIVE FILTER AREA (mm^2): 385

LABORATORY RESULTS

CLIENT #	LAB. ID #	LOCATION	VOLUME (ft)	G.O.'s ANALYZED	AREA ANALYZED (mm^2)	ANALYT. SENSITIV. (struct./ cm^2)	TOTAL ASBESTOS AIR CONC. (struct./ cm^3)	TOTAL ASBESTOS FILTER CONC. (str./ mm^2)	AIR CONC. FOR STRUCT. 0.555-5.0 μm	AIR CONC. FOR STRUCT. 8-25.0 μm	ASBEST. TYPE CHRYS.	AMPHIB. ASBEST. TYPE SPECIFY
10WA	T02-11-031-3856	Inside clean room of person. decon.	1800	4	0.0537	0.0040	<0.0040	<18.61	NA	NA	NA	NA
20WA	T02-11-031-3857	Within 6ft of window entrance into the W.A.	1800	4	0.0537	0.0040	<0.0040	<18.61	NA	NA	NA	NA
31WA	T02-11-031-3858	On setback. Center of work area	1800	4	0.0537	0.0040	<0.0040	<18.61	NA	NA	NA	NA
41WA	T02-11-031-3859	On setback. South section of W.A.	1800	4	0.0537	0.0040	<0.0040	<18.61	NA	NA	NA	NA
51WA	T02-11-031-3860	On setback. North section of W.A.	1800	4	0.0537	0.0040	<0.0040	<18.61	NA	NA	NA	NA


ANALYST
R. Dimitrakas


LABORATORY DIRECTOR
Spiro Dongaris

LABORATORY CERTIFICATION NUMBERS: NVLAP 101958, ELAP 10955

- Athenica Environmental Services Inc. (AES), is responsible only for information pertaining to samples taken by its employees.
- Air sampling cassettes will be stored for sixty (60) days. AES Inc., should be notified within this time frame for a true duplicate analysis.
- If AES Inc., did not conduct the sampling, the reported airborne concentration was derived based on information provided by the client. Under these circumstances, the air concentration data is supplied solely for the convenience of the client.
- The report relates only to items tested. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. Test reports may not be reproduced except in full and with prior approval of AES Inc.
- The liability of Athenica Environmental Services Inc. with respect to the services charged, shall in no event exceed the amount of the invoice.

**220 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630**

WARREN & PANZER ENGINEERS, P. C.
AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1.

P.O. _____

CLIENT: NYC. D.E.P.

PROJECT: DEP Fibre control.

LOCATION: 130 William St. NY. NY.

W&P FILE #: 1079.01.02

LABORATORY: Warren and Panzer

ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II

TECHNICIAN: Yuru Bedin.

CONTACT: *Mr. M. Nolan.*

Setback of the Buntling

[illegible]

COMMENTS:

SAMPLE BY: Vanya Bedin. DATE: 11-5-02

SIGNATURE: W. B. B. B.

RELEASED BY: Yudy Bedin. DATE: 11-5-02

SIGNATURE: Yung Bedin Released 18:30 PM.

RECEIVED BY: A. C. HIGGINS DATE: 11/6/02

SIGNATURE: U. G. [Signature]

104-11-09

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION