

Asbestos Inspection Report

Premise No. 150 WILLIAM STREET (81 ^{AKA} FULTON ST)					Inspection Date: AS NOTED	
Floor Roof, 17, 13, 10	Zip 10038	Borough 1	Block 93	Lot 1	Squad # N/A	Badge # A020
Inspector Dennis Antzoulatos		Building Type COMMERCIAL		Basis of Inspection WTC Survey		Photos Taken Yes/No
Contractor's Name Benjamin Kurzban & Son Control				Sample Number N/A		
Address City 1248 Ralph Avenue, Brooklyn				Sample Number N/A		
State Zip Phone NY 11236 (718)531-2900				Sample Number N/A		
Laboratory Name Warren & Panzer Engineers Inc.				Owner's Name		
Address City 228 East 45 Street New York				Address City		
State Zip Phone NY 10017 (212) 922-0077				State Zip Phone		
Contact Person				Time of Inspection from: AS NOTED		

WEDNESDAY NOVEMBER 13 2002

THE CLEAN UP OF THE ROOF OF THE PREMISE (ANN STREET SIDE ONLY) BEGINS. WORKERS WILL UTILIZE DOUBLE TYVEK SUITS AND STEP OFF PADS IN LIEU OF A REMOTE DECONTAMINATION UNIT DUE TO SPACE LIMITATIONS. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP WAS PERFORMED BY EDMAN DIBRA (CERTIFICATE # AH01-12337 EXP 02/03). FOUR AIR SAMPLES WERE SET UP ON THE ROOF AND ONE SAMPLE WAS RUN INSIDE THE BUILDING AT THE ENTRANCE TO THE ROOF.

THURSDAY NOVEMBER 14 2002 - FRIDAY NOVEMBER 15 2002

THE CLEAN UP OF THE ROOF OF THE PREMISE WAS COMPLETED. AIR SAMPLING FOR THIS PORTION OF THE CLEAN UP WAS PERFORMED BY FESTY OSEMWEIGIE (CERTIFICATE # AH01-01030 EXP 01/03) OF WARREN & PANZER ENGINEERS. AT THE CONCLUSION OF THE CLEAN UP ACTIVITIES, FESTY OSEMWEIGIE CONDUCTED A VISUAL INSPECTION OF THE CLEANED SURFACES AND HE OBSERVED NO VISIBLE WTC DEBRIS.

SATURDAY NOVEMBER 16 2002

THE CLEAN UP OF THE 17TH FLOOR SET BACK WAS CONDUCTED TODAY. ACCESS TO THE SET BACK WAS ACHIEVED THROUGH AN OFFICE SPACE WINDOW. FLAPS WERE INSTALLED AT THE WINDOW USED FOR ACCESS. PLASTIC SHEETING WAS INSTALLED ON TOP OF THE CARPETING FROM THE ELEVATOR LOBBY TO THE WINDOW. DESK AND FILING CABINET IN THE IMMEDIATE VICINITY OF THE WINDOW WERE COVERED WITH PLASTIC SHEETING. DUE TO SPACE LIMITATIONS NO REMOTE DECON UNIT WAS ERECTED. STEP OFF PADS WERE UTILIZED AND WORKERS DONNED DOUBLE PROTECTIVE SUITS. THREE AIR SAMPLES WERE RUN INSIDE THE OFFICE SPACE AND TWO AIR SAMPLES WERE RUN ON THE SET BACK. AIR SAMPLING WAS PERFORMED BY FESTY OSEMWEIGIE OF WARREN & PANZER ENGINEERS. THE CLEAN UP ON THE 17TH FLOOR SET BACK WAS LIMITED TO THE FULTON STREET SIDE ONLY. NO WTC DEBRIS WAS OBSERVED ON THE 'ANN ST., GOLD ST. AND WILLIAM ST. SIDES

Asbestos Inspection Report

Premise No. 150 WILLIAM STREET (AKA 81 FULTON STREET)	Inspection Date: AS NOTED
Inspector Dennis Antzoulatos	Page <u>2</u> of <u>2</u>

AT THE CONCLUSION OF THE CLEAN UP ACTIVITIES, FESTY OSEMWEIGIE CONDUCTED A VISUAL INSPECTION OF THE CLEANED SURFACES AND HE OBSERVED NO VISIBLE WTC DEBRIS. THE CLEAN UP OF THE 13TH FLOOR SET BACK BEGAN. ACCESS TO THE SET BACK WAS ACHIEVED THROUGH AN OFFICE SPACE WINDOW. THE SAME PROCEDURES REGARDING WORK PLACE PREPARATION AND AIR SAMPLING WERE OBSERVED FOR THIS SETBACK AS WELL. AIR SAMPLING FOR THIS LOCATION WAS PERFORMED BY OCHOGHO ERHABOR (CERTIFICATE #AH CO-16198 EXP 12/02). ALL FOUR SIDES OF THE SET BACK (FULTON STREET, ANN STREET, GOLD STREET AND WILLIAM STREET) UNDERWENT CLEANUP ACTIVITIES. THE FULTON STREET AND WILLIAM STREET SIDES WERE TARGETED TODAY. THE ANN STREET AND GOLD STREET SIDES WILL BE CLEANED TOMORROW.

SUNDAY NOVEMBER 17 2002

THE CLEAN UP OF THE 13TH FLOOR SET BACK WAS COMPLETED. AIR SAMPLING WAS PERFORMED BY OCHOGHO ERHABOR OF WARREN & PANZER ENGINEERS. AT THE CONCLUSION OF THE CLEAN UP ACTIVITIES, I CONDUCTED A VISUAL INSPECTION OF THE CLEANED SURFACES AND I OBSERVED NO VISIBLE WTC DEBRIS. THE CLEAN UP OF THE 10TH FLOOR SET BACK WAS CONDUCTED TODAY. CLEAN UP ON THIS SET BACK WAS LIMITED THE GOLD STREET AND FULTON STREET SIDES ONLY. AIR SAMPLING FOR THIS SET BACK WAS PERFORMED BY FESTY OSEMWEIGIE OF WARREN & PANZER ENGINEERS. AT THE CONCLUSION OF THE CLEAN UP ACTIVITIES FESTY OSEMWEIGIE CONDUCTED A VISUAL INSPECTION OF THE CLEANED SURFACES AND HE OBSERVED NO VISIBLE WTC DEBRIS. THE PROTOCOLS USED FOR THE 17TH FLOOR AND 13TH FLOOR SETBACKS WERE USED FOR THE 10TH FLOOR SET BACK.

R